



Issue Date:	April 20, 2009;
Code/Section:	Arizona Revised Statutes (A.R.S.) Title 40, Section 360.22.J
Developed By:	David McCarthy, P.E., Mechanical Plans Engineer
Revised By:	John Brean, P.E. Mechanical Plans Engineer, September 17, 2020
References:	IFGC 404.17.3

ARIZONA REVISED STATUES (A.R.S.), SECTION 40-360.22.J AS A SUPPLEMENT TO THE CITY OF PHOENIX PLUMBING CODE

The Rule will be applied as follows:

1. Plastic underground sewer piping shall have a continuous 18 gauge [or larger] copper tracer wire installed with and attached to the plastic sewer piping material at 8'-0" O.C. This wire shall extend from the sewer pipe connection at the property or right-of-way line to the connection at the building drain. This tracer wire shall terminate (in a visible location) 12" above ground at the sewer/building drain connection.
2. Plastic underground water piping shall have a continuous 18 gauge [or larger] copper tracer wire installed with and attached to the plastic water piping material at 8'-0" O.C. This wire shall extend from the service connection at the meter box to the riser that supplies the building served. This tracer wire shall terminate (in a visible location) 12" above ground at the water service riser. Landscape irrigation water systems are not regulated by the Phoenix Plumbing Code downstream of the backflow prevention device.
3. Gas piping (non-metallic) shall have a tracer wire as specified in 2018 IFGC 404.17.3.

This publication can be made available in alternate formats (Braille, large print or digital media) upon request. Contact Planning & Development at (602) 262-7811 voice or (602) 534-5500 TTY.