



- Hydraulic elevators, roped-hydraulic elevators, and hydraulic vertical platform lifts are required to have a qualified elevator company perform a Category 1 test annually. When the test is complete, a tag, signed and dated by the mechanic, is placed adjacent to or on the controller.  
**Code reference: ASME A17.1 – 8.6.5.14, and 8.6.1.7.2.**
- Piston grippers, and overspeed valves shall be tested with rated load every 5 years, When the test is complete a tag, signed and dated by the mechanic is placed on the equipment.  
**Code reference: ASME A17.1 8.6.5.16.4 and 8.10.3.2.5 (N),along with 8.6.5.16.5 and 8.10.3.2.5(o).**
- Traction elevators are required to have a “Category 1 test” annually. When the test is complete a tag, signed and dated by the mechanic is placed adjacent to or on the controller.  
**Code reference: ASME A17.1 – 8.6.4.19, and 8.6.1.7.2.**
- Traction elevators are also required to have a “Category 5 test” performed once every five years. When the test is complete tags, signed and dated by the mechanic, are placed on the buffers and adjacent to or on the controller.  
**Code reference: ASME A17.1 – 8.6.4.20, and 8.6.1.7.2.**
- Standby power, when provided, should be tested annually.  
**Code reference: ASME A17.1 – 8.6.4.19.7**
- Firefighters Emergency Operation should be tested by trained personnel monthly. A fire service test log shall be kept on site.  
**Code reference: ASME A17.1 – 8.6.11.1**