



2020

**INDUSTRIAL PRETREATMENT
ANNUAL REPORT**

Phoenix
Scottsdale
Tempe
Gilbert
Glendale
Mesa
ARIZONA



City of Phoenix
WATER SERVICES DEPARTMENT
ENVIRONMENTAL SERVICES DIVISION
Quality Reliability Value

February 26, 2021

SENT VIA ELECTRONIC MAIL TO:
pretreatment@azdeq.gov

ADEQ Pretreatment
Water Quality Utility Field Service Unit
Arizona Department of Environmental Quality
1110 West Washington Street Mail Code: 5415B-1
Phoenix, Arizona 85007-2952

To whom it may concern,

Re: **AZPDES Permit AZ0020559 – 23rd Avenue Wastewater Treatment Plant**
NPDES Permit AZ0020524 – 91st Avenue Wastewater Treatment Plant
Industrial Pretreatment Programs Annual Report

We are pleased to submit the Industrial Pretreatment Annual Report (Report) for the 23rd Avenue and 91st Avenue Wastewater Treatment Plants. Once again we are submitting a consolidated Report for both plants. The Report covers the reporting period beginning on January 1, 2020 and ending on December 31, 2020 and includes information required by the National Pollutant Discharge Elimination System Permit, effective October 4, 2016; and the Arizona Pollutant Discharge Elimination System Permits, effective August 5, 2019.

In addition to the City of Phoenix, this Report also includes Significant Industrial User compliance information from the Cities of Glendale, Mesa, Scottsdale, Tempe, and the Town of Gilbert.

Sincerely,


Eric Froberg
Interim Water Services Department Director

Enclosure

c: Amelia Whitson, EPA
Edward Meza, Town of Gilbert
David Nigh, City of Glendale
Gene Gonzales, City of Mesa
Krystal Heyer, City of Scottsdale

Richard Dalton, City of Tempe
Linda Palumbo, City of Phoenix
Stephen Wetherell, City of Phoenix
Jesse D. Flores, City of Phoenix
Chelsey Weaver, City of Phoenix

PRETREATMENT PROGRAM ANNUAL REPORT

For the Year Ending December 31, 2020

for the
23rd Avenue Wastewater Treatment Plant
(AZPDES Permit № AZ0020559)
the
91st Avenue Wastewater Treatment Plant
(NPDES Permit № AZ0020524)

PHOENIX, ARIZONA

TABLE OF CONTENTS

PART 1

WASTEWATER TREATMENT PLANTS & THE SUBREGIONAL OPERATING GROUP (SROG)

WWTPs AND SROG	SECTION 1.1
▪ WWTP AND SROG INTRODUCTION.....	1 - 3
▪ SYSTEM MAP.....	4
▪ SUMMARY OF PRIORITY POLLUTANT RESULTS	5
▪ 23RD AVENUE WWTP PRIORITY POLLUTANTS	6 - 19
▪ 91ST AVENUE WWTP PRIORITY POLLUTANTS.....	20 - 33
▪ UPSET, INTEFERENCE & PASSTHROUGH.....	34 - 35
▪ REVIEW OF LOCAL LIMITS	36
SIGNIFICANT NON-COMPLIANCE (SNC)	SECTION 1.2
▪ NUMERICAL HISTORY OF SIUS IN SNC	37
▪ GRAPHED HISTORY OF SIUS IN SNC	38
▪ SIUS IN SNC FOR 2020, TO BE PUBLISHED IN 2021	39 - 40
▪ 2020 NEWSPAPER PUBLICATIONS FOR 2019 SNCS	41 - 42
DEFINITIONS, LIMITS, AND FORMS	SECTION 1.3
▪ DEFINITIONS	43 - 46
▪ SROG LIMIT APPENDICES (EXCEPT TEMPE)	47 - 72
▪ TEMPE LIMIT APPENDICES.....	73 - 88
▪ GUIDE TO SIU COMPLIANCE STATUS REPORT FORM.....	89 - 94

PART 2
THE SROG CITY PRETREATMENT PROGRAMS

CITY OF GLENDALE	SECTION 2.1
▪ CERTIFICATION STATEMENT	95
▪ JURISDICTION DESCRIPTION	96
▪ PRETREATMENT PROGRAM CHANGES, P2, TRAINING, AND OTHER ACTIVITIES	97 - 98
▪ PRETREATMENT PROGRAM BUDGET & EXPENDITURES	99
▪ LIST OF SIUS	100
▪ SIU ADDITIONS, DELETIONS, AND NAME CHANGES	101
▪ ANNUAL PRETREATMENT PERFORMANCE SUMMARY	102
▪ SIU COMPLIANCE STATUS REPORTS	103 - 114
CITY OF MESA	SECTION 2.2
▪ CERTIFICATION STATEMENT	115
▪ JURISDICTION DESCRIPTION	116 - 118
▪ PRETREATMENT PROGRAM CHANGES, P2, TRAINING, AND OTHER ACTIVITIES	119 - 122
▪ PRETREATMENT PROGRAM BUDGET & EXPENDITURES	123
▪ LIST OF SIUS	124
▪ SIU ADDITIONS, DELETIONS, AND NAME CHANGES	125
▪ ANNUAL PRETREATMENT PERFORMANCE SUMMARY	126
▪ SIU COMPLIANCE STATUS REPORTS	127 - 134
CITY OF PHOENIX	SECTION 2.3
▪ CERTIFICATION STATEMENTS	135 - 136
▪ JURISDICTION DESCRIPTION	137
▪ PRETREATMENT PROGRAM CHANGES, P2, TRAINING, AND OTHER ACTIVITIES	138 - 146
▪ PRETREATMENT PROGRAM BUDGET & EXPENDITURES	147 - 149
▪ LIST OF SIUS	150 - 155
▪ SIU ADDITIONS, DELETIONS, AND NAME CHANGES	156 - 157
▪ ANNUAL PRETREATMENT PERFORMANCE SUMMARIES	158 - 159
▪ SIU COMPLIANCE STATUS REPORTS	160 - 351
CITY OF SCOTTSDALE	SECTION 2.4
▪ CERTIFICATION STATEMENT	352
▪ JURISDICTION DESCRIPTION	353 - 354
▪ PRETREATMENT PROGRAM CHANGES, P2, TRAINING, AND OTHER ACTIVITIES	355 - 356
▪ PRETREATMENT PROGRAM BUDGET & EXPENDITURES	357
▪ LIST OF SIUS	358
▪ SIU ADDITIONS, DELETIONS, AND NAME CHANGES	359
▪ ANNUAL PRETREATMENT PERFORMANCE SUMMARY	360
▪ SIU COMPLIANCE STATUS REPORTS	361 - 370

CITY OF TEMPE SECTION 2.5

- CERTIFICATION STATEMENT371
- JURISDICTION DESCRIPTION372
- PRETREATMENT PROGRAM CHANGES, P2, TRAINING,
AND OTHER ACTIVITIES373 - 381
- PRETREATMENT PROGRAM BUDGET & EXPENDITURES382
- LIST OF SIUS383 - 384
- SIU ADDITIONS, DELETIONS, AND NAME CHANGES385
- ANNUAL PRETREATMENT PERFORMANCE SUMMARY386
- SIU COMPLIANCE STATUS REPORTS.....387 - 444

TOWN OF GILBERT SECTION 2.6

- CERTIFICATION STATEMENT445
- JURISDICTION DESCRIPTION446
- PRETREATMENT PROGRAM CHANGES, P2, TRAINING,
AND OTHER ACTIVITIES447 - 450
- PRETREATMENT PROGRAM BUDGET & EXPENDITURES451
- LIST OF SIUS452
- SIU ADDITIONS, DELETIONS, AND NAME CHANGES453
- ANNUAL PRETREATMENT PERFORMANCE SUMMARY454
- SIU COMPLIANCE STATUS REPORTS.....455 - 468

SECTION 1.1

WWTPs & SROG

Introduction

The Sub-Regional Operating Group (SROG)



The Sub-Regional Operating Group, or SROG, was formed in 1979 pursuant to a joint exercise of powers agreement (SROG Agreement) between the Cities of Glendale, Mesa, Phoenix, Scottsdale, Tempe, and the Towns of Gilbert and Youngtown to jointly own and operate the 23rd and 91st Avenue Wastewater Treatment Plants (WWTP) and their interceptor systems. The 23rd Avenue WWTP was part of the SROG system until it was removed in 1983 through an amendment to the SROG Agreement and currently services only the City of Phoenix. Gilbert sold its purchased capacity in the system to Mesa in 1981 and Youngtown sold its purchased capacity in the system to Phoenix in 1995. Physical changes to the system were completed in late 1995. With these changes there are now five current SROG members.

The SROG system currently consists of the 91st Avenue WWTP, Salt River Outfall (SRO) Interceptor, the Southern Avenue Interceptor (SAI), and the 99th Avenue Interceptor.

Intergovernmental agreements exist between SROG members and non-SROG jurisdictions which allow third parties to discharge to the SROG system. Agreements exist between the following jurisdictions:

- City of Phoenix - City of Mesa - Town of Gilbert
- City of Phoenix - City of Scottsdale - Town of Paradise Valley
- City of Phoenix - City of Tempe - Town of Guadalupe

In addition to the sewer service agreements above, the Cities of Glendale, Peoria, Phoenix, and Tolleson jointly own and operate the 99th Avenue Interceptor, a major trunk sewer in the west Valley serving both the 91st Avenue and Tolleson WWTPs.

Each of these agreements contains requirements for all parties to implement appropriate Industrial Pretreatment Programs within their own jurisdictions. This annual report summarizes the activities of the pretreatment programs for the Cities of Glendale, Mesa, Phoenix, Scottsdale, Tempe, and the Town of Gilbert.

91st Avenue Wastewater Treatment Plant


The original 91st Avenue WWTP, a 5 million gallon per day (mgd) cooperative venture between Glendale and Phoenix, was built in 1958. This plant was later replaced with a 45 mgd plant which was subsequently expanded in 1969, 1976, 1984, 1989, and 2009. Upon completion of the most recent expansion in 2010, the plant has a certified treatment capacity of 230 mgd, and receives an average daily flow of 133.23 million gallons.



SROG City Allocations into 91st Avenue WWTP			
City	Flow (mgd)	COD (lbs/day)	TSS (lbs/day)
Glendale	13.20	114,000	63,000
Mesa	29.22	168,000	90,000
Phoenix	134.80	708,000	356,000
Scottsdale	20.25	123,000	93,000
Tempe	32.53	233,000	96,000
SROG	230.00	1,346,000	698,000


Purchased Capacity

Flow (MGD)




Purchased Capacity vs Monthly Flows

COD Loading (lbs/day)



View Current Loadings

TSS Loading (lbs/day)



Tres Rios Ecosystem Restoration and Flood Control Project

The 91st Avenue WWTP delivers treated wastewater to the Tres Rios Flow Regulating Wetlands. The wetland complex removes additional nutrients and metals from the treated water. Reclaimed water from the plant is also currently delivered, via the Salt and Gila rivers, to the Buckeye Irrigation Company (BIC) for agricultural use, and via pipeline to Arizona Public Service's Palo Verde Nuclear Generating Station which uses this water for cooling purposes. The 91st Avenue WWTP consistently meets all environmental standards.

In 1994, as part of a research project to determine if wetlands could polish effluent from the 91st Avenue WWTP. Phoenix, in cooperation with SROG and the U.S. Bureau of Reclamation, created the Tres Rios Constructed Wetlands Demonstration Project. A secondary goal of the project was to restore the riparian habitat for wildlife along the Salt River. Because of the success achieved with the demonstration wetlands, a full scale, 200+ acre wetland system was designed. Construction was completed with steady wastewater flow introduced in the spring of 2010. The full scale Tres Rios Ecosystem Restoration and Flood Control Project, which was 65% funded by the US Army Corp of Engineers and 35% funded by SROG, improved and enhanced a 7-mile long, 1500-acre section of the Salt and Gila Rivers in southwestern Phoenix. Currently portions of the constructed wetlands are open for passive recreational uses, such as bird watching, hiking, and horseback riding.


For more information regarding Tres Rios please visit <https://www.phoenix.gov/waterservices/tresrios/wetlandsinfo>.

23rd Avenue Wastewater Treatment Plant

The original 10 mgd 23rd Avenue WWTP, built in 1932, was expanded in 1946, 1962, and 1994. The plant was recertified following headworks modification and influent line reconstruction from 1994 to 1996, and currently has a treatment capacity of 63 mgd. 23rd Avenue WWTP currently receives an average daily flow of 33.53 million gallons. Approximately 10 mgd of flow is diverted to the 91st Avenue WWTP. Reclaimed water from the 23rd Avenue WWTP is delivered to the Roosevelt Irrigation District (RID) for non-food crop irrigation.




1947 Construction of Clarifier at 23rd Avenue WWTP



Legend

- Wastewater Treatment Plant
- Sewer Meter Station
- Sewer Meter Station - Future Site
- Sewer Lift Stations
- SROG-99
- SROG-SAI
- SROG-SRO
- Other City Mains

WWTPs and Multi-City Joint Sewage Transmission Lines



Created on Date: 01-08-2021
 Data Source: COP Enterprise GIS
 Created by: JDeary
 File Location: I:\Users\JDeary\SROG Lines\SROG System Map 2021.mxd
 Note: Protected Critical Infrastructure Information and Exempt from Public Disclosure

Summary of Priority Pollutant Results

23rd Avenue Wastewater Treatment Plant
91st Avenue Wastewater Treatment Plant

Part III Section F.4.a. of the 91st Avenue WWTP NPDES Permit and Part V Section A.4.b. of the 23rd Avenue WWTP AZPDES Permit require the following to be included within this annual report:

A summary of analytical results from representative, flow proportioned, 24-hour composite sampling of the POTW's influent and effluent for those pollutants identified under CWA section 307(a) which are known or suspected to be discharged by nondomestic users. This will consist of an annual full priority pollutant scan, with quarterly samples analyzed only for those pollutants detected in the full scan. Influent or effluent monitoring data shall be provided for nonpriority pollutants which the Cities believe may be causing or contributing to Interferences or Pass Through. All sampling and analysis required under this paragraph must be performed using the test methods specified under 40 CFR 136. Sampling and analysis for asbestos is not required. Sludge sampling and analyses are covered elsewhere in this permit.

As required, a summary of analytical results for influent, effluent, and biosolids samples collected from the 23rd and 91st Avenue Wastewater Treatment Plants are presented in the following pages.

23rd Avenue

	Number of Observations	Number of Non-Detects	¹ Average	Maximum	Units
1,1,1-Trichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,1,2,2-Tetrachloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,1,2-Trichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,1-Dichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,1-Dichloroethylene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,2,4-Trichlorobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
1,2-Dichlorobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
1,2-Dichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,2-Dichloropropane					
Influent	4	4	All Non-Detect	-	µg/L

Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,2-Diphenylhydrazine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,2-Trans-dichloroethylene (Trans-1,2-Dichloroethene)					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,3-Dichlorobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
1,3-Dichloropropylene (cis/trans-1,3-Dichloropropene)					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
1,4-Dichlorobenzene					
Influent	12	8	6.15	1.2	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
2,3,7,8-TCDD (Dioxin)					
Influent	1	1	All Non-Detect	-	pg/L
Effluent	3	3	All Non-Detect	-	pg/L
Biosolids	1	1	All Non-Detect	-	ng/kg Dry Wt
2,4,6-Trichlorophenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
2,4-Dichlorophenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
2,4-Dimethylphenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2,4-Dinitrophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2,4-Dinitrotoluene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2,6-Dinitrotoluene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2-Chloroethyl vinyl ethers

Influent	1	1	All Non-Detect	-	µg/L
Effluent	1	1	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2-Chloronaphthalene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2-Chlorophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

2-Nitrophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

3,3-Dichlorobenzidine

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

4,4-DDD

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	4	0.03	0.15	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

4,4-DDE

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
4,4-DDT					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	4	0.04	0.21	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
4,6-Dinitro-o-cresol (2-Methyl-4,6-dinitrophenol)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
4-Bromophenyl phenyl ether					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
4-Chlorophenyl phenyl ether					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
4-Nitrophenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Acenaphthene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Acenaphthylene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Acrolein					
Influent	1	1	All Non-Detect	-	µg/L
Effluent	1	1	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Acrylonitrile					
Influent	1	1	All Non-Detect	-	µg/L
Effluent	1	1	All Non-Detect	-	µg/L

Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Aldrin					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Alpha-BHC					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Alpha-endosulfan (Endosulfan I)					
Influent	12	10	0.015	0.059	ug/L
Effluent	4	3	0.015	0.051	ug/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Anthracene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Antimony					
Influent	12	12	All Non-Detect	-	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	6	All Non-Detect	-	mg/kg Dry Wt
Arsenic					
Influent	12	9	0.0017	0.0033	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	7	0	15.63	61.3	mg/kg Dry Wt
Benzene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Benzidine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Benzo(a) anthracene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Benzo(a)pyrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	4	0.41	0.14	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Benzo(b) fluoranthene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Benzo(ghi) perylene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Benzo(k) fluoranthene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Beryllium

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	6	6	All Non-Detect	-	mg/kg Dry Wt

Beta-BHC

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Beta-endosulfan (Endosulfan II)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Bis(2-chloroethoxy) methane

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Bis(2-chloroethyl) ether

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Bis(2-chloroisopropyl) ether

Influent	12	12	All Non-Detect	-	µg/L
----------	----	----	----------------	---	------

Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Bis(2-ethylhexyl) phthalate					
Influent	12	5	31.88	56.7	µg/L
Effluent	5	2	2	2.80	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Boron (Non Priority Pollutant studied for Local Limits Monitoring)					
Influent	12	0	0.300	0.336	mg/L
Effluent	4	0	0.290	0.302	mg/L
Biosolids	0	0	N/A	-	mg/kg Dry Wt
Bromoform					
Influent	4	3	0.27	0.54	µg/L
Effluent	5	2	0.63	1.9	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Bromomethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Butyl benzyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	1	1.7	2.6	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Cadmium					
Influent	12	12	All Non-Detect	-	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	6	All Non-Detect	-	mg/kg Dry Wt
Carbon tetrachloride					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Chlordane					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Chlorobenzene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Bromodichloromethane

Influent	4	0	0.92	1.3	µg/L
Effluent	5	0	10.52	14	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Chloroethane

Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Chloroform

Influent	4	0	6.5	8.0	µg/L
Effluent	5	0	14.8	17	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Chromium

Influent	12	3	0.0060	0.0108	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	0	65.22	96.2	mg/kg Dry Wt

Chrysene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Copper

Influent	12	0	0.130	0.152	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	7	0	967	1900	mg/kg Dry Wt

Cyanide, Total (Cyanide samples are discrete samples)

Influent	1	1	All Non-Detect	-	mg/L
Effluent	1	1	All Non-Detect	-	mg/L
Biosolids	6	0	11.97	14	mg/kg Dry Wt

Delta-BHC

Influent	12	11	0.016	0.089	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Dibenzo(a,h) anthracene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Dibromochloromethane

Influent	4	0	0.67	0.97	µg/L
Effluent	5	0	4.84	9.5	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Dieldrin					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Diethyl phthalate					
Influent	12	9	31.98	11.6	µg/L
Effluent	4	2	4.12	7.1	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Dimethyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Di-n-butyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Di-n-octyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Endosulfan sulfate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Endrin					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Endrin aldehyde					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Ethylbenzene					
Influent	4	2	0.38	0.59	µg/L
Effluent	5	5	All Non-Detect	-	µg/L

Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Fluoranthene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Fluorene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Fluoride (Non Priority Pollutant studied for Local Limits Monitoring)					
Influent	12	0	0.85	1.10	mg/L
Effluent	1	0	0.60	0.60	mg/L
Biosolids	0	0	All Non-Detect	-	mg/kg Dry Wt
Gamma-BHC					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Heptachlor					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Heptachlor epoxide					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Hexachlorobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Hexachlorobutadiene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
Hexachlorocyclopentadiene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Hexachloroethane

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Indeno (1,2,3-cd) pyrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Isophorone

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Lead

Influent	12	0	0.0049	0.0057	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	5	38.36	63.6	mg/kg Dry Wt

Mercury

Influent	12	4	0.0002	0.00079	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	5	1.07	1.3	mg/kg Dry Wt

Methyl bromide (Bromomethane)

Influent	4	4	All Non-Detect	-	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Methyl chloride (Chloromethane)

Influent	4	4	All Non-Detect	-	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Methylene chloride (Dichloromethane)

Influent	4	0	2.98	7.9	mg/L
Effluent	5	5	All Non-Detect	-	mg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Molybdenum (Non Priority Pollutant studied for Local Limits Monitoring)

Influent	12	0	0.0098	0.0183	mg/L
Effluent	4	0	0.0300	0.0978	mg/L
Biosolids	6	0	22.1	29.9	mg/kg Dry Wt

Naphthalene

Influent	12	12	All Non-Detect	-	µg/L
----------	----	----	----------------	---	------

Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	2	2	All Non-Detect	-	mg/kg Dry Wt
Nickel					
Influent	12	6	0.007	0.012	mg/L
Effluent	4	3	0.005	0.005	mg/L
Biosolids	6	1	32.47	47.7	mg/kg Dry Wt
Nitrobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
N-nitrosodimethylamine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
N-nitrosodi-n-propylamine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
N-nitrosodiphenylamine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Parachlorometa cresol (4-Chloro-3-methylphenol)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
PCB-1016 (Arochlor 1016)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
PCB-1221 (Arochlor 1221)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
PCB-1232 (Arochlor 1232)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

PCB-1242 (Arochlor 1242)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

PCB-1248 (Arochlor 1248)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

PCB-1254 (Arochlor 1254)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

PCB-1260 (Arochlor 1260)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Pentachlorophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Phenanthrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Phenol

Influent	12	7	19.32	38.6	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Pyrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt

Selenium

Influent	12	11	0.00190	0.0011	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	0	5.22	6.9	mg/kg Dry Wt

Silver

Influent	12	11	0.0022	0.0017	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	6	0	All Non-Detect	-	mg/kg Dry Wt
Tetrachloroethylene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Thallium					
Influent	12	12	0.00012	0.00037	mg/L
Effluent	4	4	0.000096	0.00016	mg/L
Biosolids	6	6	All Non-Detect	-	mg/kg Dry Wt
Toluene					
Influent	4	0	2.25	3.3	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Toxaphene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Trichloroethylene (Trichloroethene)					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	5	5	All Non-Detect	-	µg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Vinyl chloride					
Influent	4	4	All Non-Detect	-	mg/L
Effluent	5	5	All Non-Detect	-	mg/L
Biosolids	1	1	All Non-Detect	-	mg/kg Dry Wt
Zinc					
Influent	12	0	0.190	0.202	mg/L
Effluent	4	0	0.050	0.057	mg/L
Biosolids	6	0	1367	1630	mg/kg Dry Wt

¹Average calculations include non-detect values. Non-detect values were multiplied by 0.5. Due to varying laboratory reporting levels, the average can exceed the maximum in some cases. No average was calculated when all results were non-detects.

91st Avenue

	Number of Observations	Number of Non-Detects	¹ Average	Maximum	Units
1,1,1-Trichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,1,2,2-Tetrachloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,1,2-Trichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,1-Dichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,1-Dichloroethylene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,2,4-Trichlorobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	14	14	All Non-Detect	-	µg/L
Biosolids	9	9	All Non-Detect	-	mg/kg Dry Wt
1,2-Dichlorobenzene					
Influent	13	13	All Non-Detect	-	µg/L
Effluent	15	15	All Non-Detect	-	µg/L
Biosolids	9	9	All Non-Detect	-	mg/kg Dry Wt
1,2-Dichloroethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,2-Dichloropropane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L

Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,2-Diphenylhydrazine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
1,2-Trans-dichloroethylene (Trans-1,2-Dichloroethene)					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,3-Dichlorobenzene					
Influent	13	13	All Non-Detect	-	µg/L
Effluent	13	13	All Non-Detect	-	µg/L
Biosolids	9	9	All Non-Detect	-	mg/kg Dry Wt
1,3-Dichloropropylene (trans/cis-1,3-Dichloropropene)					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
1,4-Dichlorobenzene					
Influent	13	13	All Non-Detect		µg/L
Effluent	15	14	0.4	0.11	µg/L
Biosolids	9	9	All Non-Detect	-	mg/kg Dry Wt
2,3,7,8-TCDD (Dioxin)					
Influent	1	1	All Non-Detect	-	pg/L
Effluent	2	2	All Non-Detect	-	pg/L
Biosolids	3	3	All Non-Detect	-	mg/kg Dry Wt
2,4,6-Trichlorophenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
2,4-Dichlorophenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
2,4-Dimethylphenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2,4-Dinitrophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2,4-Dinitrotoluene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2,6-Dinitrotoluene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2-Chloroethyl vinyl ethers

Influent	1	1	All Non-Detect	-	µg/L
Effluent	1	1	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2-Chloronaphthalene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2-Chlorophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

2-Nitrophenol

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

3,3-Dichlorobenzidine

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

4,4-DDD

Influent	12	12	All Non-Detect	-	µg/L
Effluent	14	13	0.02	0.15	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

4,4-DDE

Influent	12	11	0.032	0.049	µg/L
----------	----	----	-------	-------	------

Effluent	14	14	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
4,4-DDT					
Influent	12	11	0.041	0.069	µg/L
Effluent	14	13	0.023	0.21	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
4,6-Dinitro-o-cresol (2-Methyl-4,6-dinitrophenol)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
4-Bromophenyl phenyl ether					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
4-Chlorophenyl phenyl ether					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
4-Nitrophenol					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Acenaphthene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Acenaphthylene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Acrolein					
Influent	1	1	All Non-Detect	-	µg/L
Effluent	1	1	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Acrylonitrile					
Influent	1	1	All Non-Detect	-	µg/L
Effluent	1	1	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Aldrin						
Influent	12	12	All Non-Detect	0.074		µg/L
Effluent	23	15	0.007	0.007		µg/L
Biosolids	4	4	All Non-Detect	-		mg/kg Dry Wt
Alpha-BHC						
Influent	12	12	All Non-Detect	-		µg/L
Effluent	12	12	All Non-Detect	-		µg/L
Biosolids	4	3	0.245	0.1		mg/kg Dry Wt
Alpha-endosulfan (Endosulfan I)						
Influent	12	11	0.044	0.048		ug/L
Effluent	12	10	0.025	0.019		ug/L
Biosolids	4	4	All Non-Detect	-		mg/kg Dry Wt
Anthracene						
Influent	12	12	All Non-Detect	-		µg/L
Effluent	12	12	All Non-Detect	-		µg/L
Biosolids	5	5	All Non-Detect	-		mg/kg Dry Wt
Antimony						
Influent	12	10	0.0011	0.0027		mg/L
Effluent	5	4	0.00090	0.0011		mg/L
Biosolids	4	3	3.72	7.1		mg/kg Dry Wt
Arsenic						
Influent	12	5	0.0021	0.0035		mg/L
Effluent	5	3	0.0016	0.0027		mg/L
Biosolids	12	0	6.67	7.2		mg/kg Dry Wt
Benzene						
Influent	4	4	All Non-Detect	-		µg/L
Effluent	6	6	All Non-Detect	-		µg/L
Biosolids	4	4	All Non-Detect	-		mg/kg Dry Wt
Benzidine						
Influent	12	12	All Non-Detect	-		µg/L
Effluent	12	12	All Non-Detect	-		µg/L
Biosolids	4	4	All Non-Detect	-		mg/kg Dry Wt
Benzo(a) anthracene						
Influent	12	12	All Non-Detect	-		µg/L
Effluent	12	12	All Non-Detect	-		µg/L
Biosolids	5	5	All Non-Detect	-		mg/kg Dry Wt
Benzo(a)pyrene						

Influent	12	12	All Non-Detect	-	µg/L
Effluent	14	12	1.076	0.14	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Benzo(b) fluoranthene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Benzo(ghi) perylene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Benzo(k) fluoranthene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Beryllium					
Influent	12	12	All Non-Detect	-	mg/L
Effluent	5	5	All Non-Detect	-	mg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Beta-BHC					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Beta-endosulfan (Endosulfan II)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Bis(2-chloroethoxy) methane					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Bis(2-chloroethyl) ether					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Bis(2-chloroisopropyl) ether					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L

Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Bis(2-ethylhexyl) phthalate					
Influent	12	5	32.1	56.9	µg/L
Effluent	14	5	2.18	6.00	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Boron (Non Priority Pollutant studied for Local Limits Monitoring)					
Influent	12	0	0.34	0.40	mg/L
Effluent	12	0	0.34	0.38	mg/L
Biosolids	0	0	All Non-Detect	-	mg/kg Dry Wt
Bromodichloromethane					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	0	0.507	0.67	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Bromoform					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Butyl benzyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	3	1.814	2.6	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Cadmium					
Influent	12	12	All Non-Detect	-	mg/L
Effluent	24	24	All Non-Detect	-	mg/L
Biosolids	12	12	All Non-Detect	-	mg/kg Dry Wt
Carbon tetrachloride					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Chlordane					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Chlorobenzene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Chloroethane

Influent	4	4	All Non-Detect	-	µg/L
Effluent	4	4	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Chloroform

Influent	4	0	5.10	5.30	µg/L
Effluent	6	0	1.92	2.40	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Chromium

Influent	12	0	0.0082	0.025	mg/L
Effluent	4	3	0.0017	0.0039	mg/L
Biosolids	12	0	48.44	51.7	mg/kg Dry Wt

Chrysene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Copper

Influent	12	0	0.12	0.196	mg/L
Effluent	4	3	0.001	0.005	mg/L
Biosolids	12	0	6.28	711	mg/kg Dry Wt

Cyanide, Total (Cyanide samples are discrete samples.)

Influent	11	11	All Non-Detect	-	mg/L
Effluent	24	23	0.0026	0.005	mg/L
Biosolids	4	0	18.25	23	mg/kg Dry Wt

Delta-BHC

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	10	0.017	0.058	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Dibenzo(a,h) anthracene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Dibromochloromethane

Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Dieldrin

Influent	12	12	All Non-Detect	-	µg/L
----------	----	----	----------------	---	------

Effluent	23	22	0.0035	0.0057	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Diethyl phthalate					
Influent	12	8	31.89	14.1	µg/L
Effluent	12	5	3.81	6.9	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Dimethyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Di-n-butyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	11	0.33	0.4	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Di-n-octyl phthalate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Endosulfan sulfate					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Endrin					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	25	25	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Endrin aldehyde					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Ethylbenzene					
Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Fluoranthene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L

Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Fluorene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Fluoride (Non Priority Pollutant studied for Local Limits Monitoring)					
Influent	12	0	1.4	1.7	mg/L
Effluent	2	0	1.4	1.4	mg/L
Biosolids	0	0	All Non-Detect	-	mg/kg Dry Wt
Gamma-BHC					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	25	25	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Heptachlor					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	25	25	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Heptachlor epoxide					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	25	21	0.009	0.0084	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
Hexachlorobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	14	14	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Hexachlorobutadiene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	14	14	All Non-Detect	-	µg/L
Biosolids	9	9	All Non-Detect	-	mg/kg Dry Wt
Hexachlorocyclopentadiene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	13	13	All Non-Detect	-	µg/L
Biosolids	55	4	All Non-Detect	-	mg/kg Dry Wt
Hexachloroethane					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Indeno (1,2,3-cd) pyrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Isophorone

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Lead

Influent	12	12	0.0024	0.0043	mg/L
Effluent	24	0	0.0008	0.0018	mg/L
Biosolids	12	0	All Non-Detect	-	mg/kg Dry Wt

Mercury

Influent	12	12	All Non-Detect	-	mg/L
Effluent	26	0	1.37	3.20	ng/L
Biosolids	12	2	2.3	18*	mg/kg Dry Wt

Methyl bromide (Bromomethane)

Influent	4	4	All Non-Detect	-	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Methyl chloride (Chloromethane)

Influent	4	4	All Non-Detect	-	mg/L
Effluent	4	4	All Non-Detect	-	mg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Methylene chloride (Dichloromethane)

Influent	4	0	6.15	7.50	mg/L
Effluent	6	6	All Non-Detect	-	mg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Molybdenum (Non Priority Pollutant studied for Local Limits Monitoring)

Influent	12	0	0.0070	0.0105	mg/L
Effluent	5	5	0.0028	0.0034	mg/L
Biosolids	12	11	11.74	23.70	mg/kg Dry Wt

Naphthalene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	14	14	All Non-Detect	-	µg/L
Biosolids	9	8	225.32	4.1	mg/kg Dry Wt

Nickel

Influent	12	9	0.029	0.015	mg/L
----------	----	---	-------	-------	------

Effluent	5	2	0.0027	0.003	mg/L
Biosolids	12	12	All Non-Detect	-	mg/kg Dry Wt
Nitrobenzene					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
N-nitrosodimethylamine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
N-nitrosodi-n-propylamine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
N-nitrosodiphenylamine					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
Parachlorometa cresol (4-Chloro-3-methylphenol)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt
PCB-1016 (Arochlor 1016)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
PCB-1221 (Arochlor 1221)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
PCB-1232 (Arochlor 1232)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt
PCB-1242 (Arochlor 1242)					
Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

PCB-1248 (Arochlor 1248)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

PCB-1254 (Arochlor 1254)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

PCB-1260 (Arochlor 1260)

Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Pentachlorophenol

Influent	12	11	All Non-Detect	-	µg/L
Effluent	14	14	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Phenanthrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Phenol

Influent	12	3	36.95	49	µg/L
Effluent	12	9	1.1	3.2	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Pyrene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	12	12	All Non-Detect	-	µg/L
Biosolids	5	5	All Non-Detect	-	mg/kg Dry Wt

Selenium

Influent	12	11	0.0019	0.0012	mg/L
Effluent	24	24	All Non-Detect	-	mg/L
Biosolids	12	11	6.5	7.6	mg/kg Dry Wt

Silver

Influent	12	12	All Non-Detect	-	mg/L
Effluent	5	5	All Non-Detect	-	mg/L
Biosolids	12	12	All Non-Detect	-	mg/kg Dry Wt

Tetrachloroethylene

Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Thallium

Influent	12	12	All Non-Detect	-	mg/L
Effluent	5	5	All Non-Detect	-	mg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Toluene

Influent	4	2	3.26	8.50	µg/L
Effluent	6	4	0.1	0.13	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Toxaphene

Influent	12	12	All Non-Detect	-	µg/L
Effluent	23	23	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Trichloroethylene (Trichloroethene)

Influent	4	4	All Non-Detect	-	µg/L
Effluent	6	6	All Non-Detect	-	µg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Vinyl chloride

Influent	4	4	All Non-Detect	-	mg/L
Effluent	6	6	All Non-Detect	-	mg/L
Biosolids	4	4	All Non-Detect	-	mg/kg Dry Wt

Zinc

Influent	12	0	0.176	0.251	mg/L
Effluent	5	0	0.017	0.023	mg/L
Biosolids	12	0	846.0	924	mg/kg Dry Wt

¹Average calculations include non-detect values. Non-detect values were multiplied by 0.5. Due to

*Laboratory error suspected; re-analysis did not confirm result. Since the original analysis met method requirements it could not be discarded.

Upset, Interference, and Pass Through

23rd Avenue Wastewater Treatment Plant
91st Avenue Wastewater Treatment Plant

The following is a discussion of Upset, Interference, or Pass-Through incidents, if any, which the Cities know or suspect, were caused by nondomestic users of the POTW system during the year ending December 31, 2020. If any incidents occurred, the reasons why, the corrective actions taken, and the nondomestic user(s) or industry sector(s) responsible are provided.

Additionally, a review of the applicable pollutant limits to determine whether any additional limitations, or changes to existing requirements may be necessary to prevent Interference, Pass Through or noncompliance with sludge disposal requirements is provided.

This information is required under Part III Section D.4.b. of the NPDES Permit and Part V Section B.4.b. of the AZPDES Permit.

Analytical results of effluent samples obtained during 2020 at the 23rd Avenue and 91st Avenue Wastewater Treatment Plants (WWTP) were compared against the federal definitions of Upset, Interference, and Pass Through.

The definition for **Upset** is found at 40 CFR 122.41(n):

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

The definition for **Interference** is found at 40 CFR 403.3(i):

The term "interference" means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- 1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and*
- 2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to Subtitle D or the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.*

The definition for **Pass-Through** is found at 40 CFR 403.3(n):

The term "Pass-Through" means a Discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

23rd Avenue WWTP

Based upon these definitions, there were no violations due to incidents of upset, interference, or pass-through that were attributable to nondomestic users of the POTW at the 23rd Avenue WWTP during 2020.

91st Avenue WWTP

Based upon these definitions, there were no violations due to incidents of upset, interference, or pass-through that were potentially attributable to nondomestic users of the POTW at the 91st Avenue Wastewater Treatment Plant (WWTP) during 2020.

Three permit exceedances occurred that were not attributable to nondomestic users but are provided here for informational purposes. In January, an exceedance of the daily maximum ammonia limit occurred, and in August, a daily maximum and monthly average ammonia limit exceedance occurred. Both events were caused by mechanical and operational problems within the plant.

Review of Local Limits

In 2002, the City retained a consultant to evaluate local limits. The consultant identified the pollutants of concern and the SROG cities participated in a local limits data collection sampling event in December 2002. The data was evaluated and revised local limits were established. BMP development and implementation was recommended for five pollutants: beryllium, fluoride, molybdenum, selenium, and di(2-ethylhexyl) phthalate (DEHP). Each of the SROG Cities had their revised local limits approved, incorporated into the City ordinance, and accepted by City Council. The local limits changes and revised City ordinances were approved by ADEQ on December 10, 2004. The revised limits and city ordinance changes were effective January 1, 2005. Public meetings with target industries were held in March 2005 to communicate to industries and to obtain commitment from them to implement the BMPs in accordance with the May 2004 SROG Phase II Local Limits Final Report and the June 2005 SROG BMPs Technical Memorandum prepared for the SROG cities by Malcolm Pirnie an engineering and consulting firm.

Permits Renewed and Amended

Since 2002 when local limits were last developed, the following permits were renewed or amended:

- NPDES permit for 91st Avenue WWTP which became effective December 1, 2016 and was modified on February 26, 2020.
- AZPDES permit for 23rd Avenue WWTP which became effective August 5, 2019.
- Aquifer Protection Permit (APP) for the 91st Avenue WWTP became effective on October 4, 2002 and was last amended on November 18, 2019.
- APP for the 23rd Avenue WWTP became effective on April 29, 1999 and was last amended on July 16, 2020.

SECTION 1.2 SIGNIFICANT NON-COMPLIANCE (SNC)


Publication of Significant Industrial Users in Significant Noncompliance (SNC)

In accordance with the Federal Clean Water Act and the public participation requirements of 40 CFR 25 pertaining to the enforcement of National Pretreatment Standards as defined by 40 CFR 403.8(f)2(viii), the Cities of Glendale, Mesa, Phoenix, Scottsdale, Tempe and the Town of Gilbert, Arizona annually publish in the newspaper a list of Industrial Users in Significant Noncompliance with pretreatment requirements.


A list of Industrial Users in SNC for the year ending December 31, 2020 is scheduled to appear in the Arizona Republic during the 1st or 2nd Quarter of 2021 and appears following these SNC History pages. Additionally, the April 11, 2020 Arizona Republic publication of Industrial Users in SNC for the year ending December 31, 2019 follows the 2020 SNC list. The table below and graphs on the next page illustrate a ten-year history of the number of Industrial Users in SNC for each year and for each SROG municipality.

Total IU's Published by Municipality SNC Years 2011 - 2020											
SNC Year	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	10-Year Totals
Glendale	0	1	0	1	1	0	0	0	0	0	4
Mesa	0	0	0	0	0	0	0	0	0	0	0
Phoenix	0	2	2	2	4	1	3	7	8	5	37
Scottsdale	0	0	0	0	0	0	0	0	0	0	0
Tempe	1	1	0	1	1	0	0	1	0	0	6
Gilbert	0	0	0	0	0	0	1	0	0	0	1
SROG System TOTALS	1	4	2	4	6	1	4	8	8	5	48

SROG System SNCs Per Year



**Total IUs Published by Municipality
SNC Years 2011 - 2020**



**Industrial Users In Significant Noncompliance with
Applicable Pretreatment Requirements in 2020**

The Cities of Glendale, Mesa, Phoenix, Scottsdale, and Tempe, and the Town of Gilbert, Arizona are responsible for implementing and operating industrial wastewater control (pretreatment) programs in each of their communities. Each program is designed to protect the wastewater treatment plants (POTW), the safety of personnel operating the wastewater collection system, and the environment from adverse impacts that could occur when toxic wastes are discharged into a wastewater collection system. Each municipality issues wastewater discharge permits to Significant* Industrial Users (Users) in their communities and the Users are responsible for ensuring that they comply with respective local ordinances and federal regulations.

In accordance with the Federal Clean Water Act and the public participation requirements of 40 CFR Part 25 in the enforcement of the National Pretreatment Standards as defined by 40 CFR 403.8(f)(2)(viii), the Cities of Glendale, Mesa, Phoenix, Scottsdale, and Tempe, and the Town of Gilbert, Arizona are hereby publishing the following list of Users in Significant Noncompliance(SNC) with applicable pretreatment requirements. **This notice covers the period from January 1, 2020 through December 31, 2020.**

A Significant Industrial User, and in specific cases an Industrial User*, is in a state of SNC when violations meet one or more of the following:

- A. Chronic violations (CSNC) of wastewater discharge limits defined here as those in which sixty-six percent or more of all of the measurements taken during a six-month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant parameter.
- B. Technical Review Criteria violations (TRCSNC), defined here as those in which thirty-three percent or more of all of the measurements taken during a six-month period equal or exceed the product of the daily maximum limit or the average limit multiplied by the applicable TRC (TRC= 1.4 for BOD, TSS, fats, oil and grease; and 1.2 for all other pollutants except pH).
- C. Any other violation of a pretreatment effluent limit (daily maximum or long term average) that the POTW determines has caused alone or in combination with other discharges interference or pass through (including endangering the health of POTW personnel or the general public);
- D. Any discharge of a pollutant that has caused imminent endangerment of human health, welfare or to the environment or has resulted in the POTW's exercise of its emergency authority to halt or prevent such as discharge;
- E. Failure to meet, within 90 days after the schedule date, a compliance schedule milestone contained in a permit or enforcement order for starting construction, completing construction, or attaining final compliance;
- F. Failure to provide within 30 (45*) days after the due date the required report such as a Baseline Monitoring Report, a 90 day compliance report, periodic self-monitoring reports, and reports on compliance with compliance schedules;
- G. Failure to accurately report noncompliance; or
- H. Any other violation or group of violations, which the POTW determines will adversely affect the operation or implementation of the local pretreatment program.

Public participation and cooperation are important to a successful industrial pretreatment program. If you have comments or witness a situation that you believe may involve an illegal discharge of pollutants or hazardous material into a municipality's sewer system, please immediately notify the appropriate municipality: Gilbert (480) 503-6411, Glendale (623) 930-4758, Mesa (480) 644-2131, Phoenix (602) 495-5926, Scottsdale (480) 391-5687, or Tempe (480) 350-2678.

Industrial User	Nature of Violation/ Type of Pollutant	Date Of Last Non-Compliance	Has User Returned to Compliant Status as of 12/31/2020?	Number of Times Published	Nature of Enforcement Action(s)	Comments
Glendale No Users in SNC						83
Mesa No Users in SNC						
Phoenix						
ChemResearch Co., Inc. 1101 West Hilton Avenue Phoenix, Arizona 85007-4305	Late Reporting – 24- Hour Notification Report submitted 35 days late during 1 st Quarter	01/23/2020	Yes	2	Notice of Violation SNC Notification Show Cause Meeting Monetary Penalty	A Show Cause Proceeding imposing monetary penalties took place during the 3 rd Quarter of 2020. Violations in addition to late reporting include a cadmium effluent violation.
Quantum Global Technology, LLC. dba Quantum Clean 3925 East Watkins Street Phoenix, Arizona 85034-7208	Total Toxic Organics (TTO) Daily Maximum Technical Review Criteria – 1 st Quarter	08/26/2020	Yes	2	Notices of Violation TISM SNC Notification Show Cause Meeting Monetary Penalty	A Show Cause Proceeding imposing monetary penalties took place during the 1 st Quarter of 2021. There was an additional TTO violation in the 3 rd Quarter that did not result in SNC.
4RB Disposal, LLC. 2245 West Shangri La Road Phoenix, Arizona 85029-4813	Copper (Daily Maximum TRC & Chronic); Zinc (Daily Max TRC & Chronic); Cadmium (Daily Max TRC) – 2 nd Quarter	07/23/2020	Yes	1	Notices of Violation TISM SNC Notification Show Cause Proceeding Monetary Penalty	A Show Cause Proceeding imposing monetary penalties took place during the 4 th Quarter of 2020. Violations in addition to copper, zinc and cadmium effluent include failure to sample and late reporting.
Cleanpart Southwest, LLC. 3844 East University Drive Phoenix, Arizona 85034-7221	Total Toxic Organics Daily Maximum Chronic – 3 rd Quarter	10/22/2020	Yes	1	Notice of Violation TISM SNC Notification Show Cause Proceeding (Pending) Monetary Penalty (Pending)	A Show Cause Proceeding imposing monetary penalties will take place during the 1 st or 2 nd Quarter of 2021. There were two additional TTO violations in the 4 th Quarter that did not result in SNC.

Abrazo Central Campus 2000 West Bethany Home Rd Phoenix, Arizona 85015-2443	Late Reporting – 24- Hour Notification Report submitted 49 days late during 4 th Quarter	12/18/2020	Yes	2	Notice of Violation SNC Notification Show Cause Meeting Monetary Penalty	A Show Cause Proceeding imposing monetary penalties will take place during the 2 nd Quarter of 2021. There was an additional late reporting violation that did not result in SNC.
Industrial User	Nature of Violation/ Type of Pollutant	Date Of Last Non- Compliance	Has User Returned to Compliant Status as of 12/31/2020?	Number of Times Published	Nature of Enforcement Action(s)	Comments
Scottsdale						
No Users in SNC						
Tempe						
No Users in SNC						
Town of Gilbert						
No Users in SNC						

*Phoenix City Code Chapter 28 was amended on October 7, 2020 to incorporate the October 14, 2005 updates to 40 CFR Part 403, resulting in a change to the definition of SNC, including applicability and reporting criteria.

THE ARIZONA REPUBLIC

PO Box 194, Phoenix, Arizona 85001-0194
Phone 1-602-444-7315 Fax 1-877-943-0443

STATE OF WISCONSIN

} SS.

AFFIDAVIT OF PUBLICATION

COUNTY OF BROWN

CITY OF PHOENIX
200 W WASHINGTON
PHOENIX, AZ 85003

I, being first duly sworn, upon oath deposes and says: That I am the legal clerk of the Arizona Republic, a newspaper of general circulation in the counties of Maricopa, Coconino, Pima and Pinal, in the State of Arizona, published weekly at Phoenix, Arizona, and that the copy hereto attached is a true copy of the advertisement published in the said paper on the dates indicated.

Publication: Arizona Republic

Ad number: GCI0379444

PO Field: Log#11981


Published Date(s):

03/20/2020



Sworn to before me this

20th day of
March, 2020



Notary Public

My Commission Expires on

9/19/21



CITY OF PHOENIX- LEG
200 W WASHINGTON ST
PHOENIX AZ 85003--161

Account 291908 **AD#** 0004078813 **Net Amount** \$0.00 **Tax Amount** \$0.00 **Total Amount** \$0.00 **Payment Method** Invoice **Payment Amount** \$0.00 **Amount Due** \$0.00

Sales Rep: ECSUSER **Order Taker:** ECSUSER **Order Created:** 02/25/2020

Product	# Ins	Column	Lines	Start Date	End Date
PNI-Arizona Republic	1	6.00	1	03/20/2020	03/20/2020

* ALL TRANSACTIONS CONSIDERED PAID IN FULL UPON CLEARANCE OF FINANCIAL INSTITUTION

Text of Ad: 02/25/2020

Industrial User	Nature of Violation/ Type of Pollutant	Date Of Last Non-Compliance	Has User Returned to Compliant Status as of 12/31/2019?	Number of Times Published	Nature of Enforcement Action(s)
<p>Industrial Users In Significant Noncompliance with Applicable Pretreatment Requirements in 2019</p> <p>The Cities of Glendale, Mesa, Phoenix, Scottsdale, and Tempe, and the Town of Gilbert, Arizona are responsible for implementing and operating industrial wastewater control (pretreatment) programs in each of their communities. Each program is designed to protect the wastewater treatment plants (POTW), the safety of personnel operating the wastewater collection system, and the environment from adverse impacts that could occur when toxic wastes are discharged into a wastewater collection system. Each municipality issues wastewater discharge permits to Industrial Users (Users) in their communities and the Users are responsible for ensuring that they comply with respective local ordinances and federal regulations.</p> <p>In accordance with the Federal Clean Water Act and the public participation requirements of 40 CFR Part 25 in the enforcement of the National Pretreatment Standards as defined by 40 CFR 403.8(f)(2)(viii), the Cities of Glendale, Mesa, Phoenix, Scottsdale, and Tempe, and the Town of Gilbert, Arizona are hereby publishing the following list of Users in Significant Noncompliance(SNC) with applicable pretreatment requirements. This notice covers the period from January 1, 2019 through December 31, 2019.</p> <p>An Industrial User is in a state of SNC when violations meet one or more of the following:</p> <p>A. Chronic violations (CSNC) of wastewater discharge limits defined here as those in which sixty-six percent or more of all of the measurements taken during a six-month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant parameter.</p> <p>B. Technical Review Criteria violations (TRCSNC), defined here as those in which thirty-three percent or more of all of the measurements taken during a six-month period equal or exceed the product of the daily maximum limit or the average limit multiplied by the applicable TRC (TRC = 1.4 for BOD, TSS, fats, oil and grease; and 1.2 for all other pollutants except pH).</p> <p>C. Any other violation of a pretreatment effluent limit (daily maximum or long term average) that the POTW determines has caused alone or in combination with other discharges interference or pass through (including endangering the health of POTW personnel or the general public);</p> <p>D. Any discharge of a pollutant that has caused imminent endangerment of human health, welfare or to the environment or has resulted in the POTW's exercise of its emergency authority to halt or prevent such discharge;</p> <p>E. Failure to meet, within 90 days after the schedule date, a compliance schedule milestone contained in a permit or enforcement order for starting construction, completing construction, or attaining final compliance;</p> <p>F. Failure to provide within 30 days after the due date the required report such as a Baseline Monitoring Report, a 90 day compliance report, periodic self-monitoring reports, and reports on compliance with compliance schedules;</p> <p>G. Failure to accurately report noncompliance; or</p> <p>H. Any other violation or group of violations, which the POTW determines will adversely affect the operation or implementation of the local pretreatment program.</p> <p>Public participation and cooperation are important to a successful industrial pretreatment program. If you have comments or witness a situation that you believe may involve an illegal discharge of pollutants or hazardous material into a municipality's sewer system, please immediately notify the appropriate municipality: Gilbert (480) 503-0411, Glendale (523) 930-4758, Mesa (480) 644-2131, Phoenix (602) 496-6926, Scottsdale (480) 391-5667, or Tempe (480) 350-2678.</p>					
Glendale No Users in SNC					
Mesa No Users in SNC					
Phoenix Marlyn Nutraceuticals, Inc. - Naturally Vitamins 4404 East Elwood Street Phoenix, Arizona 85040-1909	Late Reporting - 24-Hour Notification Report submitted greater than 30-days late during 1st Quarter	01/25/2019	Yes	1	Notices of Violation TISM SNC Notification Show Cause Meeti Monetary Penalty
Prudential Overall Supply 3102 West Roosevelt Street Phoenix, Arizona 85043-2716	Late Reporting - SMR Lab Results submitted greater than 30-days late during the 1st and 4th Quarters	02/08/2020	No	3	Notices of Violation TISM SNC Notification Show Cause Meeti Monetary Penalty
Upper Crust Bakery 3555 West Washington Street Phoenix, Arizona 85009-4759	Late Reporting - 24-Hour Notification Report submitted greater than 30-days late during 1st Quarter	08/23/2019	No	2	Notices of Violation SNC Notification Show Cause Meeti Monetary Penalty
Baker Commodities, Inc. 3602 West Elwood Street Phoenix, Arizona 85009-6737	Late Reporting - 24-Hour Notification Report submitted greater than 30-days late during 1st Quarter	03/22/2019	Yes	1	Notices of Violation TISM SNC Notification Show Cause Meeti Monetary Penalty
Heligear Acquisition Co. dba Northstar Aerospace - Phoenix 481 South 36th Street Phoenix, Arizona 85034-2812	Nickel Monthly Average Technical Review Criteria - 1st Quarter	08/31/2019	Yes	1	Notices of Violation TISMS SNC Notification Show Cause Meeti Monetary Penalty
Signetix, Inc. 2611 South 7th Street, Suite 101 Phoenix, Arizona 85034-6503	Late Reporting - SMR Lab Results submitted greater than 30-days late during 2nd Quarter	08/29/2019	Yes	1	Notice of Violation SNC Notification Show Cause Meeti Monetary Penalty
Phoenix Indian Medical Center 4212 North 16th Street Phoenix, Arizona 85016-5319	Mercury Daily Maximum Technical Review Criteria - 3rd Quarter	10/02/2019	Yes	1	Notices of Violation TISMS S HC Notification Show Cause Meeti
Elite Waste Services, Inc. 2412 West Sherman Avenue Phoenix, Arizona 85009-5817	Late Reporting - 24-Hour Notification Report submitted greater than 30-days late during 3rd Quarter	09/28/2019	Yes	1	Notices of Violation TISMS SNC Notification Show Cause Meeti Monetary Penalty
Scottsdale No Users in SNC					
Tempe No Users in SNC					
Town of Gilbert No Users in SNC					

For the Year Ending December 31, 2019

SECTION 1.3

DEFINITIONS, LIMITS, AND FORMS

DEFINITIONS

The following is a list of the more commonly used words and phrases used throughout this report.

AZPDES Permit - An Arizona Pollutant Discharge Elimination System Permit, issued to the City by the ADEQ, which imposes federal and local standards governing the quality of the treated effluent discharged from the POTW.

Baseline Monitoring Report (BMR) - The initial monitoring report submitted by categorical industrial users in accordance with 40 CFR 403.12.

Bypass - The intentional diversion of wastes from any portion of a treatment facility.

Categorical Standards - (National/Federal Categorical Pretreatment Standards) - Those standards promulgated by the U.S. Environmental Protection Agency (EPA) under the authority of Section 307 (b) and (c) of the Clean Water Act (33 U.S.C. 1317) which apply to a specific category of Industrial User and which are published in 40 CFR Chapter I, Subchapter N (Parts 401-471).

Compliance Status - Is a standard established by the EPA on which to measure whether an industrial discharger is complying with the law. This standard is broken down into three parts: (1) Compliance, (2) Inconsistent compliance, and (3) Significant noncompliance. Compliance is when an industrial discharger has committed no pretreatment violations during the reporting year. Significant noncompliance is defined in the definition section. Inconsistent compliance is where there is at least one pretreatment violation, or more, but not enough to reach significant noncompliance.

Composite sample - A combination of individual samples obtained at regular intervals over a specified time period. The volume of each individual sample shall be either proportional to the flow rate during the sample period (flow composite) or constant and collected at equal time intervals during the composite period (time composite) as defined in the permit.

Industrial User

- A. A source of industrial discharge; or
- B. Any nonresidential user of the sewer system which discharges more than the equivalent strength of 25,000 gallons per day of domestic wastes;
- C. Any significant industrial user;
- D. Has control over the disposal of a waste as described in A, B, or C above; or
- E. Has the right of possession and control over any property which produces a waste as described in A, B, C, or D above.

Interference - A discharge which, alone or in conjunction with a discharge or discharges from

other sources, both:

- A. Inhibits or disrupts the POTW, its treatment processes or operation, or its sludge processes use or disposal
- B. Therefore is a cause of a violation of any requirement of any environmentally related permit issued by a governmental entity (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent state or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including Title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA)); and including state regulations contained in any state sludge management plan prepared pursuant to Subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

Liquid Waste Hauler (or Waste Hauler) - Any person carrying on or engaging in vehicular transport of wastewater or wastes as part of, or incidental to, any business for the purpose of discharging such waste into the City's treatment works.

NPDES Permit - A National Pollutant Discharge Elimination System Permit, issued to the City by the EPA, which imposes federal standards governing the quality of the treated effluent discharged from the POTW.

Pass Through - A discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW NPDES Permit (including an increase in the magnitude or duration of a violation) or which causes or contributes to a violation of an applicable numeric or narrative water quality standard.

Pretreatment - The physical, chemical, biological or other treatment of any industrial discharge prior to discharge to the POTW, for the purpose of:

- A. Reducing the amount or concentration of any pollutant; or
- B. Eliminating the discharge or any pollutant; or
- C. Altering the nature of any pollutant characteristic to a less harmful state.

POTW - Publicly Owned Treatment Works and connecting sewer collection system which are owned and/or operated, in whole or in part, by the City and which provide the City with wastewater collection and disposal services.

Sanitary Sewer - A sewer which carries sewage and to which storm, surface, and ground waters are not intentionally admitted.

Significant Industrial User - This term includes:

- A. All process wastewater discharges subject to categorical pretreatment standards under 40 CFR 403.6 and 40 CFR Chapter I, Subchapter N.
- B. All noncategorical dischargers that, in the opinion of the Director, have a reasonable potential to adversely affect the operation, or that contribute a process wastestream which makes up five percent or more of the average dry weather capacity of any of the POTW treatment plants or that discharges an average of 25,000 gallons per day or more of process wastewater to the POTW, or has a reasonable potential for adversely affecting the POTW operation or for violating any pretreatment standard or requirement.

Significant Noncompliance - An Industrial user is in a state of significant noncompliance (SNC) when violations meet one or more of the following criteria:

- A. Chronic violations of wastewater discharge limits, defined here as those in which 66 percent or more of all of the measurements taken during a six-month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant parameter;
- B. Technical Review Criteria (TRC) violations, defined here as those in which 33 percent or more of all of the measurements for each pollutant parameter taken during a six-month period equal or exceed the product of the daily maximum limit or the average limit multiplied by the applicable TRC (TRC=1.4 for BOD, TSS, fats, oil and grease, and 1.2 for all other pollutants except pH);
- C. Any other violation of a pretreatment effluent limit (daily maximum or long-term average) that the POTW determines has caused, alone or in combination with other dischargers, interference or pass through (including endangering the health of POTW personnel or the general public);
- D. Any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the POTW's exercise of its emergency authority under this Chapter to halt or prevent such a discharge;
- E. Failure to meet, within 90 days after the schedule date, a compliance schedule milestone contained in a permit or enforcement order for starting construction, completing construction, or attaining final compliance;
- F. Failure to provide within 30 days after the due date, required reports such as baseline monitoring reports, 90-day compliance reports, periodic self monitoring reports, and reports on compliance with compliance schedules;
- G. Failure to accurately report noncompliance; or
- H. Any other violation or group of violations, which the POTW determines, will adversely affect the operation or implementation of the local pretreatment program.

Upset - An exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee, excluding such factors as operational error, improperly designed or inadequate treatment facilities, or improper operation and maintenance or lack thereof.

PHRASES

Parameter Violation - A pre-established limit for a particular pollutant has been exceeded, resulting in an unlawful wastewater discharge to the sanitary sewer. For example, if Company XYZ is only regulated under the Phoenix City Code, and discharges silver, the permissible limit would be 1.2 mg/l (parts per million). If a discharge exceeds this limit, then that would be a parameter violation.

Reporting Violation - Failure of the industrial discharger to submit reports required under the law.

Limits Appendices Glendale, Mesa, Phoenix, Scottsdale, and Gilbert

The Limits Appendices on the following pages are used in the Significant Industrial User Compliance Status Reports of this annual report, and apply to the discharges from all permitted industrial users throughout the Cities of Glendale, Mesa, Phoenix, Scottsdale, and Town of Gilbert service area. The more stringent of the applicable Federal Categorical Standards and the Local Limits contained in Appendix A are applied on a parameter-by-parameter basis to the industrial users' discharges.

All limitations for each limit appendix are in concentration units of milligrams per liter (mg/L), unless noted otherwise.

APPENDIX DESCRIPTION

A	Local Limits
B	423.16 Steam Electric Power Generating PSES
C	420.106 Iron and Steel Manufacturing – <i>Allied Tube and Conduit Corporation</i>
D	433.15 Metal Finishing PSES
E	433.17 Metal Finishing PSNS
F	469.18 Electrical and Electronic Components Subpart A PSNS
G	467.35 Aluminum Forming Subpart C PSES Conc. Equivalent - <i>Hydro Remelt</i>
H	467.35 Aluminum Forming Subpart C PSES Conc. Equivalent - <i>Hydro Plant 1</i>
I	467.35 Aluminum Forming Subpart C PSES Conc. Equivalent - <i>Hydro Plant 2</i>
J	465.45 Coil Coating Subpart D PSES Conc. Equivalent - <i>Rexam Beverage Can Company</i>
K	439.46 Pharmaceutical Manufacturing Subpart D PSES
L	439.47 Pharmaceutical Manufacturing Subpart D PSNS
M	437.16 Centralized Waste Treatment Subpart A PSNS
N	437.26 Centralized Waste Treatment Subpart B PSNS
O	437.36 Centralized Waste Treatment Subpart C PSNS
P	437.46(b) Centralized Waste Treatment Subpart D PSES Multiple Wastestreams
Q	437.47(b) Centralized Waste Treatment Subpart D PSNS Multiple Wastestreams
R	421.306 Nonferrous Metals Mfr. Subpart AB PSNS Conc. Equivalent - <i>Mega Metals</i>
S	469.18 Electrical and Electronic Components Subpart A PSNS CWF 98.70% - <i>Entrepix</i>
T	469.28 Electrical and Electronic Components Subpart B PSNS CWF 23.14% - <i>SUMCO</i>
U	464.36 Metal Molding and Casting Subpart C PSNS Conc. Equivalent - <i>Arizona Cast Turbine</i>
V	433.17 Metal Finishing PSNS CWF 96.03% - <i>MPP Group of Companies</i>
W	433.17 Metal Finishing PSNS CWF 90.91% - <i>Honeywell Sky Harbor Circle</i>
X	439.47 Pharmaceutical Manufacturing Subpart D PSNS CWF 3.60% - <i>Celgene Corporation</i>
Y	439.46 Pharmaceutical Manufacturing Subpart D PSES CWF 70.50% - <i>The Procter & Gamble Manufacturing Company</i>
Z	Reserved

APPENDIX A - Local Limits

Metals	Daily Maximum (mg/L)	Prohibited Substances (µg/L)	
Arsenic	0.13	4,4' - DDE	
Cadmium	0.047	4,4' - DDT	
Copper	1.5	Aldrin	
Lead	0.41	BHC-Alpha	
Mercury	0.0023	BHC-Beta	
Selenium	0.10	BHC-Gamma (Lindane)	
Silver	1.2	Heptachlor	
Zinc	3.5	Heptachlor Epoxide	
Anions	Daily Maximum (mg/L)	Polychlorinated Biphenyl Compounds (PCBs)	
Cyanide (T)	2.0	Pretreatment Sludges	
Other	Range	Organics	Daily Maximum (µg/L)
pH	5.0 – 10.5 SU	Benzene	35
Other	Daily Maximum	Chloroform	2000
Temperature (Max)	150°F/66°C		
Flash Point	140°F/60°C		

**APPENDIX B – Steam Electric Power Generating
Pretreatment Standards for Existing Sources
40 CFR 423.16**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium	0.2	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc	1.0	N/A
pH	5.0 – 10.5 SU	N/A

**APPENDIX C – Iron and Steel Manufacturing
Pretreatment Standards for New Sources
Subpart J 40 CFR 420.106 (b) (1) and
Subpart L 40 CFR 420.126 (a) (1)**

**Allied Tube and Conduit Corporation
2525 North 27th Avenue
Phoenix, Arizona 85009-1710**

Concentration Equivalent		
Permit № 1702-5378		
Effective 02/01/2017 through 01/31/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium VI*	0.3	0.1
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead*	0.41	0.8
Mercury	0.0023	N/A
Oil & Grease**	100*	N/A
pH	5.0 – 10.5	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc*	3.0	1.0

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40 CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

** Permittee is required to use EPA Method 1664 (Revision A or B) Silica Gel Treated n-Hexane Extractable Material (SGT HEM) in 40 CFR 136 for Oil & Grease (O&G) analysis, and Permittee must report Total O&G- SGT HEM. The non-polar material O&G Daily Maximum target level should be no greater than 100 mg/L as recommended in "Treatability of Oil and Grease Discharge to Publicly Owned Treatment Works", Document EPA 440/1-75/066, April 1975.

**APPENDIX D – Metal Finishing
Pretreatment Standards for Existing Sources
40 CFR 433.15**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	0.26
Chromium	2.77	1.71
Copper	1.5	2.07
Cyanide (T)	1.20	0.65
Lead	0.41	0.43
Mercury	0.0023	N/A
Nickel	3.98	2.38
Selenium	0.10	N/A
Silver	0.43	0.24
TTO	2.13	N/A
Zinc	2.61	1.48
pH	5.0 – 10.5 SU	N/A

Cyanide limitations apply to cyanide bearing process wastewaters prior to combining with other process flows.

**APPENDIX E - Metal Finishing
Pretreatment Standards for New Sources
40 CFR 433.17**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	0.07
Chromium	2.77	1.71
Copper	1.5	2.07
Cyanide (T)	1.20	0.65
Lead	0.41	0.43
Mercury	0.0023	N/A
Nickel	3.98	2.38
Selenium	0.10	N/A
Silver	0.43	0.24
TTO	2.13	N/A
Zinc	2.61	1.48
pH	5.0 – 10.5 SU	N/A

Cyanide limitations apply to cyanide bearing process wastewaters prior to combining with other process flows.

**APPENDIX F – Electrical and Electronic Components
 Subpart A – Semiconductor Subcategory
 Pretreatment Standards for New Sources
 40 CFR 469.18**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
TTO	1.37	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

**APPENDIX G – Aluminum Forming
Subpart C – Extrusion Subcategory
Pretreatment Standards for Existing Sources
40 CFR 467.35**

**Hydro Extrusions North America, LLC - Remelt Operation
249 South 51st Avenue
Phoenix Arizona 85043-3715**

Concentration Equivalent		
Permit № 1803-21490		
Effective 03/5/2018 through 12/31/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium*	3.05	1.24
Copper	1.5	N/A
Cyanide (T) *	2.0	1.51
Lead	0.41	N/A
Mercury	0.0023	N/A
Oil & Grease*	356.5	180.84
Selenium	0.10	N/A
Silver	1.2	N/A
TTO*	4.750	N/A
Zinc*	3.5	7.61
pH	5.0 – 10.5 SU	N/A

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40 CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

**APPENDIX H - Aluminum Forming
Subpart C – Extrusion Subcategory
Pretreatment Standards for Existing Sources
40 CFR 467.35**

**Hydro Extrusions North America, LLC
- Extrusion Operation Plant 1
249 South 51st Avenue
Phoenix Arizona 85043-3715**

Concentration Equivalent		
Permit № 1803-21491		
Effective 03/05/2018 through 12/31/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium*	1.08	0.74
Copper	1.5	N/A
Cyanide (T) *	.71	0.30
Lead	0.41	N/A
Mercury	0.0023	N/A
Oil & Grease*	128.51	64.45
Selenium	0.10	N/A
Silver	1.2	N/A
TTO*	1.690	N/A
Zinc*	3.5	1.49
pH	5.0 – 10.5 SU	N/A

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

**APPENDIX I – Aluminum Forming
Subpart C – Extrusion Subcategory
Pretreatment Standards for Existing Sources
40 CFR 467.35**

**Hydro Extrusions North America, LLC
- Extrusion Operation Plant 2
50 South 49th Avenue
Phoenix Arizona 85043-3825**

Concentration Equivalent		
Permit № 1803-21489		
Effective 03/05/2018 through 12/31/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium*	3.20	1.31
Copper	1.5	N/A
Cyanide (T) *	2.0	0.89
Lead	0.41	N/A
Mercury	0.0023	N/A
Oil & Grease*	390.84	188.32
Selenium	0.10	N/A
Silver	1.2	N/A
TTO*	5.010	N/A
Zinc*	3.5	4.44
pH	5.0 – 10.5 SU	N/A

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

**APPENDIX J – Coil Coating
Subpart D Can Making Subcategory
Pretreatment Standards for Existing Sources
40 CFR 465.44**

**Rexam Beverage Can Company
211 North 51st Avenue
Phoenix, Arizona 85043-3704**

Concentration Equivalent		
Permit № 1710-5475		
Effective 10/01/2017 through 09/30/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium*	0.90	0.37
Copper*	1.5	2.06
Cyanide (T)	2.0	N/A
Fluoride*	122.6	54.4
Lead	0.41	N/A
Manganese*	1.40	0.59
Mercury	0.0023	N/A
Oil & Grease*	41.22	24.74
Phosphorus (T)*	34.42	14.07
Selenium	0.10	N/A
Silver	1.2	N/A
TTO*	0.66	0.31
Zinc*	3.01	1.26
pH	5.0 – 10.5 SU	N/A

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40 CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

**APPENDIX K – Pharmaceutical Manufacturing
Subpart D Mixing/Compounding and Formulation Subcategory
Pretreatment Standards for Existing Sources
40 CFR 439.46**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Acetone	20.7	8.2
n-Amyl Acetate	20.7	8.2
Ethyl Acetate	20.7	8.2
Isopropyl Acetate	20.7	8.2
Methylene Chloride	3.0	0.7
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

APPENDIX L - Pharmaceutical Manufacturing
Subpart D Mixing/Compounding and Formulation Subcategory
Pretreatment Standards for New Sources
40 CFR 439.47

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Acetone	20.7	8.2
n-Amyl Acetate	20.7	8.2
Ethyl Acetate	20.7	8.2
Isopropyl Acetate	20.7	8.2
Methylene Chloride	3.0	0.7
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

**APPENDIX M - Centralized Waste Treatment
Subpart A – Metals Treatment and Recovery
Pretreatment Standards for New Sources
40 CFR 437.16**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Antimony	0.249	0.206
Arsenic	0.13	0.104
Cadmium	0.047	0.0962
Chromium	15.5	3.07
Cobalt	0.192	0.124
Copper	1.5	1.06
Cyanide(T)	2.0	N/A
Lead	0.41	0.283
Mercury	0.0023	0.000739
Nickel	3.95	1.45
Selenium	0.10	0.408
Silver	0.120	0.0351
Tin	0.409	0.120
Titanium	0.0947	0.0618
Vanadium	0.218	0.0662
Zinc	2.87	0.641
pH	5.0 – 10.5 SU	N/A

**APPENDIX N – Centralized Waste Treatment
Subpart B – Oils Treatment and Recovery
Pretreatment Standards for New Sources
40 CFR 437.26**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Bis(2-ethylhexylphthalate)	0.215	0.101
Cadmium	0.047	N/A
Carbazole	0.598	0.276
Chromium	0.746	0.323
Cobalt	56.4	18.8
Copper	1.5	0.242
Cyanide (T)	2.0	N/A
Fluoranthene	0.0537	0.0268
Lead	0.350	0.160
Mercury	0.0023	N/A
n-Decane	0.948	0.437
n-Octadecane	0.589	0.302
Selenium	0.10	N/A
Silver	1.2	N/A
Tin	0.335	0.165
Zinc	3.5	4.50
pH	5.0 – 10.5 SU	N/A

**APPENDIX O – Centralized Waste Treatment
Subpart C – Organics Treatment and Recovery
Pretreatment Standards for New Sources
40 CFR 437.36**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
2,4,6-Trichlorophenol	0.155	0.106
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
p-Cresol	0.698	0.205
o-Cresol	1.92	0.561
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

**APPENDIX P – Centralized Waste Treatment
Subpart D Multiple Wastestreams
Pretreatment Standards for Existing Sources
40 CFR 437.46(b)**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
2,4,6-Trichlorophenol	0.155	0.106
Antimony	0.249	0.206
Arsenic	0.13	0.104
Bis(2-ethylhexyl)phthalate	0.267	0.158
Cadmium	0.047	0.0962
Carbazole	0.392	0.233
Chromium	0.947	0.487
Cobalt	0.192	0.124
Copper	0.405	0.301
Cyanide	2.0	N/A
Fluoranthene	0.787	0.393
Lead	0.222	0.172
Mercury	0.00234	0.000739
Molybdenum	N/A	N/A
n-Decane	5.79	3.31
Nickel	3.95	1.45
n-Octadecane	1.22	0.925
o-Cresol	1.92	0.561
p-Cresol	0.698	0.205
Selenium	0.10	N/A
Silver	0.120	0.0351
Tin	0.409	0.120
Titanium	0.0947	0.0618
Vanadium (T)	0.218	0.0662
Zinc	2.87	0.641
pH	5.0 – 10.5 SU	N/A

**APPENDIX Q – Centralized Waste Treatment
Subpart D Multiple Wastestreams
Pretreatment Standards for New Sources
40 CFR 437.47(b)**

Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
2,4,6-Trichlorophenol	0.155	0.106
Antimony	0.249	0.206
Arsenic	0.13	0.104
Bis(2-ethylhexyl)phthalate	0.215	0.101
Cadmium	0.047	0.0962
Carbazole	0.598	0.276
Chromium	0.746	0.323
Cobalt	0.192	0.124
Copper	0.500	0.242
Cyanide	2.0	N/A
Fluoranthene	0.0537	0.0268
Lead	0.350	0.160
Mercury	0.00234	0.000739
Molybdenum	N/A	N/A
n-Decane	0.948	0.437
Nickel	3.95	1.45
n-Octadecane	0.589	0.302
o-Cresol	1.92	0.561
p-Cresol	0.698	0.205
Selenium	0.10	N/A
Silver	0.120	0.0351
Tin	0.409	0.120
Titanium	0.0947	0.0618
Vanadium (T)	0.218	0.0662
Zinc	2.87	0.641
pH	5.0 – 10.5 SU	N/A

**APPENDIX R – Nonferrous Metals Manufacturing
Subpart AB Primary & Secondary Titanium Subcategory
Pretreatment Standards for New Sources
40 CFR 421.306**

**Mega Metals
1325 North 22nd Avenue
Phoenix, Arizona 85009-3714**

Concentration Equivalent for:		
Permit № 1809-27341		
Effective 09/01/2018 through 08/31/2023		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium*	3.2	1.28
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead*	0.41	1.11
Mercury	0.0023	N/A
Nickel*	4.7	3.17
Oil & Grease**	N/A	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
Titanium*	4.5	1.97
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40 CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

** Permittee is required to use EPA Method 1664 (Revision A or B) Silica Gel Treated n-Hexane Extractable Material (SGT HEM) in 40 CFR 136 for Oil & Grease (O&G) analysis, and Permittee must report Total O&G- SGT HEM. The non-polar material O&G Daily Maximum target level should be no greater than 100 mg/L as recommended in "Treatability of Oil and Grease Discharge to Publicly Owned Treatment Works", Document EPA 440/1-75/066, April 1975.

**APPENDIX S - Electrical and Electronic Components
Subpart A – Semiconductor Subcategory
Pretreatment Standards for New Sources
40 CFR 469.18**

**Entrepix, Inc.
4717 East Hilton Avenue
Phoenix, Arizona 85034-6404**

98.70% Combined Wastestream Formula		
Permit № 1804-30385		
Effective 04/01/2018 through 03/31/2023		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
Selenium	0.10	N/A
Silver	.43	N/A
TTO*	1.35	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

*These limitations were derived by applying the Combined Wastestream Formula at 40 CFR 403.6(e) to the discharges regulated under Local Limitations and Electrical and Electronic Components Subpart A – Semiconductor Subcategory Standards (40 CFR 469).

**APPENDIX T – Electrical and Electronic Components
Subpart B – Electronic Crystals Subcategory
Pretreatment Standards for New Sources
40 CFR 469.28**

**SUMCO Southwest Corporation
19801 North Tatum Boulevard
Phoenix, Arizona 85050-4201**

23.14% Combined Wastestream Formula		
Permit № 1703-5340		
Effective 03/01/2017 through 02/28/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A*
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Lead	0.41	N/A
Mercury	0.0023	N/A
Selenium	0.10	N/A
Silver	1.2	N/A
TTO**	0.317	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

* 469.28 Arsenic limitations apply only to Gallium or Indium Arsenide manufacturers

**These limitations were derived by applying the Combined Wastestream Formula at 40 CFR 403.6(e) to the discharges regulated under Local Limitations and Electrical and Electronic Components Subpart B – Electronic Crystals Subcategory Standards (40 CFR 469).

**APPENDIX U – Metal Molding and Casting
Subpart C – Ferrous Casting Subcategory
Pretreatment Standards for New Sources
40 CFR 464.36(e) Investment Casting**

**Arizona Cast Turbine LLC
3110 N Oakland Street, Suite 1114
Mesa, Arizona 85215**

Concentration Equivalent		
Permit Effective 01/31/2017 through 01/30/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Chromium	0.2	N/A
Copper*	1.5	1.76
Cyanide (T)	2.0	N/A
Lead	0.41	4.3
Mercury	0.0023	N/A
Oil and Grease *	330	110
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc*	1.0	6.17
TTO*	13.2	4.3
pH	5.0 – 10.5 SU	N/A

*These limitations were converted from the Federally promulgated mass-based standards in accordance with the Federal General Pretreatment Regulations at 40 CFR 403.6(c). These limits represent the more stringent of the converted standards and local limitations.

**APPENDIX V - Metal Finishing
Pretreatment Standards for New Sources
40 CFR 433.17**

**MPP Group of Companies
230 South 49th Avenue
Phoenix, Arizona 85043-3905**

96.03% Combined Wastestream Limits		
Permit № 1801-5335		
Effective 01/01/2018 through 12/31/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium*	0.047	0.06
Chromium*	2.66	1.64
Copper*	1.5	1.90
Cyanide (T)*	1.15	0.63
Lead*	0.41	0.39
Mercury	0.0023	N/A
Nickel*	3.83	2.29
Selenium	0.10	N/A
Silver*	0.41	0.23
TTO*	2.05	N/A
Zinc*	2.51	1.42
pH	5.0 – 10.5 SU	N/A

*These limitations were derived by applying the Combined Wastestream Formula at 40 CFR 403.6(e) to the discharges regulated under Local Limitations and Metal Finishing Standards (40 CFR 433). Cyanide limitations apply to cyanide bearing process wastewaters prior to combining with other process flows.

**APPENDIX W - Metal Finishing
Pretreatment Standards for New Sources
40 CFR 433.17**

**Honeywell Mechanical Repair and Overhaul
Phoenix Repair and Overhaul
1944 East Sky Harbor Circle
Phoenix, Arizona 85034-3442**

90.91% Combined Wastestream Limits		
Permit № 1807-2990		
Effective 07/01/2018 through 06/30/2023		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Arsenic	0.13	N/A
Cadmium*	0.047	0.068
Chromium*	2.41	1.49
Copper*	1.5	1.80
Cyanide (T)*	1.05	0.57
Lead*	0.41	0.37
Mercury	0.0023	N/A
Nickel*	3.47	2.07
Selenium	0.10	N/A
Silver*	0.37	0.21
TTO*	1.85	N/A
Zinc*	2.27	1.29
pH	5.0 – 10.5 SU	N/A

*These limitations were derived by applying the Combined Wastestream Formula at 40 CFR 403.6(e) to the discharges regulated under Local Limitations and Metal Finishing Standards (40 CFR 433). Cyanide limitations apply to cyanide bearing process wastewaters prior to combining with other process flows.

**APPENDIX X– Pharmaceutical Manufacturing
Subpart D Mixing/Compounding and Formulation Subcategory
Pretreatment Standards for New Sources
40 CFR 439.47**

**Celgene Corporation
620 North 51st Avenue
Phoenix, Arizona 85043-2702**

3.60% Combined Wastestream Limits		
Permit № 1903-27278		
Effective 03/01/2019 through 02/28/2022		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Acetone*	0.750	0.300
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Ethyl Acetate*	0.750	0.300
Isopropyl Acetate*	0.750	0.300
Lead	0.41	N/A
Mercury	0.0023	N/A
Methylene Chloride*	0.110	0.030
n-Amyl Acetate*	0.750	0.300
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

*These limitations were derived by applying the Combined Wastestream Formula at 40 CFR 403.6(e) to the discharges regulated under Local Limitations and Pharmaceutical Manufacturing – Subpart D Mixing/Compounding and Formulation Subcategory Standards (40 CFR 439).

**APPENDIX Y– Pharmaceutical Manufacturing
Subpart D Mixing/Compounding and Formulation Subcategory
Pretreatment Standards for Existing Sources
40 CFR 439.46**

**The Procter & Gamble Manufacturing Company
2050 South 35th Avenue
Phoenix, Arizona 85009-6705**

70.50% Combined Wastestream Limits		
Permit № 1903-27278		
Effective 07/01/2019 through 06/30/2024		
Parameter	Daily Maximum (mg/L)	Monthly Average (mg/L)
Acetone*	14.6	5.8
Arsenic	0.13	N/A
Cadmium	0.047	N/A
Copper	1.5	N/A
Cyanide (T)	2.0	N/A
Ethyl Acetate*	14.6	5.8
Isopropyl Acetate*	14.6	5.8
Lead	0.41	N/A
Mercury	0.0023	N/A
Methylene Chloride*	2.1	0.3
n-Amyl Acetate*	14.6	5.8
Selenium	0.10	N/A
Silver	1.2	N/A
Zinc	3.5	N/A
pH	5.0 – 10.5 SU	N/A

*These limitations were derived by applying the Combined Wastestream Formula at 40 CFR 403.6(e) to the discharges regulated under Local Limitations and Pharmaceutical Manufacturing – Subpart D Mixing/Compounding and Formulation Subcategory Standards (40 CFR 439).

Limits Appendices Tempe

The Limits Appendices on the following pages are used in the City of Tempe Significant Industrial User Compliance Status Reports of this annual report, and apply to the discharges from all permitted industrial users throughout the City of Tempe service area. The more stringent of applicable Federal Categorical Standards and the Local Limits contained in Appendix T-A are applied on a parameter-by-parameter basis to the industrial users' discharges.

All limitations for each limit appendix are in concentration units of milligrams per liter, unless noted otherwise.

APPENDIX DESCRIPTION

T-A	Tempe Local Limits
T-B	413.14 and 413.54 Electroplating Subparts A and E PSES < 10,000 GPD
T-C	413.84 Electroplating PSES > 10,000 GPD
T-D	433.15 Metal Finishing PSES
T-E	433.17 Metal Finishing PSNS
T-F	469.16 and 469.18 Electrical and Electronic Components Subpart A PSES and PSNS
T-G	469.26 Electrical and Electronic Components Subpart B PSES
T-H	469.34 Electrical and Electronic Components Subpart C PSES
T-I	426.136.Glass Manufacturing Subpart M (b) PSNS
T-J	461.15.Battery Manufacturing Subpart A (2) PSNS
T-K	423.16 Steam Electric Power Generating PSES
T-L	439.47 Pharmaceutical Manufacturing Subpart D PSNS
T-M	421.266 Nonferrous Metals Manufacturing Subpart X PSNS
T-N	469.28 Electrical and Electronic Components Subpart B PSNS
T-O	469.36 Electrical and Electronic Components Subpart C PSNS

**APPENDIX T-A
Tempe Local Limits**

Metals	Daily Maximum mg/l	Organics	Daily Maximum mg/l	
Arsenic	0.13	Benzene	0.035	
Cadmium	0.047	Chloroform	2.0	
Copper	1.5	Other	Daily Maximum	
Lead	0.41	pH (High)	10.5 standard units	
Mercury	0.0023	pH (Low)	5 standard units	
Selenium	0.10	Temperature (Max)	150°F/66°C	Degrees
Silver	1.2	Flash Point	140°F/60°C	Degrees
Zinc	3.5			
Anions	Daily Maximum mg/l	Prohibited Substances		
Cyanide (T)	2.00	4,4' - DDE		
		4,4' - DDT		
		Aldrin		
		BHC-Alpha		
		BHC-Beta		
		BHC-Gamma (Lindane)		
		Heptachlor		
		Heptachlor Epoxide		
		Polychlorinated Biphenyl Compounds (PCBs)		
		Pretreatment Sludges		

APPENDIX T-B

40 CFR 413 - Electroplating Point Source Category, <10,000 GPD

**40 CFR 413.14, Subpart A – Electroplating of Common Metals Subcategory,
Pretreatment Standards for Existing Sources (PSES)**

and

**40 CFR 413.54, Subpart E – Coatings Subcategory,
Pretreatment Standards for Existing Sources (PSES)**

Parameter	Daily Maximum mg/l	Four-Day Average mg/l	Sample Method
Cyanide, Amenable*	5.00	2.70	Grab
Lead, Total	0.60	0.40	Composite
Cadmium, Total	1.20	0.70	Composite
Total Toxic Organics	4.57	N/A	Grab

* The Cyanide sample shall be taken at the end of CN destruction and before mixing with any other waste stream if process is present.

APPENDIX T-C

**40 CFR 413.84 - Electroplating Point Source Category, > 10,000 GPD
Subpart H - Printed Circuit Board Subcategory,
Pretreatment Standards for Existing Sources (PSES)**

Parameter	Daily Maximum mg/l	Four-Day Average mg/l	Sample Method
Cyanide, Total*	1.90	1.00	Grab
Copper, Total	4.50	2.70	Composite
Nickel, Total	4.10	2.60	Composite
Chromium, Total	7.00	4.00	Composite
Zinc, Total	4.20	2.60	Composite
Lead, Total	0.60	0.40	Composite
Cadmium, Total	1.20	0.70	Composite
Total Metals**	10.50	6.80	Composite
Total Toxic Organics	2.13	N/A	Grab

* The Cyanide sample shall be taken at the end of CN destruction and before mixing with any other waste stream if process is present.

** The term "total metals" is defined as the sum of the concentration or mass of Copper (Cu), Nickel (Ni), Chromium (Cr)(total) and Zinc (Zn).

APPENDIX T-D

**40 CFR 433.15 - Metal Finishing Point Source Category,
Subpart A – Metal Finishing Subcategory,
Pretreatment Standards for Existing Sources (PSES)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Cadmium, Total	0.69	0.26	Composite
Chromium, Total	2.77	1.71	Composite
Copper, Total	3.38	2.07	Composite
Lead, Total	0.69	0.43	Composite
Nickel, Total	3.98	2.38	Composite
Silver, Total	0.43	0.24	Composite
Zinc, Total	2.61	1.48	Composite
Cyanide, Total*	1.20	0.65	Grab
Total Toxic Organics	2.13	N/A	Grab

* The Cyanide sample shall be taken at the end of CN destruction and before mixing with any other waste stream if process is present.

APPENDIX T-E

**40 CFR 433.17 - Metal Finishing Point Source Category,
Subpart A – Metal Finishing Subcategory,
Pretreatment Standards for New Sources (PSNS)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Cadmium, Total	0.11	0.07	Composite
Chromium, Total	2.77	1.71	Composite
Copper, Total	3.38	2.07	Composite
Lead, Total	0.69	0.43	Composite
Nickel, Total	3.98	2.38	Composite
Silver, Total	0.43	0.24	Composite
Zinc, Total	2.61	1.48	Composite
Cyanide, Total*	1.20	0.65	Grab
Total Toxic Organics	2.13	N/A	Grab

* The Cyanide sample shall be taken at the end of CN destruction and before mixing with any other waste stream if process is present.

APPENDIX T-F

**40 CFR 469.16 – Electrical and Electronic Components Point Source Category,
Subpart A – Semiconductor Subcategory
Pretreatment Standards for Existing Sources (PSES)**

AND

**40 CFR 469.18 - Electrical and Electronic Components Point Source Category,
Subpart A - Semiconductor Subcategory,
Pretreatment Standards for New Sources (PSNS)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Total Toxic Organics	1.37	N/A	Grab

APPENDIX T-G

**40 CFR 469.26 - Electrical and Electronic Components Point Source Category,
Subpart B - Electronic Crystals Subcategory,
Pretreatment Standards for Existing Sources (PSES)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Total Toxic Organics	1.37	N/A	Grab
Arsenic, Total	2.09	0.83	Composite

APPENDIX T-H

**40 CFR 469.34 - Electrical and Electronic Components Point Source Category,
Subpart C - Cathode Ray Tube Subcategory,
Pretreatment Standards for Existing Sources (PSES)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Total Toxic Organics	1.58	N/A	Grab
Cadmium, Total	0.06	0.03	Composite
Chromium, Total	0.65	0.30	Composite
Lead, Total	1.12	0.41	Composite
Zinc, Total	1.38	0.56	Composite
Fluoride, Total	35.00	18.00	Composite

APPENDIX T-I

**40 CFR 426.136 - Glass Manufacturing Point Source Category
Subpart M (b) - Hand Pressed and Blown Glass Manufacturing Subcategory
Pretreatment Standards for New Sources (PSNS)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Fluoride, Total	26.00	13.00	Composite

APPENDIX T-J

40 CFR 461.15 - Battery Manufacturing Point Source Category Subpart A (2) - Cadmium Subcategory - Impregnated Anodes Pretreatment Standards for New Sources (PSNS)

Parameter	Daily Maximum mg/kg	Monthly Average mg/kg	Sample Method
Cadmium, Total	40.00	16.00	Composite
Nickel, Total	110.00	74.00	Composite
Zinc, Total	204.00	84.00	Composite
Cobalt, Total	28.00	14.00	Composite

APPENDIX T-K

**40 CFR 423.16 - Steam Electric Power Generating Point Source Category
Pretreatment Standards for Existing Sources (PSES)**

Parameter	Chemical Metal Cleaning Wastes Daily Maximum mg/l	Cooling Tower Blowdown Maximum anytime mg/l	Sample Method
Copper, Total*	1.00	N/A	Composite
Chromium, Total	N/A	0.20	Composite
Zinc, Total	N/A	1.00	Composite
All other Priority Pollutants	N/A	No Detectable Amount	Composite

There shall be no discharge of Polychlorinated Biphenyls.

* This applies only when chemical metal cleaning waste is being discharged.

APPENDIX T-L

40 CFR 439.47 - Pharmaceutical Manufacturing Point Source Category Subpart D - Mixing/Compounding and Formulation Subcategory Pretreatment Standards for New Sources (PSNS)

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Acetone	20.70	8.20	Grab
n-Amyl acetate	20.70	8.20	Grab
Ethyl acetate	20.70	8.20	Grab
Isopropyl acetate	20.70	8.20	Grab
Methylene chloride	3.00	0.70	Grab

APPENDIX T-M

**40 CFR 421 - Nonferrous Metals Manufacturing Point Source Category
Subpart X - Secondary Precious Metals Subcategory,
§421.266 - Pretreatment Standards for New Sources (PSNS)
(c) Spent Plating Solutions**

(as amended at 55 FR 31711-31713, August 3, 1990)

Pollutant	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Copper	1.28	0.61	Composite
Cyanide (Total)	0.20	0.08	Grab
Zinc	1.02	0.42	Composite
Combined Metals (Au, Pt, Pd only)	0.30	----	Composite
Ammonia (as N)	133.30	58.60	Composite

APPENDIX T-N

**40 CFR 469.28 - Electrical and Electronic Components
Point Source Category
Subpart B - Electronic Crystals Subcategory
Pretreatment Standards for New Sources (PSNS)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Total Toxic Organics	1.37	N/A	Grab
Arsenic (T)*	2.09	.083	Composite

* The Arsenic (T) limitation only applies to manufacturers of gallium or indium arsenide crystals.

APPENDIX T-O

**40 CFR 469.36 – Electrical and Electronic Components
Point Source Category
Subpart C – Cathode Ray Tube Subcategory
Pretreatment Standards for New Sources (PSNS)**

Parameter	Daily Maximum mg/l	Monthly Average mg/l	Sample Method
Total Toxic Organics	1.58	N/A	Grab
Cadmium (T)	0.06	0.03	Composite
Chromium (T)	0.56	0.26	Composite
Lead (T)	0.72	0.27	Composite
Zinc (T)	0.80	0.33	Composite
Fluoride (T)	35.00	18.00	Composite

GUIDE TO THE SIU COMPLIANCE STATUS REPORT FORM

In order to facilitate understanding of the information supplied on the Significant Industrial User (SIU) Compliance Status Report Form contained in this report, the following words and phrases have been defined beginning with the top left hand portion of the form and continuing through to the bottom of the reverse side (refer to sample form following this guide):

1. **NAME:** The correct legal name of the significant industrial user (SIU).
2. **REPORT PERIOD:** The report is done yearly or on a quarterly basis. The four quarters end on March 31, June 30, September 30, and December 31. The year ends on December 31. The report period including the year is shown here.
3. **SERVICE ADDRESS:** The street address of the SIU, which contains the authorized discharge point(s) to the sewer.
4. **MAILING ADDRESS:** The address where written communication is given to the SIU. This may be the same as the service address.
5. **CATEGORICAL INDUSTRIAL USER:** This is followed by a "yes" or "no". If a yes is inserted, then the appropriate 40 CFR Citation is used in 5a. For example, a company having plating operations with thermal infusion coating process would have a 40 CFR cite of 40 CFR 433.17. "CFR" stands for Code of Federal Regulations. If this is a Non-Categorical SIU, N/A would be shown in 5a.
6. **LIMITS APPENDIX:** Identifies the parameters and limits with which the SIU must comply. These limits are identified with letters of the alphabet, which in turn corresponds to the applicable limits. For example, the letter "A" contains the city code limitations. To review the actual limitations, see the limits appendices found in this Report.
7. **BMR SUBMITTED:** This is the date that the Baseline Monitoring Report (BMR) was submitted. This report is a requirement for all categorical users discharging to the sewer.
8. **TTO Certification Date Submitted:** Either the date submitted or N/A should be indicated. For facilities having limits for total toxic organics (TTO), this indicates the date certification was last provided during the pretreatment year.
9. **PERMIT EFFECTIVE:** This is the date that a City Permit was effective authorizing the SIU to discharge to the City sewer.
10. **PERMIT EXPIRES:** This is the date that the City Permit expires. If the date is followed by the letters "AC", this means that even though the SIU timely submitted an application for a renewed permit, a renewed permit has not yet been issued and is administratively continued or automatically extended. The existing permit remains in full force and effect until the renewed permit is issued.
11. **SAMPLING LOCATION VERIFIED ON:** This is the last date on which the point at which compliance samples are taken was visually viewed and verified by the City.
12. **RCRA NOTICE:** This acronym stands for the Resource Conservation and Recovery Act (42 U.S.C. § 6901 et seq.). 40 CFR 403.8(f)(2)(iii) requires the City to notify industrial users (IUs) of any applicable requirements under Subtitles C and D of RCRA. Generally, this notice describes requirements applicable to IUs regarding the identification of hazardous wastes generated by those IUs and limitations regarding hazardous waste accumulation and storage by IUs. This notice is generally given to the IU in one of the following EPA documents: "RCRA Information on Hazardous Waste for Publicly Owned Treatment Works"; Understanding the Small Quantity Generator Hazardous Waste Rules." The RCRA Notice is the date of the letter sent to the IU.
13. **SLUG CONTROL PLAN EVALUATION DATE:** This is the last date that the SIU was evaluated to determine the need for a plan to control slug discharges.
14. **COMPLIANCE SAMPLING POINT No:** This refers to a manhole, petcock, valve, sampling port, open-channel flow device, or other waste plumbing appurtenance specifically

designated by the Director for monitoring wastewater flows and for collection of samples for determination of compliance with effluent limitations.

15.
 - a. **NUMBER OF INSPECTIONS:** Indicates the number of on-site inspections of the SIU during the quarter. Every inspection is followed-up with a written report. The date the inspection was actually performed determines its quarter location on the form, even though a typed report may not be finalized until a later quarter.
 - b. **NUMBER OF CITY SAMPLING DAYS:** Indicates the actual number of days that the City took wastewater samples that were successfully analyzed with a result during the quarter for the IU as a whole. NOTE: Days in which pH was the only parameter monitored are not included in this number. NOTE: Where the IU has multiple compliance sampling points, the number City Sampling Days IS NOT multiplied by the number of compliance sampling points.
 - c. **NUMBER OF SIU SAMPLING DAYS:** Indicates the actual number of days that the SIU took wastewater samples that were successfully analyzed with a result during the quarter. Note: Days in which pH was the only parameter monitored are not included in this number.
 - d. **NUMBER OF PARAMETER VIOLATIONS:** Indicates the actual number of parameters (limitations) that were violated during the quarter. As an example, if there was one copper and one silver limit exceeded on July 14, then the Arabic number two (2) would appear for this requirement in the Third Quarter box.
 - e. **NUMBER OF INSPECTION VIOLATIONS:** Indicates by quarter the number of pretreatment violations that were found through on-site inspections of the SIU.
 - f. **NUMBER OF REPORTING VIOLATIONS:** SIUs are required to submit periodic reports that include results of their sampling, as well as meeting other reporting obligations. This indicates the actual number of pretreatment violations arising from failure to meet reporting requirements.
 - g. **NUMBER OF PERMIT CONDITION VIOLATIONS:** Indicates by quarter the number of permit condition violations found. Examples of permit condition violations are failure to sample required parameters; using incorrect analytical methods; taking grab samples in lieu of composite when required. NOTE: Each parameter counts as a violation where the IU fails to sample or fails to correctly analyze.
 - h. **COMPLIANCE STATUS:** This is indicated by the letters "C", "I", and "S", which is further discussed in "Compliance codes" below.
 - i. **EVALUATED AS OF:** This is the actual date on which the compliance status of the SIU was determined, using data available at that time.

16. COMPLIANCE CODES:

- a. C = Compliance: This means that the SIU was in 100 percent compliance with every applicable pretreatment requirement for every day in the quarter.
- b. I = Inconsistent Compliance: This means that the SIU had at least one pretreatment violation during the quarter, but the violation(s) did not meet the definition of Significant Noncompliance (SNC).
- c. S = Significant Noncompliance (SNC): This is a term that is defined in 40 CFR 403.8(f)(2)(vii) and in City Code that requires an IU having SNC pretreatment violations to be published in the largest local daily newspaper (Arizona Republic). SNC is determined for each quarter using data from the previous six months. The quarter for SNC is determined by the date on which the violation occurred, i.e., the quarter for SNC late reporting is the first day on which the report is late. Pretreatment Violations that meet the SNC criteria are:
 - (i) chronic violations of wastewater discharge limits are those in which 66 percent or more of all of the measurements taken during a six-month period exceed (by any magnitude) the daily maximum limit or the average limit for the same pollutant

- parameter;
- (ii) technical review criteria (TRC) violations, are those in which 33 percent or more of all of the measurements for each pollutant parameter taken during a six-month period equal or exceed the product of the daily maximum limit or the average limit multiplied by the applicable TRC (TRC=1.4 FOR BOD, TSS, fats, oil, and grease, and 1.2 for all other pollutants except pH);
 - (iii) any other violation of a pretreatment effluent limit (daily maximum or longer-term average) that the City determines has caused, alone or in combination with other discharges, interference or pass through (including endangering the health of Publicly Owned Treatment Plant (POTW) personnel or the general public);
 - (iv) any discharge of a pollutant that has caused imminent endangerment to human health, welfare or to the environment or has resulted in the POTW's exercise of its emergency authority to halt or prevent such a discharge;
 - (v) failure to meet, within 90 days after the schedule date, a compliance schedule milestone contained in a permit or enforcement order for starting construction, completing construction, or attaining final compliance;
 - (vi) failure to provide, within 30 days after the due date, required reports such as baseline monitoring reports, 90-day compliance reports, periodic self monitoring reports, and reports on compliance with compliance schedules;
 - (vii) failure to accurately report noncompliance; or
 - (viii) any other violation or group of violations, which the City determines, will adversely affect the operation or implementation of the local pretreatment program.

17. IF COMPANY IS IN "I" OR "S" THEN THE FOLLOWING TABLE APPLIES: This table contains information, which clarifies the nature and degree of violation of pretreatment requirements. The Quarter indicates what time period in which the violation occurred. The type of violation tells what it is, e.g., parameter, reporting, permit condition, etc. This is followed by boxes labeled "date of violation", sample composite or grab", "limit federal or city", and "monitoring City or IU", which further identify the violation and source of detection. The remaining large box identifies the parameter violated, a comparison of the violation number with the actual limitation, and the total number of City and IU measurements combined per quarter for the purpose of SNC evaluation.

18. ENFORCEMENT STATUS: Is identified with letters of the alphabet by quarter. These letters are discussed in "Enforcement Status Codes," below.

19. ENFORCEMENT STATUS CODES:

- A. Notice of Violation (NOV) - Written notice to the violating SIU, that a pretreatment violation had occurred and requesting information as to why it happened and what corrective measures will be taken to prevent future occurrences.
- B. Administrative Order (AO) - A written document issued by the City ordering specified action to be taken. These generally are compliance orders instructing the SIU to install pretreatment equipment. Note: Requiring an appearance of the SIU at an administrative proceeding falls within this category.
- C. Civil Action Filed - A lawsuit filed in Maricopa County Superior Court or U.S. District Court seeking damages, civil penalties, and/or an injunction for pretreatment violations.
- D. Criminal Action Filed - An action taken by the City Prosecutor seeking criminal fines and/or jail time for pretreatment violations.
- E. Pretreatment Settlement Agreement (PSA) - An out-of-court settlement addressing pretreatment violations. These agreements may provide for the payment of monetary penalties, completion of a compliance schedule, as well as stipulated civil penalties for future violations.
- F. Assessment of Monetary Penalties - This can be done as part of an out of court settlement or included within a civil action. This is the payment of money by the SIU for pretreatment

violations. The maximum civil penalty by law is \$25,000 per day for each violation.

- G. Restriction of Flow - Reduction of the volume of industrial wastewater that can be lawfully discharged into the sanitary sewer.
 - H. Permit Revocation - A SIU can only lawfully discharge wastewater in accordance with a Permit issued by the City, which Permit can be taken away from the SIU.
 - I. Compliance Schedule Issued - Is a timetable under which specified pretreatment equipment must be installed and/or management and operation practices must be implemented. Such schedules may also be part of Administrative Orders or within Review Meeting Summaries.
 - J. Disconnection from Sewer - The actual physical blocking of the SIU from the sanitary sewer.
 - K. Published in Newspaper as Significant Violator in Prior Reporting Year - Newspaper publication is required of all SNC violators during the prior reporting year. This publication is generally done in March.
 - L. Temporary Increase in SIU Self Monitoring (TISM) - If an SIU has one or more violations of any effluent limit, then the IU is notified that it is required to sample for all parameters that were violated once a week for four consecutive weeks. In the event that it is not possible for an IU to increase the frequency of self monitoring, then an unannounced inspection at the IU site will be performed. The cost of this enforcement activity will be billed to the IU. This procedure would apply to those IUs who are currently sampling every day or for every batch prior to discharge.
 - N. No Enforcement Action - Enforcement action is not required or necessary.
- 20. ENFORCEMENT SUMMARY AND COMMENTS:** This begins the reverse portion of the form. Its purpose is to highlight and further elaborate upon violations and the appropriate enforcement action taken.
- 21. COMPANY NAME:** The legal name of the SIU.
- 22. PROCESS FLOW:** The calculated yearly average of wastewater that the SIU discharges to the sewer. This is usually stated in gallons per day (GPD).
- 23. GENERAL INFORMATION:** This section contains a brief description of what the SIU manufactures or what their regulated processes are in addition to the type of wastewater treatment system in place.
- 24. 1ST QUARTER:** Provides for enforcement summary and comments for the quarter ending March 31.
- 25. 2ND QUARTER:** Provides for enforcement summary and comments for the quarter ending June 30.
- 26. 3RD QUARTER:** Provides for enforcement summary and comments for the quarter ending September 30.
- 27. 4TH QUARTER:** Provides for enforcement summary and comments for the quarter ending December 31.
- 28. TO BE PUBLISHED THIS YEAR IN NEWSPAPER AS A SIGNIFICANT VIOLATOR:** SNC SIUs must be published in the newspaper. Indicate whether the SIU will be published for this reporting year is indicated in this section.
- 29. PENALTIES ASSESSED THIS REPORTING YEAR:** The City can seek civil penalties from SIUs for pretreatment violations. This section provides a running total of the amount of civil penalties assessed as agreed in all Pretreatment Settlement Agreements during the reporting year. NOTE: This is NOT the amount of calculated civil penalties. If criminal monetary penalties and/or jail time is applicable, then this will be specifically stated in this section.
- 30. PENALTIES COLLECTED THIS REPORTING YEAR:** This section provides a running total of the amount of all monetary penalties collected during the reporting year.

ENFORCEMENT SUMMARY AND COMMENTS (20)

Company Name: (21)

Process Flow: (22)

General Information and type of wastewater treatment	(23)
First Quarter	(24)
Second Quarter	(25)
Third Quarter	(26)
Fourth Quarter	(27)

To be published for this year in newspaper for Significant Non-Compliance? (28) Yes No

Penalties this reporting year: Assessed (29) Collected (30)

SECTION 2.1
CITY OF GLENDALE

POTW PRETREATMENT ANNUAL REPORT

CITY OF GLENDALE, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 91st Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020524

Person to Contact Concerning City of Glendale Information Contained in the Report:

Dave Nigh
Environmental Compliance Officer
City of Glendale
5901 North Glen Harbor Boulevard
Glendale, Arizona 85307-4502
623-930-4779

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all CITY OF GLENDALE attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

2/4/2021
Date:



Dave Nigh
Environmental Compliance Officer
City of Glendale, Arizona



CITY OF GLENDALE, ARIZONA



WESTGATE CITY CENTER: In the heart of Glendale's Sports & Entertainment District, Westgate includes restaurants, shops, hotels, sports and entertainment.

Glendale was founded in 1892 by W.J. Murphy and is located in Maricopa County on the western border of Phoenix. Incorporated as a town in 1910, agriculture and railway shipping sustained Glendale's early growth. The City has grown from its original one square mile to 61.5 square miles today.

Glendale's modern economic base is diverse and continues to expand. Major industries experiencing significant growth include healthcare, advanced business services, high tech manufacturing, technology, education, aviation, and aerospace and defense. Luke Air Force Base is the largest fighter training base in the western world and is located on the western boundary of Glendale known as the "New Frontier".

Downtown Glendale is the historic heart of Glendale and is renowned for its small town charm and spectacular annual events. The Glendale Sports and Entertainment District will again be in the international spotlight, hosting the 2023 Superbowl and 2024 NCAA Final Four Tournament. The SED is also home to the NHL Gila River Arena and NFL State Farm Stadium and Camelback Ranch spring training facility.

The Glendale Pretreatment Program officially began in 1983 as a requirement of the US EPA. The basis of this requirement is the 1972 Clean Water Act and the 1978 Federal General Pretreatment Regulations. The objectives of the Pretreatment Program are to prevent interference at the 91st Avenue Publicly Owned Treatment Works, prevent pass-through of pollutants from the treatment works, prevent contamination of treatment plant sludge to allow for land application or landfilling, and to protect the health and safety of our sewer and treatment plant personnel.



City of Glendale NPDES Annual Report 2020

Pretreatment Program Changes and Other Activities

Program Changes

No significant changes made this calendar year.

SROG Participation

City of Glendale Pretreatment Administrator acted as Chair of the monthly Sub Regional Operating Group (SROG) Technical Advisory Committee meetings held at the AMWUA offices in Phoenix during this period. Glendale Pretreatment personnel also attend quarterly Multi Cities FOG (fats, oil & grease) interest group meetings to discuss valley wide FOG related issues, and AZ WATER Pretreatment Committee meetings as well.

Training / Seminars Attended by Pretreatment Personnel

- City of Glendale Pretreatment personnel use an online safety training program to complete required OSHA compliance trainings.
- The annual AZ WATER conference was attended virtually by pretreatment division staff in 2020.
- All pretreatment inspectors attended the AZ FOG & Pretreatment virtual workshop in November 2020.
- Four pretreatment employees completed numerous webinar trainings relating to pretreatment, grease interceptors and related topics.

Public Participation / Education

The City of Glendale Pretreatment Program webpage is available through the city website at www.glendaleaz.com

City of Glendale Pretreatment personnel routinely distribute brochures during commercial inspection such as: *The City of Glendale Pretreatment Program*; *Pollution Prevention for Automotive Maintenance and Repair Shops*; *Pocket Guide to Grease Traps and Interceptors for Eating Establishments*; *Fat-Free Sewers (Published in English and Spanish)*; *Pollution Prevention Begins with You*; and the ADEQ *Managing Hazardous Waste Handbook*.



City of Glendale

Pretreatment Program 2020

Pollution Prevention Through Point Source Control Measures

Section C.1 of the National Pollutant Discharge Elimination System (NPDES) Permit No. AZ0020524 requires Sub-Regional Operating Group (SROG) member cities to submit progress reports detailing efforts pertaining to pollution prevention through point source control measures. The City of Glendale's activities of January through December 2020 are summarized below.

Point Source Control Program

Pollutants of Concern:

Businesses that have the potential to discharge pollutants of concern have been found in 50+ different SIC code designations within the City of Glendale. Our commercial inspection program includes all businesses with pollutants of concern including, but not limited to: laundries, dry cleaners, beauty shops, automotive repair, car washes, medical facilities, and public schools. Our updated database includes over 1,300 such businesses in Glendale and pollution prevention inspections are performed periodically at these businesses. There were over 1000 commercial inspections conducted in 2020 (includes follow-up inspections). Educational materials regarding waste minimization and pollution prevention are handed out during these inspections.

Fats, Oil & Grease Program:

The City of Glendale's Pretreatment database currently identifies 905 active restaurants, taverns, and other establishments that have potential fats, oil, and grease (FOG) discharges and thus receive periodic inspections based on needs by the staff. There were over 800 FOG related field inspections performed during 2020. The importance of FOG facility inspections continues and accounted for more than 60% of all pretreatment inspections conducted in 2020.

Significant Industrial Users (SIUs):

Annual sampling is conducted at Arrowhead Hospital; Banner Thunderbird Medical Center; Corning Communications; Magellan Aerospace, Glendale, Inc.; All Pro Pumping Company; and American Pumping Company. All Significant Industrial Users are sampled and inspected on an annual basis to ensure compliance with industrial pretreatment discharge permit requirements. The City of Glendale Pretreatment Program periodically reviews business license records, planning and building department information and conducts field investigations to find other potential significant industrial users.

Storm Water Program:

The City of Glendale's Municipal Separate Storm Sewer System (MS4) Permit was re-issued in August of 2010. With this permit, the Glendale Pretreatment Program received additional duties. Performing 100+ stormwater related inspections per fiscal year is a requirement of the permit assigned to the Pretreatment staff. For the calendar year from January 1, 2020 to December 31, 2020, the City of Glendale Pretreatment Program conducted over 140 storm water inspections from a prioritized list based on the 11 storm water categories outlined by the Arizona Department of Environmental Quality. A one-page best management practices guidance document for the retail gas station industry was delivered to facilities of this type to fulfill an educational outreach requirement in 2020.



CITY OF GLENDALE

SUMMARY OF PRETREATMENT PROGRAM EXPENDITURES

January 1, 2020 – December 31, 2020 – Total Pretreatment Expenditures
\$ 425,937.37

PRETREATMENT PROGRAM PERSONNEL

<u>Title</u>	<u>FTEs 2019</u>	<u>FTEs 2020</u>
Pretreatment Program Administrator	1.0	1.0
Pretreatment Inspector	3.0	3.0

PRETREATMENT PROGRAM EXPENDITURES

Computer Upgrades & Equipment	\$ 17,635.43
Chemicals, Sampling Supplies	\$11,184.01
General Supplies & Phones	\$ 4,363.03
Laboratory Analysis	\$ 13,653.47
Uniforms	\$1,229.50
Vehicles & Fuel	\$ 7,143.39
Professional Development	\$ 100.00
Permit Fees	\$ 3,000.00
Insurance	\$26,557.33
Personnel Expenses	\$ 341,071.21

PRETREATMENT EQUIPMENT INVENTORY

<u>Equipment Name</u>	<u>Purchased 2019</u>	<u>Total 2020</u>
Computers	1	5
Samplers	0	5
Flowmeters/pH Meters	0	3/3
Vehicles	0	4
Gas Detectors	0	3
Tablets	0	5



**CITY OF GLENDALE
LIST OF SIGNIFICANT INDUSTRIAL USERS
12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
1.	American Pumping Company 7220 N. 65th Avenue Glendale, Arizona 85301 Signatory: Mr. Tim Dear, Owner Contact: Mr. Tim Dear Phone: 602-252-8111	91 st Avenue	7699 1711	Local Limits
2.	Arrowhead Hospital 18701 N. 67th Avenue Glendale, AZ 85308 Signatory: Mr. Tim Riley, Director Facilities Services Contact: Mr. Tim Riley Phone: 623-537-3444	91 st Avenue	8062	Local Limits
3.	Banner Thunderbird Medical Center 5555 W Thunderbird Rd. Glendale, AZ 85306 Signatory: Mr. Raul Haro, Plant Operations Manager Contact: Mr. Raul Haro Phone: 602-865-3023	91 st Avenue	8062	Local Limits
4.	Corning Optical Communication RF LLC 5310 West Camelback Road Glendale, AZ 85301 Signatory: Mr. Gary DeRichie, Environmental Health and Safety Manager Contact: Mr. Gary DeRichie Phone: 623-245-1050 Ext. 230	91 st Avenue	3644 3471	433.15
5.	Magellan Aerospace, Glendale Inc. 5440 West Missouri Ave Glendale, AZ 85301 Signatory: Mr. Jason Dougherty, EHS Coordinator Contact: Mr. Jason Dougherty Phone: 623-934-7062	91 st Avenue	3361 3479	433.15
6.	All Pro Pumping and Hydro Jetting 6525 W. State Ave Glendale, AZ 85301 Signatory: Ryan Parsons, General Manager Contact: Charlie Ochoa Phone: 760-275-8330	91 st Avenue	7699 1711	Local Limits



CITY OF GLENDALE

PRETREATMENT PERFORMANCE SUMMARY ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST

ADDITIONS

The following Significant Industrial Users were added in 2020:

None

DELETIONS

The following Significant Industrial Users have ceased operations in 2020:

None

RECLASSIFICATIONS

The following Significant Industrial Users have been reclassified in 2020:

None

NAME CHANGES

The following Significant Industrial Users changed their names in 2020:

.None



City of Glendale
PRETREATMENT PERFORMANCE SUMMARY
91st Avenue Wastewater Treatment Plant

I. General Information						
Control Authority Name: City of Glendale			NPDES No.: AZ0020524			
Address: 5901 N. Glen Harbor Boulevard		City: Glendale		State: Arizona		ZIP: 85307-4502
Contact Person: Dave Nigh, Pretreatment Programs Administrator				Contact Telephone Number: (623) 930-4779		
Reporting Period: January 1 – December 31, 2020		Categorical IUs: 2		Significant Non-Categorical IUs: 4		
II. Significant Industrial User Compliance						
	Categorical		Non-categorical		Total SIUs	
	Ne	%	Ne	%	Ne	%
1. No. of SIUs in Full Compliance	2	100	4	100	6	100
2. No. of SIUs in Inconsistent Compliance	0	0	0	0	0	0
3. No. of SIUs in Significant Noncompliance	0	0	0	0	0	0
4. No. of Parameter Violations	0		0		0	
5. No. of Reporting Violations	0		0		0	
6. No. of Permit Condition Violations	0		0		0	
III. Compliance Monitoring Program						
	Categorical		Non-categorical		Total SIUs	
1. No. of Control Documents Issued	0		0		0	
2. No. of Non-sampling Inspections Conducted	4		4		8	
3. No. of Facilities Inspected (Non-sampling)	2		4		6	
4. No. of Sampling Visits Conducted	6		8		14	
5. No. of Facilities Sampled	2		4		6	
IV. Enforcement Actions						
	Categorical		Non-categorical		Total SIUs	
1. Notices of Violations Issued to SIUs	0		0		0	
2. Temporary Increase in IU Self Monitoring	0		0		0	
3. Administrative Orders Issued to SIUs	0		0		0	
4. Compliance Schedules Issued	0		0		0	
5. Settlement Agreements	0		0		0	
6. Other Actions	0		0		0	
7. Amount of Penalties Collected (Total Dollars / IUs Assessed)	\$ 0.00 / 0		\$ 0.00 / 0		\$ 0.00 / 0	

Company Name: All Pro Pumping

Process Flow: 8351 gpd (Average)

General Information and type of wastewater treatment

All Pro Pumping specializes in batch treatment of commercial grease trap and residential septic waste. All Pro Pumping pretreatment system is a non-hazardous liquid waste dewatering system that consists of lime conditioning, polymer addition, and belt press dewatering. Discharge average is approximately 8,351 gallons per day, 30 days per month. Flow and pH are monitored continuously during all batch discharges.

First Quarter

Second Quarter

Third Quarter

Fourth Quarter

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: American Pumping Service, Inc.

Process Flow: 8,333 gpd (Average)

General Information and type of wastewater treatment	<p>American Pumping specializes in batch treatment of commercial grease trap and residential septic waste. American Pumping's pretreatment system is a non-hazardous liquid waste dewatering system that consists of lime conditioning, polymer addition, and belt press dewatering. Discharge average is approximately 8,333 gallons per day, 21 days per month. Flow and pH are monitored continuously during all batch discharges.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arrowhead Hospital

Process Flow: 59,012 gpd (Average)

General Information and type of wastewater treatment	
Arrowhead Hospital is a full service health care facility with medical and surgical services. Pretreatment consists of acid neutralization (tank), solids screening, and a single three stage grease interceptor that collects hospital cafeteria waste.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

Company Name: Banner Thunderbird Medical Center

Process Flow: 94,706 gpd (Average)

General Information and type of wastewater treatment	
Banner Thunderbird Medical Center is a full service health care facility with medical and surgical services. Pretreatment consist of solids separation/settling along with a single three stage grease interceptor which collects hospital cafeteria waste.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

Company Name: Corning Optical Communications RF LLC

Process Flow: 37,086

General Information and type of wastewater treatment

This facility manufactures coaxial cable connectors. Pretreatment consists of hydroxide precipitation, chromium reduction, chemical oxidation, stream segregation, filtration, sedimentation, and pH neutralization. Corning-Gilbert monitors flow and pH on a daily basis.

First Quarter

Second Quarter

Third Quarter

Fourth Quarter

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Magellan Aerospace, Glendale, Inc.

Process Flow: 10,777 gpd (Average)

General Information and type of wastewater treatment	<p>Magellan Aerospace, Glendale, Inc. produces aluminum and magnesium parts by casting. Pretreatment system consists of treating chrome rinse water by reducing chrome III with SO₂, neutralizing, and filter pressing of the resulting sludge. Non chrome rinse baths are batch reduced then released. There is no discharge to the sewer from their casting quench operation. Flow and pH are monitored on a continuous basis.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

SECTION 2.2
CITY OF MESA

POTW PRETREATMENT ANNUAL REPORT

CITY OF MESA, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 91st Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020524

Person to Contact Concerning City of Mesa Information Contained in the Report:

Gene Gonzales
Industrial Pretreatment Supervisor
640 North Mesa Drive
Post Office Box 1466
Mesa, Arizona 85211
480-644-5770

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all CITY OF MESA attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

2/3/2021
Date:



Carlos Padilla
Assistant Water Director
Water Resources Department
City of Mesa, Arizona



Since its incorporation over 100 years ago, the City of Mesa has experienced tremendous growth. Today it remains primed for further growth in size, population, and employment. The history of Mesa extends back to the Hohokam Indians, the “Departed Ones,” who built the original canal system in the Valley. Mesa’s modern history began in 1877 when a group of Mormon colonists arrived in Lehi and built Fort Utah near the present-day intersection of Lehi and Horne Roads. In 1878, a second group of Mormon colonists arrived and established what modern-day Mesa became by registering the square mile bounded by the present-day Mesa Drive, Country Club, University, and Broadway Roads. In 1883, the City of Mesa was officially incorporated and had an estimated 200 residents.

Almost fifty years later, in 1930, the City’s area had expanded to approximately 2.3 square miles and the population had increased to 3,711. Mesa’s area and population increased rapidly thereafter. By 1960, Mesa’s area was over 15 square miles and the population was nearly 34,000, concentrated near the historic city center. By

1980, the City boundaries had expanded significantly, increasing the City’s area to over 66 square miles, and the population had increased to over 152,000. Over these last 30 years, Mesa has continued its rapid growth and expansion to the east. By 2020, the City’s area and population had grown to 138 square miles with an estimated 511,344 residents and 190,175 dwellings.



The Mesa Municipal Planning Area is generally bounded by the Salt River on the north, Baseline Road or Germann road on the south, the Loop 101 Freeway on the west, and Meridian Road on the east and covers approximately 172 square miles.

Mesa is a City on the move with a population approaching a half million people, Mesa boasts of many amenities that make it the city of choice for professionals, entrepreneurs, families, students, business, and industry. Continued expansion of the light rail line through the heart of Mesa. Light rail service in Mesa is expanding, adding an additional five miles to the existing line. When light rail opened, the existing station in Mesa quickly became the highest ridership station on the 20-mile light rail line.

The citizens of Mesa strongly support the current extensions and encourage continued expansion. The light rail line makes it easier for people living and working nearby to get to many great locations without needing a car. The stations in Mesa are attracting exciting new developments that is spurring additional growth and activity in the surrounding areas.

Phoenix-Mesa Gateway Airport celebrated the arrival of its 5 millionth passenger. Formerly Williams Air Force Base, this commercial airport is now one of the fastest growing airports in the country. A new passenger terminal is planned for the north side of the airport to handle the continued growth in passenger service. The Airport is also home to several companies including service centers for Embraer Aircraft, Cessna Citation, and Able Engineering.

Spring Training and Mesa Riverview. Spring training has long been a tradition in Mesa. That tradition is growing with the new facility for the Chicago Cubs and the return of the Oakland Athletics to Hohokam Stadium. These athletic facilities provide the opportunity for other community events and activities. The Cubs Park at Riverview has brought with it an exciting new Riverview Park and expansion of the entertainment, shopping, and business activities in the area.

Redevelopment of the former GM Proving Grounds. GM operated its desert proving grounds in Mesa for many years. When the decision was made to close this facility, the property was sold for redevelopment. Using options, the subsequent owners and developers are creating exciting new additions to Mesa that include a wide variety of housing options along with interconnected recreational, educational, and shopping amenities.

Dynamic growth in higher education. Mesa has been the home of Mesa Community College (the largest community college in the country), Arizona State University Poly, Northern Arizona University, a branch of Chandler-Gilbert Community College, and AT Still University for many years. In 2011 the City of Mesa began an initiative to recruit additional colleges to the community. That effort has been very successful with Benedictine University, Albright College, Westminster College, and Wilkes University being attracted to Mesa. These new colleges and universities opened for classes in 2013. In addition, Grand Canyon University has announced plans to bring a campus to Mesa to be part of the East mark development. Mesa is also home to the East Valley Institute of Technology which provides technical education and prepares students for work in a wide variety of industries.

Positive business environment brings new and expanded industries. Several new industries such as CMC Steel, Matheson Tri-gas, Crescent Crown Distributing, Bridgestone Research and Development, and Apple have recently decided to establish facilities in Mesa and others are growing and shifting more of their operations to Mesa. One of the reasons these businesses have chosen Mesa is our proven ability to respond quickly to industry needs and process development request. Another reason is the availability of the infrastructure needed to serve new industries.

As one of the busiest general aviation airports in the United States. Falcon Field is a catalyst for economic development in Northeast Mesa. Serving aviation industry employers and large-scale manufacturers. The current and significant Falcon Field employment base is expected to grow over time.

The City of Mesa provides a wide range of services to meet the needs of the citizens and businesses located in Mesa, including roadways; gas, water, and electric utilities; police; fire and medical services; courts; libraries; solid waste disposal; parks and recreation facilities; arts and

cultural programs; and transit. These services significantly improve the quality of life for residents and competitiveness for businesses.

Furthermore, they are not generally provided by the private sector, making it incumbent upon the City to ensure their safe and efficient availability. To provide these services, the City of Mesa draws upon a wide array of revenue sources and makes numerous expenditures. While most of this revenue is from local sources, such as sales taxes, utility charges, and user fees, a proportion also comes from external sources, such as intergovernmental transfers from the State of Arizona. It is critical to the economic well-being of the community that the City's revenues and expenditures are kept in balance.

The mission of the Water Resources Department is to plan, maintain, and protect the City's water supplies in the most efficient and effective manner possible to ensure superior water services to its current and future customers, to improve the quality of life for residents and visitors, and to ensure economic stability and prosperity for Mesa's businesses and industries. The Department consistently improves the efficient use and reuse of current water supplies, secures new and diverse water supplies, and enhances the protection of its water supplies. Over the past few decades the department has developed water sustainability policies that were supported by the City Councils that allowed the City to not only diversify its water resources portfolio but become increasingly drought proof.

With all these new exciting developments, we are not done. Mesa is expecting to grow by over 150,000 people over the next 30 years. This growth projection gives us the opportunity to continue to evolve and become an even better city.

CITY OF MESA POLLUTION PREVENTION PROGRAM SUMMARY

Introduction

The provisions set forth in the Arizona Pollutant Discharge Elimination System (AZPDES) Permit, requires the City of Mesa to develop and implement a Pretreatment Program. This Program shall conduct many functions as defined in the Permit and 40-CFR-403. One of the functions identified is the development and implementation of a Pollution Prevention/Source Reduction Program. The activities of the program for the period of January 1, 2020 through December 31, 2020, are briefly described below.

Commercial/Industrial Source Control Program

The City of Mesa's Industrial Pretreatment Program established a Commercial Users Program to target the facilities that are not identified as SIU's and that could introduce measurable/controllable amounts of pollutants to the collection system. Using various sources of information, facilities are identified and surveyed for pollutants of concern (POC's). The focus of the program is to reduce these pollutants of concern through educational information and on-site evaluations. These activities were developed to promote the proper maintenance of pretreatment devices and the uses of alternative process chemicals. Emphasis is placed on educating these users and encouraging their compliance through self-regulation rather than City enforcement.

The scope of the commercial program was to identify facilities that cause blockages by the discharge of grease, oils, or other viscous materials. Other pollutants of concern were researched per the results of the influent and effluent samples at the Water Reclamation Plants (WRP). The following support activities for this program were conducted during the year:

1. The Industrial Users Database continued to be updated every year identifying new and existing industrial and commercial establishments in the City of Mesa. This database is used to identify high-density industrial, commercial and rural areas for monitoring activities. During this reporting period there were 2,729 new and existing facilities in the commercial facilities database and 275 were inspected, entered and/or updated. All these facilities have the potential to discharge Pollutant of Concern (POC) to the collection system.
2. In 2017, the City of Mesa partnered with Bakers Commodities and continues to provide 4-locations around the City to better assist residents in the disposal of fryer grease. Baker's recycles cooking oil and grease into products that can be used to feed livestock, power vehicles, and act as a base for everyday items. The goal of the program is to keep the grease out of the municipal sewer system preventing costly Sanitary Sewer Overflows (SSO) and untreated sewage releases into the environment.

3. The City of Mesa continues to work with the surrounding City Governments in implementing the Arizona Fats, Oils & Grease (AZFOG) program. This program's main emphasis was focused on finding ways to reduce the amount of fats, oils, and grease building up within the infrastructure. The program is designed to educate grease haulers and restaurant personnel on proper cleaning procedures of interceptors and grease traps set forth by the local city governments. Mesa continues to work closely with surrounding cities to create a uniformed cleaning and hauling procedures.
4. The City of Mesa has modified existing hospital permits requiring pollution prevention and/or source reduction plans for used and unused pharmaceuticals. This requirement also addresses current disposal practices for controlled substances. The intent of the requirement is to reduce and/or eliminate pharmaceuticals entering the sanitary sewer system.

Educational Source Control Program

The City of Mesa Pretreatment Section continues community outreach with pharmaceutical disposal practices. Mesa's currently distributing Prescription Drug Disposal guidelines "Pain in the Drain" created through ADEQ. The flyers are distributed at the Household Hazardous Waste collection events and at Mesa's public libraries. It is the intent of the educational information to reduce the unused prescription and over the counter medication disposed in household drains.

In addition, the Industrial Pretreatment Section continues to modify the existing multifunctional brochure distributed to the food preparation establishments. This brochure was printed in English and Spanish to reach our diverse community. The information provided focuses on minimizing disposal of grease to sewer.

(New) Household Hazardous Materials Facility & Swap Shop

On October 1, 2019, The Household Hazardous Materials Facility & Swap Shop, located at 2412 N. Center St. Bldg. 2, became open to City of Mesa residents. The facility focuses on Reuse/Recovery of Materials that are typically difficult and costly to dispose. An average of 800 vehicles per month come through to drop off hazardous materials to the facility. Another great attribute to the facility is the Swap Shop which also opened on the same day. When the facility collects materials that are still usable these items are placed into the Swap Shop, which is free for City of Mesa residents to take and reuse. An average of 30% of materials collected are placed in the Swap Shop. Over 700 visitors used the Swap Shop in the first 6 months of operation.

CITY OF MESA
SUMMARY OF SIGNIFICANT CHANGES AND ANNUAL PRETREATMENT BUDGET

The Pretreatment Section continues to oversee all sampling of the industries, collection system and wastewater treatment plants. As well as reviewing and reporting the flows that are conveyed to the 91st Avenue Treatment Plant. This diversity will enable this section to foresee and validate problems in the system. This ability will assist the capacity studies that this section conducts for engineering.

Staff Attendance and Participation in Seminars, Workshops and Training

The Industrial Pretreatment staff has attended or completed the following:

Gene Gonzales – Supervisor

- Annual Hazardous Waste Refresher
- Bloodborne Pathogens
- Confined Space Training
- Safe Drinking Water Act Training
- Regulatory Compliance Permit Training

Eddie Cortinas - Inspector

- Annual Hazardous Waste Refresher
- Bloodborne Pathogens
- Confined Space Training
- AZ Water/ FOG Workshop
- Safe Drinking Water Act Training
- Regulatory Compliance Permit Training

Jim Lagrou - Inspector

- Annual Hazardous Waste Refresher
- Bloodborne Pathogens
- Confined Space Training
- AZ Water/FOG Workshop
- Safe Drinking Water Act Training
- Regulatory Compliance Permit Training

Jimmy Hollingsworth – Inspector

- Annual Hazardous Waste Refresher
- Bloodborne Pathogen
- Confined Space Training
- AZ Water/FOG Workshop
- Safe Drinking Water Act Training
- Regulatory Compliance Permit Training

CITY OF MESA

SUMMARY OF PRETREATMENT PROGRAM EXPENDITURES

January 1, 2020 – December 31, 2020 – Total Pretreatment Expenditures

PRETREATMENT PROGRAM PERSONNEL

<u>Title</u>	<u>FTEs 2019</u>	<u>FTEs 2020</u>
Regulatory Compliance Manager	0.5	0.5
Industrial Pretreatment Supervisor	1.0	1.0
Industrial Pretreatment Inspectors	4.0	3.0
Administrative Aide	0.5	0.5

PRETREATMENT PROGRAM EXPENDITURES

Personnel	220,806.00
Laboratory Services	14,900.00
Training	2,000.00
Other Services	<u>193,331.00</u>
Total	421,1037.00

PRETREATMENT EQUIPMENT INVENTORY

<u>Equipment Name</u>	<u>Purchased 2020</u>	<u>Total 2020</u>
Autosamplers	0	12
Flow Meters	0	7
pH Meters	0	4
Vehicles	0	6
Computers	2	9
Air Monitors	0	4
Cameras	0	4

CITY OF MESA
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020

	COMPANY NAME AND ADDRESS	WWTP		SIC Code		Regulation
1.	Arizona Cast Turbine ** 3110 N Oakland Mesa, Arizona 85215	91st Avenue		331512		471
2.	Infineon Technologies EPI 550 W Juanita Ave Mesa, Arizona 85210	91st Avenue		334413		469
3.	The Boeing Company ** 5000 East McDowell Road Mesa, Arizona 85215	91st Avenue		336411		433
4.	Banner Desert Medical Center 1400 S. Dobson Rd Mesa, Arizona 85202	91st Avenue		8062		City Code
5.						

** These SIU's will also be reported in the Annual Reports submitted for the Northwest Wastewater Treatment Plant Wastewater Treatment Plant on behalf of the City of Mesa per their NPDES Permits.

CITY OF MESA

PRETREATMENT PERFORMANCE SUMMARY ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST

ADDITIONS

The following Significant Industrial Users were added in 2020:

N/A

DELETIONS

The following Significant Industrial Users have ceased operations in 2020:

N/A

RECLASSIFICATIONS

The following Significant Industrial Users have been reclassified in 2020:

N/A

NAME CHANGES

The following Significant Industrial Users changed their names in 2020:

Permittee Name
Facility Address
City, State Zip

IS NOW

Permittee Name
Facility Address
City, State Zip

City of Mesa
PRETREATMENT PERFORMANCE SUMMARY
91st Avenue Wastewater Treatment Plant

I. General Information							
Control Authority Name: City of Mesa			NPDES No.: AZ0020524				
Address: P.O. Box 1466		City: Mesa		State: Arizona		ZIP: 85211-1466	
Contact Person: Gene Gonzales				Contact Telephone Number: 480-644-5770			
Reporting Period: January 1 – December 31, 2020		Categorical IUs: 3		Significant Non-Categorical IUs: 1			
II. Significant Industrial User Compliance							
		Categorical		Non-categorical		Total SIUs	
		No.	%	No.	%	No.	%
1.	No. of SIUs in Full Compliance	3	75	1	100	3	81.25
2.	No. of SIUs in Inconsistent Compliance	3	75	0	0	3	75
3.	No. of SIUs in Significant Noncompliance	0	0	0	0	0	0
4.	No. of Parameter Violations	0		0		4	
5.	No. of Reporting Violations	0		0		4	
6.	No. of Permit Condition Violations	1		0		4	
III. Compliance Monitoring Program							
		Categorical		Non-categorical		Total SIUs	
1.	No. of Control Documents Issued	1		0		4	
2.	No. of Non-Sampling Inspections Conducted	3		1		4	
3.	No. of Facilities Inspected (Non-sampling)	3		1		4	
4.	No. of Sampling Visits Conducted	48		0		4	
5.	No. of Facilities Sampled	3		1		4	
IV. Enforcement Actions							
		Categorical		Non-categorical		Total SIUs	
1.	Notices of Violations Issued to SIUs	0		0		4	
2.	Temporary Increase in IU Self Monitoring	0		0		4	
3.	Administrative Orders Issued to SIUs	1		0		4	
4.	Compliance Schedules Issued	1		0		4	
5.	Settlement Agreements	1		0		4	
6.	Other Actions	0		0		0	
7.	Amount of Penalties Collected (Total Dollars / IUs Assessed)	\$ 9288.00 / 1		\$ 0.00 / 0		\$ 0.00 / 0	

**CITY OF MESA
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Arizona Cast Turbine		REPORT 01/01/2020 through PERIOD: 12/31/2020		
SERVICE ADDRESS: 3110 N Oakland, Mesa, Arizona 85215		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 464.36	LIMITS APPENDIX: U	BMR SUBMITTED: N/A	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 01/31/2017	PERMIT EXPIRES: 01/30/2022	
SAMPLING LOCATION VERIFIED ON: (001 & 002) 12/16/2020		RCRA NOTICE: N/A		
SLUG CONTROL PLAN EVALUATION DATE: 12/16/2020				
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	4	4	4	4
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	3/31/20	6/30/20	9/30/20	12/31/20

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona Cast Turbine
 Process Flow: 200 GPD

General Information and type of wastewater treatment	
<p>Manufactures a variety of metal parts for gas turbine engines and other applications using the lost wax precision investment casting process. Replicas of the parts are made in wax by injection into complex metal tooling. The wax replicas are then assembled into "clusters" or "trees" containing one or more parts. The wax trees are coated with ceramic, the wax is melted out, and the resulting hollow ceramic vessel is fired and filled with molten metal of the desired composition. After cooling, the cast metal parts are separated from the trees and subjected to various mechanical finishing processes (turning, milling, brazing, sandblasting, grinding, etc.) to produce the desired finished part. Arizona Cast Turbine is regulated under Title 40-CFR-464.36 and Mesa City Code.</p>	
First Quarter	
<p>On 2/11/20, the City of Mesa conducted 4 days of compliance sampling at Outfall 002</p>	
Second Quarter	
<p>On 5/6/20, the City of Mesa conducted 4 days of compliance sampling at outfall 002. On 6/15/20, the IU submitted the June PRC with no deficiencies.</p>	
Third Quarter	
<p>On 9/23/20, the City of Mesa conducted 4 days of compliance sampling at outfall 002.</p>	
Fourth Quarter	
<p>On 12/16/2020, the City of Mesa conducted an Announced Annual Compliance Inspection. On 10/17/20, the City of Mesa conducted 4 days of compliance sampling at outfall 002. On 12/15/20, the IU submitted the December PRC with no deficiencies.</p>	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF MESA
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Banner Desert Medical Center		REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE 1400 South Dobson Road ADDRESS: Mesa, AZ 85202		MAILING ADDRESS: Same	
CATEGORICAL USER: No	40 CFR	LIMITS APPENDIX:	BMR SUBMITTED: N/A
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 02/12/2020	PERMIT EXPIRES: 02/11/2025
SAMPLING LOCATIONS VERIFIED ON: (001) 01/22/2020		RCRA NOTICE: 11/1987	
SLUG CONTROL PLAN EVALUATION DATE: 09/16/2020			

	1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 – Dec 31)
Number of Inspections	1	0	0	0
Number of City Sampling Days	0	0	0	0
Number of IU Sampling Days	1	0	0	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	09/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date Of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter

	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 – Dec 31)
Enforcement Status	M	M	M	M

Enforcement Status Codes

A - Notice of Violation (NOV)
B - Administrative Order (AO)
C - Civil Action Filed
D - Criminal Action Filed
E - Settlement Agreement

F - Assessment of Monetary Penalties
G - Restriction of Flow
H - Permit Revocation
I - Compliance Schedule
J - Disconnection from Sewer

K - Published in Newspaper as Significant Violator in Prior Reporting Year
L - Automatic Increase in IU Self-Monitoring
M - No Enforcement Action

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Banner Desert Medical Center

Process Flow: 408,716 GPD

General Information and Type of Wastewater Treatment	<p>This is a full-service hospital with 649 licensed beds, operating 24 hours a day, seven days per week. The hospital has approximately 3400 employees. This hospital performs three main specialties: Women's/children's services, medical/surgical services, and emergency services. Discharges occur during all hours of operation ranging from general hospital discharges, cooling tower, boiler, chiller discharges, and kitchen wastewater discharges after it has been treated by a Grease Removal Device (GRD).</p>
First Quarter	<p>On January 22, 2020, the City of Mesa performed an announced Pre-Permit / Annual Compliance Inspection.</p>
Second Quarter	<p>On June 10, 2020, the IU submitted their June 2020 PRC with no deficiencies.</p>
Third Quarter	<p>On September 16, 2020, the IU submitted a Pollution Prevention (P2) Plan, and an updated Slug Load Control Plan (SLCP).</p>
Fourth Quarter	<p>On December 8, 2020, the IU submitted their December 2020 PRC with no deficiencies.</p>

To be published for this year in newspaper as a significant violator? Yes No

Penalties this reporting year: Assessed \$ 0.00 / Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Infineon Technologies EPI

Process Flow: 115,000 GPD

General Information and type of wastewater treatment	
<p>This facility is a custom manufacturer of silicone and/or germanium epitaxy, using vapor deposition on silicon or sapphire substrates. The deposition of an epitaxial silicon layer upon a substrate is a semiconductor manufacturing operation regulated under Title 40-CFR-469(A)(469.18). All categorical process wastewater transferred to the pretreatment system. Pretreatment consists of a three-stage pH neutralization system. Discharges from this system are continuously monitored for flow and pH (Outfall 001). Controls on the system are designed to cease discharges if pH parameters are exceeded. TTO compliance is achieved by not using or storing any regulated TTO's on-site. All non-process and pretreated wastewater discharge to Outfall 002.</p>	
First Quarter	
Second Quarter	
<p>On 4/30/20, the IU payed an administrative fee of 9,288.00. On 5/29/20, the City performed an Annual Compliance Inspection. On 6/22/20, The City of Mesa conducted 2 days of compliance sampling. On 6/15/20, the IU submitted the June PRC with no deficiencies.</p>	
Third Quarter	
Fourth Quarter	
<p>On 10/15/2020, the City of Mesa issued the IU an updated Administrative Order (AO) #2020-001, for a Permit condition violation. On 10/26/2020, the City of Mesa conducted 2-days of compliance sampling. On 12/15/20, the IU submitted the December PRC with no deficiencies.</p>	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$9,288.00 Collected \$9,288.00

**CITY OF MESA
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: The Boeing Company		REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE 5000 East McDowell Road ADDRESS: Mesa, Arizona 85215		MAILING ADDRESS: Same	
CATEGORICAL USER: Yes	40 CFR – 433.17	LIMITS APPENDIX: A & E	BMR SUBMITTED: 05/28/1991
TTO CERTIFICATION DATE SUBMITTED: 12/17/2018		PERMIT EFFECTIVE: 02/02/2016	PERMIT EXPIRES: 02/01/2021
SAMPLING LOCATIONS VERIFIED ON: (001), 10/09/18 (002), 01/24/18 (003) 03/02/18		RCRA NOTICE: 11/1987	
SLUG CONTROL PLAN EVALUATION DATE: 11/25/2020			

	1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 – Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	8	5	7	6
Number of IU Sampling Days				
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2019	06/30/2019	09/30/2019	12/31/2019

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quar-ter	Type of Violation	Date Of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter

	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 – Dec 31)
Enforcement Status	M	M	M	M

Enforcement Status Codes

- | | | |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"> A - Notice of Violation (NOV) B - Administrative Order (AO) C - Civil Action Filed D - Criminal Action Filed E - Settlement Agreement | <ul style="list-style-type: none"> F - Assessment of Monetary Penalties G - Restriction of Flow H - Permit Revocation I - Compliance Schedule J - Disconnection from Sewer | <ul style="list-style-type: none"> K - Published in Newspaper as Significant Violator in Prior Reporting Year L - Automatic Increase in IU Self-Monitoring M - No Enforcement Action |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: The Boeing Company

Process Flow: 7,500 GPD

General Information and Type of Wastewater Treatment	
<p>Assembles military helicopters and ordinance delivery systems for military applications. Activities conducted on-site consist of assembly, painting, flight testing, and research/development. Major components of the helicopters (e.g., airframes, engines, transmissions, etc.) are manufactured off-site and delivered to The Boeing Company for assembly. Several operations are conducted on-site that are regulated by Title 40-CFR-433. Processes include anodizing, chem-filming, coating, painting, abrasive jet machining, burnishing and the washing of aircraft and aircraft parts. The total process flow regulated by Title 40-CFR-433 averages 7,500 gallons per day.</p>	
First Quarter	
<p>City performed compliance monitoring at Outfall 002 on these dates: February 5, 14,21,27. City performed compliance monitoring at Outfall 003 on these dates: January 10, February 4, 27, March 17.</p>	
Second Quarter	
<p>City performed compliance monitoring at Outfall 002 on these dates: April 30, May 13, 28, June 9. City performed compliance monitoring at Outfall 003 on these dates: April 28, May 13, June 9.</p> <p>IU submitted June 2020 PRC with no deficiencies.</p>	
Third Quarter	
<p>City performed compliance monitoring at Outfall 002 on these dates: July 16, September 2, 10, 24. City performed compliance monitoring at Outfall 003 on these dates: July 15, August 7, September 1.</p>	
Fourth Quarter	
<p>City performed compliance monitoring at Outfall 001 on these dates: November 13. City performed compliance monitoring at Outfall 002 on these dates: October 20, November 4, 12, December 4. City performed compliance monitoring at Outfall 003 on these dates: October 20, November 12, December 4, 15.</p> <p>City conducted Pre-Permit Inspection / Annual Compliance Inspection on December 4, 2020.</p>	

To be published for this year in newspaper as a significant violator? Yes No

Penalties this reporting year: Assessed \$ 0.00 / Collected \$ 0.00

SECTION 2.3
CITY OF PHOENIX

POTW PRETREATMENT ANNUAL REPORT

CITY OF PHOENIX, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 23rd Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020559

Person to Contact Concerning City of Phoenix Information Contained in the Report:

Jesse Flores, Principal Engineering Technician
Industrial Pretreatment Program
2474 South 22nd Avenue, Building 31
Phoenix, Arizona 85009
602-495-5926

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all CITY OF PHOENIX attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Date: _____


Eric Froberg
Interim Water Services Department Director
City of Phoenix, Arizona

POTW PRETREATMENT ANNUAL REPORT

CITY OF PHOENIX, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 91st Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020524

Person to Contact Concerning City of Phoenix Information Contained in the Report:

Jesse Flores, Principal Engineering Technician
Industrial Pretreatment Program
2474 South 22nd Avenue, Building 31
Phoenix, Arizona 85009
602-495-5926

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all CITY OF PHOENIX attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Date: _____



Eric Froberg
Interim Water Services Department Director
City of Phoenix, Arizona



General

Phoenix was incorporated as a city in 1881. Geographically, Phoenix covers more than 500 square miles and it is actually larger than Los Angeles. Phoenix is Arizona's state capital and the 5th largest city in the United States. When people refer to Phoenix, they are often discussing the Greater Phoenix area, which includes more than 25 cities and towns. Over the past two decades Phoenix has been one of the fastest growing cities in the country, and with its size and growth it has developed into a major city.



The population of Phoenix is estimated to be 1.7 million. U.S. Census estimates the median age of a Phoenician is about 33 years old. Only 10.6% of the people in Phoenix are over the age of 65, and 56% are between the ages of 25 and 59. Almost 28% of the residents of Phoenix have at least one 4-year college degree. The median household income in Phoenix is about \$52,080. About 18% of families are living at or below poverty level in the City of Phoenix.

Phoenix is located in the Sonoran Desert, which is one of the wettest and greenest deserts in North America, thanks to 3-15 inches of annual rainfall. According to data compiled by the National Climatic Data Center, Phoenix basks in sunshine more often than any other major metropolitan area in the U.S. Phoenix experiences sunny days 85 percent of the time.

Phoenix Major Industries

The major portion of the economic base of Phoenix is made up of the following industries: aerospace and defense, technology and innovation, renewable energy, bioscience and health care, optics/photonics, advanced manufacturing, advanced business services, construction, tourism and service.

Phoenix Water

The City of Phoenix Water Services Department is more than 100 years old and treats and distributes tap water to 1.7 million customers daily. Phoenix Water manages the city's sewer system, and handles wastewater treatment operations for 4.5 million residents in five Valley cities. Infrastructure includes approximately 7,026 miles of water lines, 4,945 miles of sewer lines, eight treatment plants, 54,803 fire hydrants and 98,506 manholes. Phoenix's water and sewer rates are among the lowest of comparable-sized cities nationwide. Our tap water supply is in very good shape due to decades of planning and multiple water sources. The city reuses nearly all of its wastewater on crops, wetlands, and energy production.

Pretreatment Program Changes

The City of Phoenix Industrial Pretreatment Program (Program) submitted non-substantial program modifications including revisions to the Sewer Use Ordinance and Enforcement Response Plan on December 12, 2019 to ADEQ. Approval of the modifications was granted on July 24, 2020 and the revised Sewer Use Ordinance, Chapter 28 “Sewers” of Phoenix City Code, and Enforcement Response Plan became effective October 7, 2020.

Due to the public health and safety concerns related to the Covid-19 pandemic, and in order to maintain compliance with EPA regulations, the Program established guidelines for conducting virtual inspections at specified IU facilities with higher risk of exposure to Covid-19 in October 2020. IU facilities classified under specific high-risk types were eligible for virtual inspections given that appropriate steps could be adequately performed, and the IU facility had the appropriate software available to assist in the virtual inspection process. When conducting inspections at lower risk IU facilities, staff scheduled and performed announced inspections in-person with proper safety protocol.

Pretreatment Program Activities

The Environmental Services Division within the Water Services Department is responsible for implementing the Program for the City of Phoenix. The Program continues to be organized into three sections: Wastewater Monitoring, Commercial Inspections/FOG, and Industrial Pretreatment. An organizational chart is included in this report and appears on a page just after the Summary of Pretreatment Program Expenditures.

▪ **Wastewater Monitoring Section**

The Wastewater Monitoring Section collects wastewater, groundwater, and biosolids samples to support the following:

- NPDES and AZPDES Permit compliance for the City of Phoenix wastewater treatment plants
- Aquifer Protection Permit compliance for the City of Phoenix wastewater treatment plants and recharge facilities
- Industrial user permit compliance determination and enforcement
- Industrial user sewer rate recalculation (sewer billings)
- SROG Cities’ sewer charges and compliance determination
- Special projects, studies, and emergency response.

Sampling crews frequently conduct sampling operations in hazardous locations such as confined spaces, streets where traffic conditions must be considered, and in the Salt and Gila Rivers. Sophisticated, computerized sampling and measuring equipment in addition to manual sample collection techniques are used to collect samples, which are then analyzed by the City’s Water Services Laboratory.

▪ **Commercial Inspections / FOG Section**

The Commercial Inspections / Fats, Oils and Grease (FOG) Section inspects and enforces the City’s sewer use ordinance at commercial/industrial facilities to support the following:

- Routine/educational inspections of pretreatment devices and systems to prevent POTW infrastructure damages; obstructions; Sanitary Sewer Overflows (SSOs); and WWTP upset, interference, and passthrough
- Complaint inspections
- Routine/educational stormwater inspections (in support of the City stormwater program)
- Construction inspections of pretreatment devices and compliance sampling points
- Investigation of potential illegal discharges
- Investigation of SSOs and sewer blockages

- FOG Pollution Prevention (P2) outreach to domestic users following SSOs in residential areas
- Issuance of Temporary Discharge/Manhole Entry Permits
- Referral of industries for permitting evaluation to the Industrial Pretreatment Section
- Implementation of the Dental Rule (Dental Office Point Source Category – 40 CFR Part 441).

Additionally, the section is responsible for examination of new and remodel commercial construction plans to determine the need for wastewater pretreatment and/or wastewater discharge permitting. A database is used by staff to systematically target geographic areas for preventative inspections, as well as to track pretreatment devices and enforcement history for a given facility.

Commercial Inspections / FOG Section Metrics

Routine/Educational Inspections	495
Construction Inspections	104
SSO Investigations - Residential Areas (includes apartments)	21
SSO Investigations - Commercial/Industrial Areas	10
Routine/Educational Stormwater Inspections	403
Notices of Violation	0
Plans Reviewed for Pretreatment	878
Number of Dental Discharger Forms Distributed	145

▪ ***Industrial Pretreatment Section***

The Industrial Pretreatment Section is responsible for the following:

- Inspections of permitted industrial users and potential permittees
- Routine/educational stormwater inspections (in support of the City stormwater program)
- Examination of industrial user construction plans with regard to industrial processes, pretreatment systems, and compliance sampling points
- Issuance of Wastewater Discharge Permits
- Evaluation of permitted industrial user compliance and file management
- Records retention
- Enforcement of permitted industrial users
- Periodic recalculation of industrial user sewer rates based on flow and loading
- Periodic revision of sewer use ordinances, standard operating procedures (SOPs), Civil Penalty Policy, and Enforcement Response Plan
- Pollution Prevention (P2) outreach to industrial and residential users
- Publication of industrial user escalated enforcement actions to enable public participation
- Annual publication of Significantly Noncompliant industrial users
- Coordination and writing of the Annual Report on behalf of the SROG cities.

Pollution Prevention Program

Section F.4.e. of the National Pollutant Discharge Elimination System (NPDES) Permit № AZ0020524 and AZPDES Permit № AZ0020559 requires the City of Phoenix (City) to develop and implement, through its Industrial Pretreatment Program (Program), a Pollution Prevention (P2) Program for controllable sources of pollutants within the service area of the 23rd and 91st Avenue Wastewater Treatment Plants (WWTPs). In accordance with the City's "Implementation of Best Management Practices in the Service Area of the 23rd and 91st Avenue WWTPs Project Schedule", as revised on March 22, 1996, the City's efforts for the period January 1, 2020 through December 31, 2020 are summarized below.

▪ **General Community Outreach / Education**

IPP Staff participated in the following Community Outreach Events:

Due to the Covid-19 pandemic throughout 2020, Industrial Pretreatment and Commercial Inspections / FOG Sections were unable to participate in the typically scheduled community outreach events.

Community Outreach Events			
Event	Organizer	Dates	Attendees
N/A	N/A	N/A	N/A

▪ **Industrial Pretreatment Compliance Academy**

The Industrial Pretreatment Section continues to deliver the Industrial Pretreatment Compliance Academy it developed in 1995 to support a P2 education/outreach program directed at industrial and commercial facilities located in Phoenix. The Compliance Academy classes include a PowerPoint presentation, a reference handbook, and a laboratory tour. The presentation and handbook includes P2 information and demonstrates ideas to specific industry sectors including metal finishers, hospitals, industrial laundries, etc. During 2020 all but one course was presented in a virtual webinar format with a .pdf booklet and class participation and materials were used for the following:

Industrial Outreach Events: Industrial Pretreatment Compliance Academy			
Class Name	Place & Date	Attendee Types	№ of Attendees
Wastewater Discharge Permit	Water Services Building January 29, 2020	<ul style="list-style-type: none"> ▪ Permitted Industrial Users ▪ Pretreatment Staff from other Municipalities ▪ Staff from Arizona Department of Environmental Quality ▪ Staff from Border Environment Cooperation Commission 	50
Wastewater Compliance Sampling	Online - WebEx March 25, 2020		25
Laboratory Analytical Issues	Online - WebEx May 27, 2020		34
Enforcement	Online – Microsoft Teams July 22, 2020		39
Pollution Prevention (P2)	Online – WebEx September 23, 2020		33
Stormwater Compliance Overview	Online – WebEx November 19, 2020		36

▪ **Water Cooler (Employee Newsletter)**

The Industrial Pretreatment Section and Commercial Inspections / FOG Section regularly contribute articles to the Water Cooler employee newsletter throughout the year in order to provide information on a variety of P2 topics. Specific topics and months include:

- Flushable Wipes – April & June 2020
- Virtual Compliance Academy – July 2020
- “Cease the Grease” – August 2020
- “Toilets Are Not Trash Cans” – September 2020
- Dental Amalgam Rule – November 2020

▪ **Illegal Oil / Solvent Disposal Outreach**

The Commercial Inspections / FOG Section coordinated efforts to investigate illegal oil / solvent disposal including development of a flyer, social media posts, and billboard advertisement. Specific outreach efforts include:

- Illegal Dumping (Twitter and Facebook) – August 25, 2020
- Illegal Dumping (Twitter and Facebook) – August 29, 2020
- Illegal Dumping (Twitter) – November 18, 2020
- Billboard (35th Avenue & Lower Buckeye, 27th Avenue & Broadway) – August 31, 2020 - Present

▪ **Point Source Control**

- The Industrial Pretreatment Section actively identifies, by SIC code, those businesses located in Phoenix that were likely to use the pollutants so that onsite inspections and wastestream sampling could be conducted to determine (1) whether or not they actually used the pollutants; (2) whether or not the pollutants are actually discharged to the WWTPs and at what levels and (3) the feasibility and benefit of implementing BMPs at businesses which discharge measurable levels of pollutants of concern. Meetings with the industrial groups and annual site inspections continue to reinforce BMP practices.
- Best Management Practices (BMPs) continue to be implemented on four pollutants. These pollutants are Fluoride, Molybdenum, Selenium, and DEHP. On January 1, 2005, the SROG cities adopted and implemented revised local limits. During the local limits review process, these four pollutants were identified as candidates for BMPs. The City determined the target industries which discharge these pollutants and identified opportunities for their reduction through the control document (Permit), inspections, and the IPP Compliance Academy.
- Class B Wastewater Discharge Permits continue to be issued for special dischargers and zero categorical wastewater dischargers. Industrial users performing manufacturing or service processes from one of the federal point source categories, but discharging zero wastewater generated from those processes are issued Class B Zero Categorical Wastewater Discharge Permits. Industrial users that do not meet the definition of an SIU, but discharge high strength BOD/TSS wastewater, remediated groundwater, or pollutants of concern (conventional pollutants) are issued Class B Wastewater Discharge Permits. As a result of Chapter 28 “Sewers” updates and program changes, including adoption of all mandatory and several optional 2005 Pretreatment Streamlining Rules, a new Class C Wastewater Discharge Permit type was created to replace the Class B Zero Categorical Wastewater Discharge Permit. This permit type will be issued beginning in 2021 to industrial users who meet the definition of a non-significant categorical industrial user. Through the end of 2020, the Industrial Pretreatment Section inspected 71 Class B Permittees.

CLASS B ZERO CATEGORICAL WASTEWATER DISCHARGE PERMITTEES		
FACILITY NAME	FACILITY ADDRESS	FACILITY TYPE
Aero Spring & Manufacturing Co., Inc.	3335 East Wier Avenue	Metal Finishing PSNS
American Aerospace Technical Castings, Inc.	2950 West Catalina Drive	Iron and Steel Manufacturing
American Tube and Pipe	2528 North 27th Avenue	Metal Finishing PSES
Asphalt Terminals, LLC.	1935 West McDowell Road	Paving and Roofing Materials PSNS
Bergmann Precision, Inc. - Bergmann Group	3730 East Southern Avenue	Metal Finishing PSNS
Bernie's Brass, Inc. – DBA M3 Metals	2326 East Magnolia Street	Metals Finishing PSNS
CMR Manufacturing, Inc.	2421 East Jackson Street	Metal Finishing PSNS

CLASS B ZERO CATEGORICAL WASTEWATER DISCHARGE PERMITTEES		
FACILITY NAME	FACILITY ADDRESS	FACILITY TYPE
Coating Technologies, Inc	21438 North 7th Avenue	Metal Finishing
Collins Metal Finishing	3536 East Illini Street	Metal Finishing PSNS
Contact Coatings, LLC	1930 West Quail Avenue, Suite B	Metal Finishing PSNS
Controlled Thermal Technology, Inc.	2617 West Cypress Street	Metal Finishing
D & R Home Decor LLC	2204 East Magnolia Street	Metal Finishing
Diversified Metals, Inc.	9849 North 19th Drive, Suite 2	Metal Finishing
Dolphin, Inc.	440 North 51 st Avenue	Metal Molding and Casting PSNS
Environmental Management Utility Services, LLC.	2132 South 5th Avenue	Centralized Waste Treatment Subpart B Oils PSNS
Gannon & Scott Phoenix, Inc.	2113 East Sky Harbor Circle South	Centralized Waste Treatment Subpart A Metals PSNS
GE Parallel Design, Inc.	4313 East Cotton Center Boulevard	Electrical and Electronic Components PSNS
Honeywell International Inc. – Honeywell Aerospace – Deer Valley	21111 North 19 th Avenue	Electrical and Electronic Components PSNS
ICP Construction, Inc.	4565 West Watkins Street	Paint Formulating PSNS
Intrepid Coatings, Inc.	1910 East Riverview Drive	Paint Formulating PSNS
Jet Processing	2660 West Quail Avenue	Metal Finishing
L.B.O. Plating	2008 West Jackson Street	Metal Finishing PSNS
Lighting Resources, LLC.	1522 East Victory Street, Suite 4	Centralized Waste Treatment PSNS
Lighting Resources, LLC.	1545 East Victory Street	Centralized Waste Treatment PSNS
Novanta Corp dba Cambridge Technology - Lincoln Polygon Products	234 East Mohave Street	Metal Finishing PSNS
Ohlinger Industries, Inc.	1211 West Melinda Lane	Metal Finishing PSNS
Osborn Products, Inc.	1127 West Melinda Way	Metal Finishing
Perma-Finish, Inc.	74 North 45th Avenue	Metal Finishing PSNS
Phoenix Heat Treating, Inc.	2405 West Mohave Street	Metal Finishing PSNS
Phoenix Metalcraft, Inc.	3845 North 29th Avenue	Metal Finishing
Phoenix Tool & Gage, Inc.	2612 West Encanto Boulevard	Metal Finishing
Precise Metal Products Company	4534 North 44th Avenue	Metal Finishing PSNS
Precision Industrial Painting, Inc.	1139 West Hilton Avenue	Metal Finishing
Precision Science	1517 West Knudsen Drive	Pesticide Chemicals PSNS
Profile Precision Extrusion	6565 West Grant Street	Aluminum Forming
Purcell Tire Company	420 South 35th Avenue	Rubber Manufacturing PSNS
R.B. Machine Company, Inc.	3729 West Buchanan Street	Metal Finishing
Razor Emporium	210 South 37 th Street	Metal Finishing PSNS
RLC Labs, Inc.	1850 East Riverview Drive	Pharmaceutical Manufacturing PSNS
Royal Sign Company, Inc.	2631 North 31st Avenue	Metal Finishing
Southwest Powder Coating, Inc.	116 North 59th Avenue	Metal Finishing PSNS
STP Performance Coating, LLC	1131 West Watkins Street	Metal Finishing PSNS
Strand Industries	1202 West Watkins Street	Metal Finishing PSNS
Sun West Engineering, Inc.	3802 West Broadway Road	Metal Finishing
Thermo Fluids, Inc.	4301 West Jefferson Street	Centralized Waste Treatment
Total Seal Piston Rings, Inc.	22642 North 15th Avenue	Metal Finishing PSNS

CLASS B ZERO CATEGORICAL WASTEWATER DISCHARGE PERMITTEES		
FACILITY NAME	FACILITY ADDRESS	FACILITY TYPE
Trainor & Trainor, Inc. - Arizona Hard Chrome, Inc.	2609 West Cypress Street	Metal Finishing
Troy Corporation Arizona	113 South 47th Avenue	Pesticide Chemicals PSNS
Veolia ES Technical Solutions, LLC	5736 West Jefferson Street	Centralized Waste Treatment
Verco Decking, Inc.	4340 North 42nd Avenue	Coil Coating-Canmaking PSES
Xpress Stripping, LLC dba Xpress Metal Cleaning	3402 East Wier Avenue	Metal Finishing PSNS
CLASS B WASTEWATER DISCHARGE PERMITTEES		
FACILITY NAME	FACILITY ADDRESS	FACILITY TYPE
American Beverage Corporation	2426 South 7 th Street	Beverage Manufacturing
Automated Chemical Solutions, Inc.	3320 East Roeser Road	Soap and Detergent Manufacturer
Bimbo Bakeries USA, Inc.	738 West Van Buren Street	Food Manufacturing
Elite Waste Services	2412 West Sherman Avenue	Hauled Waste or Septage
Freshly, Inc.	610 South 56 th Avenue	Food Manufacturing
Kinder Morgan SFPP, L.P. Phoenix Terminal	49 North 53rd Avenue	Fuel Tank Storage
La Canasta Mexican Food Products, Inc.	3101 West Jackson Street	Food Manufacturing
Leclerc Foods Nutrition Arizona, LLC	440 South 51st Avenue	Food Manufacturing
Mama Lola's, LLC.	3348 East Wier Avenue	Food Manufacturing
National Construction Rentals	2131 West Roosevelt Street	Hauled Waste or Septage
NXP USA, Inc. 52nd ST Superfund Site - OU 2	12 South 20th Street- Phoenix	Groundwater Remediation
Southwest Orthopedic and Spine Hospital, LLC. – OASIS Hospital	750 North 40 th Street	Surgical Hospital
Strictly From Scratch	800 North 17 th Avenue	Food Manufacturing
Swissport Fueling Services	4200 East Airline Drive	Fuel Storage/Hauled Waste or Septage
Swissport Fueling, Inc.	Sky Harbor International Airport 3737 East Bonanza Way	Hauled Waste or Septage
Waste Management Phoenix Hauling South	1580 East Elwood Street	Hauled Waste or Septage

Training and Participation in Conferences and Workshops

▪ **Individual Training:**

WSD/ESD Staff continue to enhance professional growth by enrolling in courses from various educational and training resources. To broaden their education, some inspectors take self-study courses through American Water College and obtain certifications through ADEQ. Operator Certifications include Water Distribution, Water Treatment, Wastewater Collection, and Wastewater Treatment.

▪ **Group Training:**

On July 13-24, 2020, IPP staff attended the AZ Water Association's 93rd Annual Conference & Exhibition hosted virtually via a platform utilizing pre-recorded technical sessions available through October 31, 2020, as well as live presentations streamed the week of July 20, 2020. The Conference

& Exhibition offers a multiple day program designed to provide professional development, continuing education, and technology transfer to support the AZ Water Association's vision of "a vibrant Arizona through safe, reliable water". The event attracts several thousand attendees from throughout the nation. Staff learned about a variety of topics during the Conference & Exhibition including: fats, oils and grease processing and biofuel, wastewater collections, water reuse, wastewater treatment, water resources, conservation, energy, and more.

On November 17, 2020, IPP and Commercial Inspections staff coordinated, organized and attended the AZ Water Association Fall Pretreatment Webinar held virtually via Microsoft Teams and hosted by the Pretreatment Committee. This workshop informs, educates, and trains water and wastewater professional technicians, regulatory inspectors, managers, policymakers, and others on the latest developments in wastewater pretreatment and FOG program management. This specific workshop discussed industrial wastewater sampling, general permits and the streamlining rules, and included a roundtable discussion with input on the dental amalgam rule, Sewer Use Ordinance updates, Enforcement Response Plan updates, and Covid-19 impacts.

On December 9, 2020, IPP staff attended the EPA National Enforcement Training Institute's Flow Measurement webinar. The webinar covered some of the basics of how flow is typically measured at an NPDES discharge point including situations applicable to industrial dischargers. The webinar provided guidance on how various open and closed channel flow measurement devices function, how they are calibrated, and their respective applications as well as an onsite demonstration/inspection.

On December 14-17, 2020, IPP staff attended the EPA Region 10 Pretreatment 101 Training Webinar. The introductory-level training to the National Pretreatment Program included an overview and history of the national pretreatment regulations, reviewed pretreatment standards and local limits, detailed industrial user inventories and permitting, and other relevant topics.

Other Activities

▪ *Coordination with Other Pretreatment Programs*

Phoenix continued to provide counsel and guidance to the Pretreatment Programs of the contributing jurisdictions and Programs throughout the state during 2020. Multi-city coordination for purposes of encouraging compliance with federal requirements and consistency of implementation was accomplished through periodic multi-city meetings attended by representatives from each Program, as well as through periodic meetings with individual Program staff.

Phoenix personnel along with members from the other SROG cities continue the monthly sampling program at all 14 Metering Stations, with only a short-term delay during the start of the Covid-19 pandemic. This sampling program provides representative information about the quality of wastewater discharged to the 91st Avenue WWTP. '

▪ *Enforcement Activities to Involve and Inform the Public*

In addition to publication of Industrial Users having a status of Significant Noncompliance during the reporting year, the City used several types of legal instruments designed to bring industrial users back into compliance. The City continued to conduct Show Cause Meetings and to collect monetary penalties from industrial users which violated pretreatment requirements during the year. A summary of these enforcement activities which identify the permittees, the nature of the violations, published Pretreatment Settlement Agreements, and any monetary penalties associated with those actions follows on the next page.

- ***NEFAP Accreditation***

The City of Phoenix Environmental Services Division achieved ISO/IEC 17025:2005 International Standard and the Field Sampling and Measurement Organizations (FSMO) Accreditation. The Certificate of Accreditation includes demonstration of technical competence in the fields defined by the Divisions scope of sampling and field tests. The Water and Wastewater Monitoring groups are one of eleven having this accreditation in the United States and the only accredited entities in Arizona.

**City of Phoenix
2020 Published Pretreatment Enforcement Actions**

Industrial User Name	SNC?	40 CFR	Violations	Show Cause Proceeding Date	Penalty Collected	Newspaper Publication Fee	PSA/CD
1 Signetix, Inc. 2611 South 7 th Street, Suite 101 Phoenix, Arizona 85034-6503	Yes	433.17	SNC – Reporting; reporting	01/14/2020	\$3,184.00	\$319.44	151917--0
2 Helligear Acquisition Co. dba Northstar Aerospace – Phoenix 401 South 36 th Street Phoenix, Arizona 85034-2812	Yes	433.17	SNC – MAV Nickel; reporting; zinc effluent	01/24/2020	\$6,135.00	\$326.70	151882--0
3 Phoenix Indian Medical Center 4212 North 16 th Street Phoenix, Arizona 85016-5319	Yes	Local Limits	SNC – Daily Mercury	02/03/2020	\$0.00	\$341.22	151972--0
4 Elite Waste Services, Inc. 2412 West Sherman Street Phoenix, Arizona 85043-5817	Yes	Local Limits	SNC – Reporting; zinc and pH effluent; reporting	02/19/2020	\$4,437.34	\$326.70	151973--0
5 AmeriPride Services, Inc. 6025 West Van Buren Street Phoenix, Arizona 85034-3509	No	Local Limits	pH effluent; reporting	05/14/2020	\$595.00	\$319.44	152755--0
6 Prudential Overall Supply 5102 West Roosevelt Street Phoenix, Arizona 85043-2716	Yes	Local Limits	SNC – Reporting	07/14/2020	\$4,550.00	\$326.70	152981--0
7 ChemResearch Co., Inc. 1101 West Hilton Avenue Phoenix, Arizona 85007-4305	Yes	433.17	SNC – Reporting	08/12/2020	\$525.00	\$319.44	153390--0
8 4RB Disposal, LLC. 2245 West Shangri La Road Phoenix, Arizona 85029-4813	Yes	Local Limits	SNC – Daily Copper, Zinc, Cadmium	10/07/2020	\$16,693.50	\$326.70	153418--0
9 Bimbo Bakeries USA, Inc. 738 West Van Buren Street Phoenix, Arizona 85007-2546	No	Local Limits	Copper effluent; reporting	11/18/2020	\$1,479.00	\$326.70	153718--0
2020 TOTAL					\$37,598.84		

CITY OF PHOENIX


SUMMARY OF PRETREATMENT PROGRAM EXPENDITURES		
January 1, 2020 – December 31, 2020 – Total Pretreatment Expenditures \$ 3,759,125		
PRETREATMENT PROGRAM EXPENDITURES		
Personnel	\$	2,341,833
Operations & Maintenance	\$	270,310
Laboratory	\$	868,657
Equipment	\$	7,858
Vehicles	\$	270,467
PRETREATMENT PROGRAM EQUIPMENT INVENTORY		
<u>Equipment Name</u>	<u>Purchased 2020</u>	<u>Total 2020</u>
Photo Ionization Detector	1	2
Flow Meters	0	24
Auto Samplers	2	28
Turbidimeters	3	3
pH/DO/Conductivity Meters	0	5
Chlorine Colorimeters	0	3
Air Movers	0	4
Confined Space Harnesses	0	9
Air/Gas Detectors	2	9
Cameras	0	9
Night Vision Cameras	0	1
Pole Cameras/GoPro	0	5
CCTV Sewer Camera	0	2
Computer Monitors	12	30
Computers	5	27
Printers	0	3
Tablets	7	13
PRETREATMENT PROGRAM VEHICLE INVENTORY		
<u>Equipment Name</u>	<u>Purchased 2020</u>	<u>Total 2020</u>
Sampling Passenger Vans	0	1
Sampling 4WD Pickups	0	1
Inspector Pickups	2 ¹	7
Sampling Vans	2 ¹	5
Vehicle Pool Sedans	0	4 (Pool) ²
¹ New vehicles purchased but not yet received, will replace older vehicles, they are not additional.		
² Vehicle pool sedans which are used for inspections of industrial facilities are shared by all staff located on the 23rd Avenue WWTP.		

PRETREATMENT PROGRAM PERSONNEL

<u>Title</u>	<u>FTEs 2019</u>	<u>FTEs 2020</u>
Deputy Water Services Director	1.0 ³	1.0 ³
Environmental Programs Coordinator	0.5 ³	0.5 ³
Assistant City Attorney IV	0.25 ³	0.25 ³
Mechanical Plans Examiner I	1	1
Environmental Quality Specialist	0.5	0.5
Chief Water Quality Inspectors	3	3
Senior Water Quality Inspectors	6	16
Water Quality Inspectors	2	6.0
Inspector Vacancies	1.0	1.0
Information Technology Application Programmer III	0.25 ³	0.25 ³
Information Technology Application Programmer I	0.5 ³	0.5 ³
Secretary II	0.25 ³	0.25 ³

³ These positions dedicate time to other Water Department functions.

CITY OF PHOENIX PRETREATMENT PROGRAM ORGANIZATION CHART



**CITY OF PHOENIX
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
1.	4RB Disposal, LLC. 2245 West Shangri La Road Phoenix, Arizona 85029-4813	23 rd Avenue	4953	City Code
2.	AAA Ajax Pumping Service, Inc. 2433 South 7th Avenue Phoenix, Arizona 85007-4302	91st Avenue	4953	City Code
3.	Abrazo Central Campus 2000 West Bethany Home Road Phoenix, Arizona 85015	23rd Avenue	8062	City Code
4.	Abrazo Scottsdale Campus 3929 East Bell Road Phoenix, Arizona 85032-2112	91st Avenue	8062	City Code
5.	Allied Tube & Conduit Corporation 2525 North 27th Avenue Phoenix, Arizona 85009-1710	23rd Avenue	3317	433.17
6.	AlSCO, Inc. 4707 West Camelback Road Phoenix, Arizona 85031	91st Avenue	7218	City Code
7.	Ameripride Services Inc. 6025 West Van Buren Street Phoenix, Arizona 85043-3509	91st Avenue	7213	City Code
8.	Angelica 4410 West Mohave Avenue Phoenix, Arizona 85043-8304	91st Avenue	7218	City Code
9.	APS BioGroup, Inc. 2235 South Central Avenue Phoenix, Arizona 85004-2909	91st Avenue	7218	439.47
10.	APS West Phoenix Power Plant 4606 West Hadley Street Phoenix, Arizona 85043-3933	91st Avenue	4911	423.16
11.	Aramark Uniform and Career Apparel, Inc. 3836 West Buckeye Road # F Phoenix, Arizona 85009	91st Avenue	7218	City Code
12.	Arizona Foods Group 2517 East Chambers Street Phoenix, Arizona 85040-3640	91st Avenue	3674	City Code
13.	Arizona Precision Sheet Metal, Inc. 2140 West Pinnacle Peak Road Phoenix, Arizona 85027-1200	91st Avenue	3444	433.17
14.	ASM America Inc.-University Drive Plant 3440 East University Drive Phoenix, Arizona 85034-7200	91st Avenue	3674	469.18
15.	Avanti Circuits, Inc. 17650 North 25th Avenue - Suite #5 Phoenix, Arizona 85023	91st Avenue	3672	433.17
16.	Baker Commodities, Inc. 3602 West Elwood Street Phoenix, Arizona 85009	91st Avenue	2077	City Code
17.	Banner Estrella Medical Center 9201 West Thomas Road Phoenix, Arizona 85035	91st Avenue	8062	City Code
18.	Banner Health – Banner University Medical Center Phoenix Campus 1111 East McDowell Road Phoenix, Arizona 85006-2612	23rd Avenue	8062	City Code

**CITY OF PHOENIX
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
19.	Barrel O' Fun Snack Foods Co. Southwest, LLC. 7330 West Sherman Street Phoenix, Arizona 85043-4751	91st Avenue	2096	City Code
20.	Benchmark Electronics, Inc. 3201 East Harbour Drive Phoenix, Arizona 85034-7227	91st Avenue	3679, 3672	433.17
21.	Bottling Group, LLC. – The Pepsi Beverages Company 4242 East Raymond Street Phoenix, Arizona 85040-1935	91st Avenue	2086	City Code
22.	Café Valley, Inc. 7000 West Buckeye Road Phoenix, Arizona 85043-4306	91st Avenue	2050	City Code
23.	Carl T. Hayden Medical Center 650 East Indian School Road Phoenix, Arizona 85012-1892	23rd Avenue	8062	City Code
24.	Cassavant Assembly & Processing, LLC. 3725 East Atlanta Avenue Phoenix, Arizona 85040-2960	91st Avenue	3471	433.17
25.	Celgene Corporation 620 North 51 st Avenue Phoenix, Arizona 85043-2702	91st Avenue	2834	439.47
26.	Certified Inspection Service Company, Inc. 21 South 41 st Street Phoenix, Arizona 85034	23rd Avenue	3479	433.17
27.	ChemResearch Co., Inc. 1130 West Hilton Avenue Phoenix, Arizona 85007-4306	23rd Avenue	3471	433.17
28.	Chromalloy Arizona 5161 West Polk Street Phoenix, Arizona 85043	91st Avenue	7699	433.17
29.	Cintas Corporation 5501 West Hadley Street Phoenix, Arizona 85043	91st Avenue	7218	City Code
30.	Cintas -Roosevelt St 4804 West Roosevelt Street Phoenix, Arizona 85043	91st Avenue	7218	City Code
31.	CleanPart Southwest LLC 3844 East University Drive Phoenix, Arizona 85034-7221	91st Avenue	3479	433.17
32.	Crothall Laundry Services Inc.- The Commercial Linen Exchange 4445 South 36 th Street Phoenix, Arizona 85040	91st Avenue	7213	City Code
33.	Dignity Health –St. Joseph's Hospital & Medical Center 350 West Thomas Road Phoenix, Arizona 85013-4409	23rd Avenue	8062	City Code
34.	District Photo, Inc. 2500 East Chamber Street Phoenix, Arizona 85040-3639	91st Avenue	7384	City Code
35.	DS Services of America, Inc. 3302 West Earll Drive Phoenix, Arizona 85017	91st Avenue	2086	City Code
36.	Dunn-Edwards Corporation 520 South 67 th Avenue Phoenix, Arizona 85043-4432	91st Avenue	2851	City Code

**CITY OF PHOENIX
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
37.	Entrepix, Inc. 4717 East Hilton Avenue Phoenix, Arizona 85034-6404	91st Avenue	3674	469.18
38.	FlipChip International, LLC 3701 East University Drive Phoenix, Arizona 85034	91st Avenue	3674	469.18
39.	FM Industries, Inc. Building "D" 2104 West Roosevelt Street Phoenix, Arizona 85009-3703	23rd Avenue	3471	433.17
40.	Frontier Group 3518 East Wood Street Phoenix, Arizona 85040	91st Avenue	3471	433.17
41.	Global Healing Center 925 East Salter Drive Phoenix, Arizona 85024-5648	91st Avenue	2833	439.47
42.	Gregory Packaging, Inc. 439 South 55th Avenue Phoenix, Arizona 85043-4621	91st Avenue	2033	City Code
43.	Hadrian Inc. 3602 West Washington Street Phoenix, Arizona 85009-4767	91st Avenue	3471	433.17
44.	Heligear Acquisition Co. dba Northstar Aerospace – Phoenix 401 South 36th Street Phoenix, Arizona 85034-2812	23rd Avenue	3599	433.17
45.	Heligear Acquisition Co.- Northstar Aerospace (Phoenix) 300 South 23 rd Street Phoenix, Arizona 85034-2500	23rd Avenue	3599	433.17
46.	Holsum Bakery, Inc. 2322 West Lincoln Street Phoenix, Arizona 85009	23rd Avenue	2051	City Code
47.	Honeywell International Inc. Former Peoria Avenue Facility/EW-1 2305 West Mercer Lane Phoenix, Arizona 85051	91st Avenue	9999	City Code
48.	Honeywell International, Inc. Former Peoria Avenue Facility/MW-10 2251 West Sierra Street Phoenix, Arizona 85029	91st Avenue	9999	City Code
49.	Honeywell International, Inc. Honeywell Aerospace – Phoenix R&O 1944 East Sky Harbor Circle Northwest Phoenix, Arizona 85034-3442	23rd Avenue	3728	433.17
50.	Honeywell International, Inc. Honeywell Engines Product Center 111 South 34 th Street Phoenix, Arizona 85034-2802	23rd Avenue	3471	433.17
51.	HonorHealth Deer Valley Medical Center 19829 North 27 th Avenue Phoenix, Arizona 85027-4001	91st Avenue	8062	City Code
52.	HonorHealth John C. Lincoln Hospital North Mountain 250 East Dunlap Avenue Phoenix, Arizona 85020-2825	23rd Avenue	8062	City Code

**CITY OF PHOENIX
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
53.	Honor Health Sonoran Crossing Medical Center 33400 North 32 nd Avenue Phoenix, Arizona 85085-8876	91 st Avenue	8062	City Code
54.	Hydro Extrusions North America, LLC - Plant 1 Extrusion Operation (Sapa) 249 South 51 st Avenue Phoenix Arizona 85043-3715	91 st Avenue	3354	467.35
55.	Hydro Extrusions North America, LLC - Plant 2 Extrusion Operation (Sapa) 50 South 49 th Avenue Phoenix Arizona 85043-3825	91 st Avenue	3354	467.35
56.	Hydro Extrusions North America, LLC - Remelt Operation (Sapa) 249 South 51 st Avenue Phoenix Arizona 85043-3715	91 st Avenue	3354	467.35
57.	Liquid Environmental Solutions of Arizona, LLC 5159 West Van Buren Street Phoenix, Arizona 85043	91 st Avenue	4953	437.47
58.	Liquid Environmental Solutions of Arizona LLC - Magnolia Street 1095 West Magnolia Street Phoenix, Arizona 85007-4508	23 rd & 91 st Avenue	4953	City Code
59.	Marlyn Nutraceuticals - Naturally Vitamins 4404 East Elwood Street Phoenix, Arizona 85040	91 st Avenue	2834	439.47
60.	Mastel Linen, Inc. 2940 West Virginia Ave Phoenix, Arizona 85009-1607	23 rd Avenue	7218	City Code
61.	Mayo Clinic Arizona – Mayo Clinic Hospital 5777 East Mayo Boulevard Phoenix, Arizona 85054-4502	91 st Avenue	8062	City Code
62.	Mega Metals, LLC. 1325 North 22nd Avenue Phoenix, Arizona 85009-3714	23 rd Avenue	5093	421 .306(m)
63.	Metco Metal Finishing, LLC 3508 East Corona Avenue Phoenix, Arizona 85040-2842	91 st Avenue	3471	433.17
64.	Mission Linen Supply, Inc. 2652 South 16 th Street Phoenix, Arizona 85034	23 rd & 91 st Avenue	7213	City Code
65.	Mistras Arizona Inspection Services, Inc. 3027 East Washington Street Phoenix, Arizona 85034-1517	23 rd Avenue	3764	433.17
66.	Modern Industries, Inc. 4755 East Beautiful Lane Phoenix, Arizona 85044	91 st Avenue	3471	433.17
67.	MPP Group of Companies 230 South 49th Avenue Phoenix, Arizona 85043-3905	91 st Avenue	3471	433.17
68.	Niagara Bottling, LLC. 275 South 67 th Avenue Phoenix, Arizona 85043-3427	91 st Avenue	2086	City Code
69.	NXP USA, Inc. 52nd ST Superfund Site OU 1 5005 East McDowell Road Phoenix, Arizona 85008	91 st Avenue	9999	City Code

**CITY OF PHOENIX
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
70.	Phoenix Children's Hospital 1919 East Thomas Road Phoenix, Arizona 85016	23rd Avenue	8062	City Code
71.	Phoenix Indian Medical Center 4212 North 16 th Street Phoenix, Arizona 85016-5319	23rd Avenue	8062	City Code
72.	Phoenix Manufacturing, Inc. 3655 East Roeser Road Phoenix, Arizona 85040-3968	91st Avenue	3585	433.15
73.	PMA Photometals of Arizona, Inc. dba PMA Industries of Arizona, Inc. 18008 North Black Canyon Highway Phoenix, Arizona 85053-1715	91 st Avenue	3479	433.17
74.	Prudential Overall Supply 5102 West Roosevelt Street Phoenix, Arizona 85043	91st Avenue	7218	City Code
75.	Quantum Global Technologies, LLC 2101 West Roosevelt Street Phoenix, Arizona 85009	23rd Avenue	7699	433.17
76.	Quantum Global Technologies, LLC dba Quantum Clean 3925 East Watkins Street, Suite 100 Phoenix, Arizona 85034	91st Avenue	3479	433.17
77.	Rexam Beverage Can Company 211 North 51 st Avenue Phoenix, Arizona 85043-3704	91st Avenue	3411	465.45
78.	Safeway Phoenix Ice Cream Plant 2434 East Pecan Road Phoenix, Arizona 85040	91st Avenue	3674	City Code
79.	Sagamore Camelback, LLC. 1 East Camelback Road Phoenix, Arizona 85012-1668	23 rd Avenue	9999	City Code
80.	Sav-On Plating, Inc. 17 West Watkins Street Phoenix, Arizona 85003-2824	23rd Avenue	3471	433.17
81.	Shamrock Foods Company – Dairy Division 2228 North Black Canyon Highway Phoenix, Arizona 85009-2707	23rd Avenue	2026	City Code
82.	Signetix, Inc. 2611 South 7 th Street, Suite 101 Phoenix, Arizona 85034-6523	91st Avenue	5093	433.17
83.	Sky Chefs-Inc. – LSG Sky Chefs 3555 South 28 th Street Phoenix, Arizona 85040-8603	91st Avenue	5812	City Code
84.	Specialty Textile Services 720 West Buchanan Street Phoenix, Arizona 85007-3405	23rd Avenue	7218	City Code
85.	StandardAero Aviation Holdings Inc. (PAS Technologies) 1021 North 22 nd Avenue Phoenix, Arizona 85009-3717	23rd Avenue	3471	433.17
86.	SUMCO Southwest Corporation 19801 North Tatum Boulevard Phoenix, Arizona 85050-4201	91st Avenue	3674	469.28
87.	Sumitomo Chemical Advanced Technologies, LLC. 3832 East Watkins Street Phoenix, Arizona 85034	91st Avenue	3674	469.18

**CITY OF PHOENIX
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
88.	The Proctor & Gamble Company 2050 South 35 th Avenue Phoenix, Arizona 85009	91st Avenue	2834	439.46
89.	UniFirst Corporation 104 North 14 th Street Phoenix, Arizona 85034-1114	23rd Avenue	7218	City Code
90.	Upper Crust Bakery 3655 West Washington Street Phoenix, Arizona 85009-4759	91 st Avenue	2051	City Code
91.	Valleywise Health Behavioral Center – Maryvale Campus 5102 West Campbell Avenue Phoenix, Arizona 85031-1703	91 st Avenue	8062	City Code
92.	Valleywise Health Medical Center 2601 East Roosevelt Street Phoenix, Arizona 85008-4973	23rd Avenue	8062	City Code
93.	Vital Pharmaceuticals, Inc. dba Bang Energy 1635 South 43 rd Avenue Phoenix, Arizona 85009-6026	91 st Avenue	2086	City Code
94.	World Resources Company 8113 West Sherman Street Phoenix, Arizona 85353-4025	91st Avenue	3399	City Code

CITY OF PHOENIX

PRETREATMENT PERFORMANCE SUMMARY ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST

ADDITIONS

The following Significant Industrial Users were added in 2020:

4RB Disposal, LLC.
2245 West Shangri La Road
Phoenix, Arizona 85029-4813

PMA Photometals of Arizona, Inc. dba
PMA Industries of Arizona, Inc.
18008 North Black Canyon Highway
Phoenix, Arizona 85053-1715

Vital Pharmaceuticals, Inc. dba Bang Energy
1635 South 43rd Avenue
Phoenix, Arizona 85009-6026

Valleywise Health Behavioral Center – Maryvale Campus
5102 West Campbell Avenue
Phoenix, Arizona 85031-1703

HonorHealth Sonoran Crossing Medical Center
33400 North 32nd Avenue
Phoenix, Arizona 85085-8876

DELETIONS

The following Significant Industrial Users have ceased operations in 2020:

N/A

RECLASSIFICATIONS

**The following Significant Industrial Users have been reclassified in 2020:
RECLASSIFIED TO**

Southwest Orthopedic and Spine Hospital, LLC. -
OASIS Hospital
750 North 40th Street
Phoenix, Arizona 85008-6486

Reclassified to Class B
Discharge IU from Class A SIU

CITY OF PHOENIX

PRETREATMENT PERFORMANCE SUMMARY ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST

NAME CHANGES

The following Significant Industrial Users changed their names in 2020:

Maricopa Integrated Health System 2601 East Roosevelt Street Phoenix, Arizona 85008-4973	IS NOW	Valleywise Health Medical Center 2601 East Roosevelt Street Phoenix, Arizona 85008-4973
PAS Technologies, Inc. 1021 North 22 nd Avenue Phoenix, Arizona 85009-3717	IS NOW	StandardAero Aviation Holdings Inc. 1021 North 22 nd Avenue Phoenix, Arizona 85009-3717
Shearer's Foods, LLC. – Barrel O' Fun Snack Foods Southwest 7330 West Sherman Street Phoenix, Arizona 85043-4751	IS NOW	Barrel O' Fun Snack Foods Co. Southwest, LLC. 7330 West Sherman Street Phoenix, Arizona 85043-4751

City of Phoenix
PRETREATMENT PERFORMANCE SUMMARY
23rd Avenue Wastewater Treatment Plant

I. General Information						
Control Authority Name: City of Phoenix			NPDES No: AZ0020559			
Address: 2474 South 22 nd Avenue		City: Phoenix		State: Arizona		ZIP: 85009
Contact Person: Jesse Flores				Contact Telephone Number: (602) 534-7588		
Reporting Period: January 1 – December 31, 2020			Categorical IUs: 13		Significant Non-Categorical IUs: 17	
II. Significant Industrial User Compliance						
	Categorical		Non-categorical		Total SIUs	
	No	%	No	%	No	%
1. No. of SIUs in Full Compliance	9	69	8	47	17	57
2. No. of SIUs in Inconsistent Compliance	3	23	7	41	10	33
3. No. of SIUs in Significant Noncompliance	1	8	2	12	3	10
4. No. of Parameter Violations	4		25		29	
5. No. of Reporting Violations	2		4		6	
6. No. of Permit Condition Violations	1		4		5	
III. Compliance Monitoring Program						
	Categorical		Non-categorical		Total SIUs	
1. No. of Control Documents Issued	13		17		30	
2. No. of Nonsampling Inspections Conducted	15		21		36	
3. No. of Facilities Inspected (Nonsampling)	13		17		30	
4. No. of Sampling Visits Conducted	84		153		237	
5. No. of Facilities Sampled	13		17		30	
IV. Enforcement Actions						
	Categorical		Non-categorical		Total SIUs	
1. Notices of Violations Issued to SIUs	6		17		23	
2. Temporary Increase in IU Self Monitoring	1		3		4	
3. Administrative Orders Issued to SIUs	0		0		0	
4. Compliance Schedules Issued	0		1		1	
5. Settlement Agreements	2		2		4	
6. Other Actions	0		0		0	
7. Amount of Penalties Collected (Total Dollars / IUs Assessed)	\$ 6,600 / \$6,660		\$16,693.50 / \$16,693.50		\$23,353.50 / \$23,353.50	

City of Phoenix
PRETREATMENT PERFORMANCE SUMMARY
91st Avenue Wastewater Treatment Plant

I. General Information						
Control Authority Name: City of Phoenix				NPDES No.: AZ0020524		
Address: 2474 South 22 nd Avenue		City: Phoenix		State: Arizona		ZIP: 85009
Contact Person: Jesse Flores				Contact Telephone Number: (602) 534-7588		
Reporting Period: January 1 – December 31, 2020			Categorical IUs: 46		Significant Non-Categorical IUs: 49	
II. Significant Industrial User Compliance						
	Categorical		Non-categorical		Total SIUs	
	No	%	No	%	No	%
1. No. of SIUs in Full Compliance	33	72	27	55	60	63
2. No. of SIUs in Inconsistent Compliance	10	22	20	41	30	32
3. No. of SIUs in Significant Noncompliance	3	7	2	4	5	5
4. No. of Parameter Violations	17		36		53	
5. No. of Reporting Violations	6		17		23	
6. No. of Permit Condition Violations	3		11		14	
III. Compliance Monitoring Program						
	Categorical		Non-categorical		Total SIUs	
1. No. of Control Documents Issued	46		49		95	
2. No. of Nonsampling Inspections Conducted	52		57		109	
3. No. of Facilities Inspected (Nonsampling)	46		48		94	
4. No. of Sampling Visits Conducted	310		412		722	
5. No. of Facilities Sampled	46		49		95	
IV. Enforcement Actions						
	Categorical		Non-categorical		Total SIUs	
1. Notices of Violations Issued to SIUs	26		42		68	
2. Temporary Increase in IU Self Monitoring	7		7		14	
3. Administrative Orders Issued to SIUs	0		0		0	
4. Compliance Schedules Issued	2		2		4	
5. Settlement Agreements	4		5		9	
6. Other Actions	0		0		0	
7. Amount of Penalties Collected (Total Dollars / IUs Assessed)	\$16,240 / \$16,240		\$88,811.82 / \$88,811.82		\$105,051.82 / \$105,051.82	

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: 4RB Disposal, LLC.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2245 West Shangri La Road Phoenix, Arizona 85029-4813		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 08/13/2018	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 02/01/2020	PERMIT EXPIRES: 01/31/2025	
SAMPLING LOCATION VERIFIED ON: 03/06/2020		RCRA NOTICE: 01/10/2020		
SLUG CONTROL PLAN EVALUATION DATE: 03/06/2020		COMPLIANCE SAMPLING POINT No: 32346.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	2	0	0	0
Number of City Sampling Days	0	3	0	0
Number of IU Sampling Days	2	8	3	0
Number of Parameter Violations	2	15	4	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	1	0
Number of Permit Cond. Violations	1	0	0	0
Compliance Status	I	S	I	C
Evaluated as of:	06/01/2020	08/13/2020	11/25/2020	02/12/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Effluent	03/18/2020	Composite	City	IU	Copper	8.66/1.5 mg/L	2
1 st	Effluent	03/18/2020	Composite	City	IU	Zinc	13.3/3.5 mg/L	2
1 st	Permit Condition	03/31/2020	N/A	N/A	N/A	Failure to Sample O&G		
2 nd	Effluent	04/17/2020	Composite	City	IU	Copper	4.9/1.5 mg/L	8
2 nd	Effluent	04/17/2020	Composite	City	IU	Zinc	7.7/3.5 mg/L	8
2 nd	Effluent	05/20/2020	Composite	City	IU	Copper	4.9/1.5 mg/L	8
2 nd	Effluent	05/20/2020	Composite	City	IU	Zinc	7.0/3.5 mg/L	8
2 nd	Effluent	05/28/2020	Composite	City	City	Copper	6.73/1.5 mg/L	8
2 nd	Effluent	05/28/2020	Composite	City	City	Zinc	7.71/3.5 mg/L	8
2 nd	Effluent	06/22/2020	Composite	City	IU	Copper	3.8/1.5 mg/L	8
2 nd	Effluent	06/22/2020	Composite	City	IU	Zinc	32/3.5 mg/L	8
2 nd	Effluent	06/23/2020	Composite	City	IU	Copper	23/1.5 mg/L	8
2 nd	Effluent	06/23/2020	Composite	City	IU	Zinc	35/3.5 mg/L	8
2 nd	Effluent	06/25/2020	Composite	City	IU	Copper	120/1.5 mg/L	8
2 nd	Effluent	06/25/2020	Composite	City	IU	Zinc	77/3.5 mg/L	8
2 nd	Effluent	06/25/2020	Composite	City	IU	Cadmium	0.063/0.047 mg/L	2
2 nd	Effluent	06/29/2020	Composite	City	IU	Copper	5.2/1.5 mg/L	8
2 nd	Effluent	06/29/2020	Composite	City	IU	Zinc	14/3.5 mg/L	8
3 rd	Effluent	07/08/2020	Composite	City	IU	Copper	13/1.5 mg/L	3
3 rd	Effluent	07/08/2020	Composite	City	IU	Zinc	49/3.5 mg/L	3
3 rd	Reporting	07/01/2020	N/A	N/A	N/A	NOV Response		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A (3), L	A (4)	E, F		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: 4RB Disposal, LLC.

Process Flow: 10,094 GPD (Average)

General Information and type of wastewater treatment	<p>4RB Disposal, LLC. (Paradise Septic is a branch of the company) is a newly permitted septic pumping company that pumps out and services residential and commercial septic tanks. The facility discharges liquid waste from septic tank pumping through its filtration process involving roll-off tanks and a catch basin for solids removal. The facility has an approved screening standard operating procedure (SOP) that details the type of waste that will be discharged, inspection and screening of waste (odor, oil & grease, color, floating materials) including pH strips, documentation of source and quantities.</p>
First Quarter	<p>Class A Wastewater Discharge Permit N^o 2002-32346 was issued on January 10, 2020 to 4RB Disposal, LLC. The Permit went into effect on February 1, 2020 and expires on January 31, 2025.</p>
Second Quarter	<p>On 05/29/2020, a Notice of Concern was issued for a late 24-Hour notification of copper and zinc effluent violations which occurred on 03/18/2020. The 24-hour notification was due on 03/27/2020 and received on 04/23/2020, 27 days late. An NOV, 30-day resample, and TISM for the copper and zinc effluent violations was issued on 06/01/2020. All requirements of the NOC and NOV were met.</p> <p>On 05/29/2020, a Notice of Concern was issued for a late 24-Hour notification of copper and zinc effluent violations which occurred on 04/17/2020. The 24-hour notification was due on 04/25/2020 and received on 05/18/2020, 23 days late. An NOV and 30-day resample for the copper and zinc effluent violations was issued on 06/01/2020. All requirements of the NOC and NOV were met.</p> <p>On 06/12/2020, an NOV was issued for IU failure to sample for oil & grease during the first quarter of 2020. All requirements of the NOV were met.</p>
Third Quarter	<p>On 07/06/2020 the City received a NOV response due on 06/30/2020 for the failure to sample NOV issued 06/12/2020. An NOV for late reporting NOV response was issued on 07/14/2020. All requirements on the NOV were met.</p> <p>On 06/01/2020 the City became aware of violations of the daily maximum limits for copper and zinc which occurred on 05/20/2020; analytical results were received 05/31/2020. An NOV and TISM were issued on 07/15/2020. The IU has met all requirements.</p> <p>On 06/17/2020 the City became aware of violations of the daily maximum limits for copper and zinc which occurred on 05/28/2020 during City monitoring. An NOV was issued on 07/28/2020; further sampling was not required because 4RB ceased discharge effective 07/23/2020. The IU has met all requirements.</p> <p>On 07/10/2020, 07/22/2020, 07/30/2020, and 08/17/2020, the City became aware of violations of the daily maximum limits for cadmium, copper, and zinc which occurred on 06/22/2020, 06/23/2020, 06/25/2020, 06/29/2020, 07/08/2020, and 07/16/2020. An NOV was issued on 08/21/2020; further sampling was not required because 4RB ceased discharge effective 07/23/2020. The IU has met all requirements.</p> <p>On 08/03/2020 the IU was notified of 2nd Quarter Significant Non-Compliance with regards to daily maximum chronic and technical review criteria for copper and zinc, as well as daily maximum technical review criteria for cadmium.</p> <p>On 09/03/2020 a Notice to Show Cause was issued as a result of multiple parameter violations occurring within a 90-day period and several late reporting violations in a 180-day period. On 10/07/2020 a Show Cause Proceeding was held to discuss violations occurring during the enforcement period 02/01/2020 through 08/01/2020.</p>
Fourth Quarter	<p>A Pretreatment Settlement Agreement was reached on 11/30/2020 which included monetary penalties of \$16,693.50 and a compliance schedule. All monetary penalties were collected in 2020 and requirements of the compliance schedule are in the process of being met.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 16,693.50 Collected \$ 16,693.50

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: AAA Ajax Pumping Service, Inc.			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 2433 South 7 th Avenue, Phoenix, Arizona 85007-4302		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 12/07/1998	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 10/01/2018	PERMIT EXPIRES: 09/30/2023	
SAMPLING LOCATION VERIFIED ON: 09/24/2020		RCRA NOTICE: 12/07/1998		
SLUG CONTROL PLAN EVALUATION DATE: 09/24/2020		COMPLIANCE SAMPLING POINT No: 5405.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	0	3	1	0
Number of IU Sampling Days	6	6	6	6
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/07/2020	07/23/2020	10/23/2020	1/18/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- A - Notice of Violation (NOV)
- B - Administrative Order (AO)
- C - Civil Action Filed
- D - Criminal Action Filed
- E - Pretreatment Settlement Agreement (PSA)
- F - Assessment of Monetary Penalties
- G - Restriction of Flow
- H - Permit Revocation
- I - Compliance Schedule Issued
- J - Disconnection from Sewer
- K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year
- L - Temporary Increase in IU Self-Monitoring (TISM)
- N- No Enforcement Action

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: AAA Ajax Pumping Service, Inc.

Process Flow: 24,756 GPD (Average)

General Information and type of wastewater treatment	<p>This facility accepts and de-watered septage, grease trap waste, and other wastewaters approved by the City of Phoenix. Treatment consists of a grinder pump, gravity settling, polymer dosing system, sludge dewatering tank, and solids extruder. The dewatering tank discharges to a centrifugal rotary fan for additional dewatering.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Abrazo Central Campus (Phoenix Baptist Hospital)		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2000 West Bethany Home Road Phoenix, Arizona 85015-2443		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 12/28/1990	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 07/01/2017		PERMIT EXPIRES: 06/30/2022	
SAMPLING LOCATION VERIFIED ON: 12/15/2020		RCRA NOTICE: 12/28/1990		
SLUG CONTROL PLAN EVALUATION DATE: 12/15/2020		COMPLIANCE SAMPLING POINT No: 2680.04, 2680.05		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	3	0	4
Number of IU Sampling Days	2	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	2
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	S
Evaluated as of:	04/16/2020	07/08/2020	12/18/2020	01/14/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
4 th	Reporting	10/29/2020	N/A	N/A	N/A	Late SMR		
4 th	Reporting	11/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	A(2)		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Abrazo Central Campus (Phoenix Baptist Hospital)

Process Flow: 68,870 (GPD) Average

General Information and type of wastewater treatment	<p>This facility is a 216-bed hospital that provides cardiovascular care, orthopedics, women's services, radiology, 24-hour emergency services, outpatient surgery, laboratories and on-site food services. The major sources of discharge are from patient rooms, cafeteria, surgical suites, and laboratories. The pretreatment system consists of a 25/50 grease trap for a 3 compartment sink in the kitchen and a 15/30 grease trap for a drain in the tallow bin area. Waste oils, acids and caustics, waste laboratory chemicals and biohazard wastes are collected in containment drums and shipped off site by a contractor for proper disposal.</p>
First Quarter	<p>On 03/25/2020, an NOC was issued as a reminder to comply with authorized signatory requirements.</p>
Second Quarter	<p>On 08/07/2020, an NOC was issued for submitting a late self-monitoring report which was due on 06/28/2020. The SMR was received on 07/27/2020; 29 days late. An NOC was issued in lieu of an NOV due to internal staff adjustments made in response to Covid-19.</p>
Third Quarter	
Fourth Quarter	<p>On 12/21/2020, the IU was notified of 4th Quarter Significant Non-Compliance for submitting a report 45 days or more past the due date; a self-monitoring report was 49 days late.</p> <p>On 12/23/2020, an NOV was issued for submitting a late self-monitoring report which was due on 10/28/2020. The SMR was received on 12/18/2020, 49 days late. All requirements of the NOV were met.</p> <p>On 12/23/2020, an NOV was issued for submitting a late self-monitoring report which was due on 11/28/2020. The SMR was received on 12/18/2020, 20 days late. All requirements of the NOV were met.</p>

To be published for this year in newspaper for Significant Non-Compliance? X Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Abrazo Scottsdale Campus			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE: 3929 East Bell Road		MAILING ADDRESS: Same		
ADDRESS: Phoenix Arizona 85032-2112				
CATEGORICAL USER?	No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: N/A
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 02/01/2017		PERMIT EXPIRES: 01/31/2022
SAMPLING LOCATION VERIFIED ON: 12/22/2020		RCRA NOTICE: 12/28/2002		
SLUG CONTROL PLAN EVALUATION DATE: 12/22/2020		COMPLIANCE SAMPLING POINT №: 20565.02		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	4	0	0	4
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	04/24/2020	07/21/2020	10/13/2020	01/21/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Reporting	03/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Abrazo Scottsdale Campus

Process Flow: 18,188 (GPD) Average

General Information and type of wastewater treatment	<p>Abrazo Scottsdale Campus is a full-service hospital featuring an Accredited Chest Pain Center, Da Vinci Robotic Surgery, Diagnostic Imaging, Emergency Services, Heart Care, Orthopedics, Outpatient Rehab, Pain Management, Rehabilitation Services, Stroke and Vascular Care, Surgical Services, Surgical Weight Loss, Urology, Wound Care and Women's Health.</p> <p>Pretreatment consists of a 3,000-gallon three compartment grease interceptor for the kitchen and implementation of BMPs in key areas of the hospital.</p>
First Quarter	
Second Quarter	<p>On 04/13/2020, an NOV was issued for submitting a late self-monitoring report which was due on 03/28/2020. The SMR was received on 04/02/2020; 5 days late. All requirements of the NOV were met.</p> <p>On 05/12/2020, an NOC was issued for submitting a late NOV response letter which was due 04/22/2020. The NOV response letter was received on 05/04/2020; 12 days late. An NOC was issued in lieu of an NOV due to internal staff adjustments as a result of Covid-19.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Allied Tube & Conduit Corporation		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2525 North 27th Avenue Phoenix Arizona 85009-1710		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 420.106	LIMITS APPENDIX: C	BMR SUBMITTED: 06/25/2003	
TTO CERTIFICATION DATE SUBMITTED: 1/21/2021		PERMIT EFFECTIVE: 02/01/2017	PERMIT EXPIRES: 01/31/2022	
SAMPLING LOCATION VERIFIED ON: 01/16/2020		RCRA NOTICE: 10/24/2003		
SLUG CONTROL PLAN EVALUATION DATE: 01/16/2020		COMPLIANCE SAMPLING POINT No: 5378.02		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	1	0	0	0
Number of City Sampling Days	0	1	1	0
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	06/26/2020	08/25/2020	11/17/2020	02/09/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV)
B - Administrative Order (AO)
C - Civil Action Filed
D - Criminal Action Filed
E - Pretreatment Settlement Agreement (PSA) | F - Assessment of Monetary Penalties
G - Restriction of Flow
H - Permit Revocation
I - Compliance Schedule Issued
J - Disconnection from Sewer | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year
L - Temporary Increase in IU Self-Monitoring (TISM)
N - No Enforcement Action |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Allied Tube & Conduit Corporation

Process Flow: 1,047 (GPD) Average

General Information and type of wastewater treatment	<p>Allied Tube & Conduit Corporation (Allied Tube) manufactures mechanical tubing, fire sprinkler pipe, electrical conduit, as well as struts, piping and tubing used in construction and other industries. The products may be galvanized or uncoated. The pretreatment system consists of a series of tanks (or stages) wherein chemicals are added to the wastewater to cause precipitation, flocculation, coagulation, clarification, and pH adjustment. After pH adjustment, the wastewater is routed through a filter press to capture solids, then to the final holding tank before discharge to the sanitary sewer system via the compliance sampling point. Allied Tube is permitted under the 40 CFR 420 Iron and Steel Category.</p> <p>The pretreatment protocol is to perform quality in-house assurance tests of the pretreatment system at two points upstream of the compliance sampling point. Allied Tube operates a batch-discharge-system which, in conjunction with the two-point quality assurance protocol performed on each batch, minimizes the probability of an exceedance.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: AlSCO, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 4707 West Camelback Road Phoenix, Arizona 85031		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 11/29/2010	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 05/01/2016	PERMIT EXPIRES: 04/30/2021	
SAMPLING LOCATION VERIFIED ON: 10/06/2020		RCRA NOTICE: 12/10/2010		
SLUG CONTROL PLAN EVALUATION DATE: 10/06/2020		COMPLIANCE SAMPLING POINT No: 27301.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	3	2	0	4
Number of IU Sampling Days	3	3	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	3
Number of Permit Cond. Violations	0	1	0	0
Compliance Status	C	I	C	I
Evaluated as of:	05/07/2020	09/30/2020	12/11/2020	1/28/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Permit Condition Reporting	06/30/2020	N/A	N/A	N/A	Failure to Sample pH Late SMR Late NOV Response Late Sample Results		
4 th		11/29/2020	N/A	N/A	N/A			
4 th		12/12/2020	N/A	N/A	N/A			
4 th		12/17/2020	N/A	N/A	N/A			
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A	N	N	A		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: AlSCO, Inc.
 Process Flow: 84,000 GPD (Average)

General Information and type of wastewater treatment	<p>This facility is an industrial laundry service provider without any dry cleaning operations. Wastewater treatment consists of stream segregation, screening, pH neutralization, physical separation, and sedimentation.</p>
First Quarter	<p>On January 2, 2020, an NOV was issued for Late Reporting due to the failure to sample NOV response being received on December 27, 2019 when it was due on December 20, 2019, 7 days late. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	<p>On November 18, 2020, an NOV was issued for IU failure to sample for pH during the month of June 2020. All requirements of the NOV were met.</p> <p>On January 6, 2021, an NOV was issued for submitting a late self-monitoring report which was due on 11/28/2020. The SMR was received on December 28, 2020, 30 days late. Completion of NOV requirements is still pending.</p> <p>On January 6, 2021, an NOV was issued for submitting a late NOV response letter which was due on 12/11/2020. The letter was received on 12/31/2020, 20 days late. Completion of NOV requirements is still pending.</p> <p>On January 8, 2021, an NOV was issued for submitting sampling results late; results were due on 12/16/2020. The results were received on 12/31/2020, 15 days late. Completion of NOV requirements is still pending.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: AmeriPride Services, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 6025 West Van Buren Street Phoenix, Arizona 85043-3509		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: N/A	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 05/01/2018	PERMIT EXPIRES: 04/30/2023	
SAMPLING LOCATION VERIFIED ON: 07/08/2020		RCRA NOTICE: 06/30/1998		
SLUG CONTROL PLAN EVALUATION DATE: 08/26/2020		COMPLIANCE SAMPLING POINT No: 5397.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	4	2	3	2
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	1	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	04/13/2020	07/17/2020	10/14/2020	01/19/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	02/04/2020	Grab	City	City	pH	10.7/10.5 S.U.	17
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A	N	E, F, I	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: AmeriPride Services, Inc.

Process Flow: 93,386 (GPD) Average

General Information and type of wastewater treatment	<p>This facility is an industrial laundry. The facility launders uniforms, linens, shop towels and various textiles. Wastewater treatment consists of coagulant/polymer addition, mixing, flocculation, settling, filter press (solids separation/disposal), and pH neutralization.</p>
First Quarter	<p>On 03/27/2020 an amended Notice to Show Cause was issued as a result of two parameter violations occurring within a 90-day period and two instances of late reporting in a 180-day period.</p> <p>On 02/04/2020 a Field NOV was issued for a pH violation which occurred during City monitoring. A TISM was issued on 02/19/2020. The IU met all of the requirements.</p>
Second Quarter	<p>On 05/14/2020 a Show Cause Proceeding was held to discuss violations occurring during the enforcement period 10/01/2019 through 03/01/2020.</p> <p>A change in ownership was determined to have taken place in early 2018 before which revised Class A Wastewater Discharge Permit No 1805-5397 went into effect. This information was not relayed until 2020 after which an ownership change permit application was submitted on May 29, 2020. However, a new Permit was already issued April 13, 2018 and went into effect May 1, 2018. Given the business name remains the same, this Permit is still considered valid.</p>
Third Quarter	<p>A Pretreatment Settlement Agreement was reached on 07/31/2020 which included monetary penalties of \$595 and a compliance schedule. All monetary penalties have been collected during 2020 and requirements of the compliance schedule are in the process of being met.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 595.00 Collected \$ 595.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Angelica		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 4410 West Mohave Street Phoenix, Arizona 85043-8304		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 07/22/2003	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 09/01/2018		PERMIT EXPIRES: 07/31/2023	
SAMPLING LOCATION VERIFIED ON: 07/01/2020		RCRA NOTICE: 02/10/2010		
SLUG CONTROL PLAN EVALUATION DATE: 07/01/2020		COMPLIANCE SAMPLING POINT No: 21470.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	3	5	3	3
Number of IU Sampling Days	1	1	2	1
Number of Parameter Violations	0	1	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	I	C	C
Evaluated as of:	04/13/2020	07/24/2020	10/19/2020	01/22/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Parameter	05/19/2020	Grab	City	City	pH	10.8/10.5 S.U.	
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A, L	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Angelica

Process Flow: 146,086 GPD (Average)

General Information and type of wastewater treatment	<p>Angelica is an industrial laundry that supplies clean linens and garments to hospitals, restaurants and the hospitality industry.</p> <p>The pretreatment system has a series of three points, each with an associated monitoring probe and injection pump, where the pH of the wastestream is monitored. The three monitoring points have different set points. The monitoring points are designated M1, M2 and M3 with corresponding set points approximately 10.0-SU, 9.7-SU and 9.0-SU. They are arranged where M1 with set point 10.0-SU is furthest from the discharge point and M3 with set point 9-SU is closest to the discharge point.</p>
First Quarter	Empty content for First Quarter
Second Quarter	<p>On 05/19/2020, a Field NOV for high pH was issued during a City sampling event. The TISM letter was mailed out on 05/22/2020 and all requirements have since been completed.</p>
Third Quarter	Empty content for Third Quarter
Fourth Quarter	Empty content for Fourth Quarter

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: APS BioGroup, Inc.			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 2235 South Central Avenue Phoenix, Arizona 85004-2909		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 439.47	LIMITS APPENDIX: A, L	BMR SUBMITTED: 12/05/2016	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 10/06/2017		PERMIT EXPIRES: 10/05/2022	
SAMPLING LOCATION VERIFIED ON: 09/04/2020		RCRA NOTICE: 10/18/2017		
SLUG CONTROL PLAN EVALUATION DATE: 09/24/2020		COMPLIANCE SAMPLING POINT No: 30755.01, 30755.02		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	1
Number of City Sampling Days	1	10	0	4
Number of IU Sampling Days	2	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	1	1
Compliance Status	C	C	I	I
Evaluated as of:	07/23/2020	08/31/2020	10/28/2020	02/04/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Permit Condition Permit Condition	08/28/2020	N/A	N/A	N/A	Prohibited Discharge Failure to maintain equipment		
4 th		12/14/2020	N/A	N/A	N/A			
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: APS BioGroup, Inc

Process Flow: 33,474 (GPD) Average

General Information and type of wastewater treatment	<p>APS BioGroup Inc. produces a wide range of bulk colostrum products as well as consumer ready packaged products in the form of capsules, tablets, individual sachets and packaged powders. Furthermore, APS BioGroup Inc. manufactures 200+ non-colostrum private label health supplements produced from over 500+ inventoried ingredients.</p> <p>Pretreatment consists of a solids interceptor and pH neutralization system; pharmaceutical wastewater is segregated in a separate holding tank and does not require pretreatment.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 08/28/2020 the City became aware of discharge of wastewater from the Compliance Area into a parking lot drywell. After a joint inspection conducted 09/04/2020, an NOV for Prohibited and Unlawful Discharge was issued on 09/24/2020. All requirements of the NOV were met.</p>
Fourth Quarter	<p>On 12/14/2020 the City became aware of discharge from the solids interceptor into a stormwater retention area. A demand inspection was conducted on 12/14/2020 and an NOV for Failure to Properly Maintain Pretreatment Equipment was issued on 01/07/2021. All requirements of the NOV were met.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: APS West Phoenix Power Plant

Process Flow: 329,065 (GPD) Average

General Information and type of wastewater treatment	<p>APS-West Phoenix Power Plant operates a natural gas-fueled steam electric power plant which is considered a peaking facility based on system demand for electricity. Discharge to City of Phoenix Sanitary Sewer is limited to the blowdown from cooling towers 1-2-3 and 4. There is no pretreatment of cooling tower blowdown wastewater prior to discharge; however, there is water treatment including pH neutralization of the cooling tower basin water as it circulates.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Aramark Uniform Services, LLC.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 3836 West Buckeye Road, Bldg F Phoenix, AZ 85009-5739		MAILING ADDRESS: Same		
CATEGORICAL USER?	No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 02/28/1990
TTO CERTIFICATION DATE SUBMITTED:	N/A	PERMIT EFFECTIVE:	04/16/2018	PERMIT EXPIRES: 03/31/2022
SAMPLING LOCATION VERIFIED ON:	06/10/2020	RCRA NOTICE:	02/28/1990	
SLUG CONTROL PLAN EVALUATION DATE:	06/10/2020	COMPLIANCE SAMPLING POINT №:	2180.02	
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	4	2	2	2
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	1	2
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	1	0	2
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	I	I	I
Evaluated as of:	06/26/2020	08/25/2020	11/20/2020	02/16/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Reporting	06/29/2020	N/A	N/A	N/A	Late SMR		
3 rd	Effluent	09/09/2020	Grab	City	City	pH	10.7/10.5 SU	3
4 th	Effluent	12/15/2020	Grab	City	IU	pH	11.9/10.5 S.U.	40
4 th	Effluent	12/24/2020	Grab	City	IU	pH	11.0/10.5 S.U.	40
4 th	Reporting	12/17/2020	N/A	N/A	N/A	24 Hour Notification 24 Hour Notification		
4 th	Reporting	12/26/2020	N/A	N/A	N/A			
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A (2), L	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Aramark Uniform and Career Apparel, Inc.

Process Flow: 70,910 GPD (Average)

General Information and type of wastewater treatment	<p>Aramark Uniform and Career Apparel, Inc. (Aramark) is an industrial laundry providing reusable textiles to a variety of customers. The facility launders garments, linen, mats, wiping towels, and maps. Wastewater treatment consists of pH neutralization and diffused air flotation.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 07/15/2020, an NOV was issued for submitting a late self-monitoring report which was due on 06/28/2020. The SMR was received on 06/29/2020; one day late. All requirements of the NOV were met.</p> <p>On 09/09/2020, a Field NOV was issued by City Wastewater Monitoring staff for High Effluent pH. A formal NOV and TISM was issued on 09/11/2020. All requirements of the NOV were met.</p>
Fourth Quarter	<p>On 01/25/2021, the City became aware of two separate pH excursions as well as two separate reporting violations of the 24-Hour notification requirement for the pH excursions. Notification was due on 12/16/2020 and 12/25/2020, received on 1/25/2021, 31 and 40 days late. An NOV for pH effluent limits and an NOV for late reporting were issued on 02/02/2021. The completion of both NOV's requirements are still pending.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Arizona Foods Group, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2517 East Chambers Street Phoenix, Arizona 85040-3640		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: N/A	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 01/16/2017	PERMIT EXPIRES: 12/31/2021	
SAMPLING LOCATION VERIFIED ON: 06/03/2020		RCRA NOTICE 02/07/2014		
SLUG CONTROL PLAN EVALUATION DATE: 06/03/2020		COMPLIANCE SAMPLING POINT No: 5325.02		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	3	0	3	2
Number of IU Sampling Days	4	4	3	3
Number of Parameter Violations	0	0	1	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	I	C
Evaluated as of:	06/26/2020	08/25/2020	11/23/2020	02/09/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Parameter	08/12/2020	Grab	City	City	pH (Instantaneous)	11.4/10.5 S.U.	6
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A, L	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona Foods Group, Inc.
 Process Flow: 15,990 (GPD) Average

General Information and type of wastewater treatment	<p>This facility is a dairy and non-dairy manufacturer of half and half, smoothie mixes, frozen yogurt, non-dairy toppings and dessert mixes. Sodium Hydroxide or Sulfuric Acid is used to neutralize the process wastes that are pumped into the pH neutralization tank before the waste is discharged to the flume. There is a 3 stage 1800-gallon oil/grease interceptor installed upstream of the compliance sampling point 5325.02.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 08/12/2020, a Field NOV was issued by City Wastewater Monitoring staff for High Effluent pH. A formal NOV and TISM were issued on 08/17/2020. All requirements of the NOV were met.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Arizona Precision Sheet Metal, Inc. (dba APSM Systems)		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2140 West Pinnacle Peak Road Phoenix, Arizona 85027-1200		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 07/29/1994	
TTO CERTIFICATION DATE SUBMITTED: 01/08/2021	PERMIT EFFECTIVE: 06/01/2020	PERMIT EXPIRES: 05/31/2025		
SAMPLING LOCATION VERIFIED ON: 09/30/2020	RCRA NOTICE: 09/16/1994			
SLUG CONTROL PLAN EVALUATION DATE: 09/30/2020	COMPLIANCE SAMPLING POINT No: 5309.01			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	2	0	2	0
Number of IU Sampling Days	1	2	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	1	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	I	C
Evaluated as of:	04/13/2020	07/27/2020	10/26/2020	01/08/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Reporting	08/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona Precision Sheet Metal, Inc. (dba APSM Systems)

Process Flow: 809 (GPD) Average

General Information and type of wastewater treatment	<p>Arizona Precision Sheet Metal, Inc. (APSM) manufactures metal parts and complete metal cabinets integrated with electronic components. The forming and assembly process includes metal forming, degreasing, etching, chromating, welding, and sanding in preparation for painting and final assembly.</p> <p>Arizona Precision has two manufacturing processes that discharge wastewater to the City of Phoenix sewer system through the compliance sampling point; the GFC line and the Deburr/Tumbler station. The pretreatment system consists of a large 2,000 gallon holding tank, a pH neutralization tank, a V-notch weir box, and a sump. Water from the holding tank is routed to the pH neutralization tank before it is discharged through the compliance sampling point.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 09/11/2020, an NOV was issued for submitting a late self-monitoring report which was due on 08/28/2020. The SMR was received on 08/31/2020; 3 days late. All requirements of the NOV were met.</p>
Fourth Quarter	<p>On 12/07/2020, an NOC was issued for failure to sample for pH during the first and second weeks of October 2020. An NOC was issued in lieu of an NOV due to an unexpected change in staffing. All requirements of the NOC were met.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: ASM America, Inc. University Drive Plant

Process Flow: 22,600 (GPD) Average

General Information and type of wastewater treatment	<p>ASM America, Inc. University Drive Plant (ASM) designs and builds machines (tools) used to manufacture semiconductors. ASM receives specifications for a layer of a wafer from a semiconductor manufacturer. ASM in turn designs a recipe for the manufacture of a wafer layer with the desired specifications. The recipe may consist of chemical constituents, temperature, pressure, deposition method and deposition rate. The recipe is tested and altered until the recipe is perfected. ASM "manufactures" semiconductors or rather layers of semiconductors but not finished semiconductor devices for production or sale.</p> <p>ASM utilizes pH neutralization for the pretreatment process. Regulated process flows are routed to a pH adjust tank (approximately 1,300 gallons). Doses of sodium hydroxide are fed/dispensed to the pH adjust tank from a 375 gallon tank to neutralize the wastewater before discharge to the sewer. The pH Monitoring/Adjust System is configured such that it has a "set point" to trigger a dose of sodium hydroxide to raise the pH of wastewater when needed. The system also has "alert points" that will cause an audible alarm if the pH of wastewater in the tank varies outside of a specified range.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 09/14/2020 an NOC was issued for releasing roughly 6,000-gallons of wastewater with a system approximated pH between 2.7 and 5.0 S.U. into the Sanitary Sewer on 08/31/2020. At the time of the suspected discharge, no compliance sample was taken to verify the pH of the wastewater.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Avanti Circuits, Inc.

Process Flow: 16,593 (GPD) Average

General Information and type of wastewater treatment	<p>The facility manufactures printed circuits boards. Wastewater treatment consists of: stream segregation, ion exchange, metals precipitation, flocculation, and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Baker Commodities, Inc. (Elwood)

Process Flow: 90,642 (GPD) Average

General Information and type of wastewater treatment	<p>The facility renders animal fat from dead animals and separates grease from wastewater for reuse in animal feed. The wastewater treatment consists of stream segregation, emulsion breaking, pH neutralization, physical separation, and sedimentation.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Banner Estrella Medical Center		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 9201 West Thomas Road Phoenix Arizona 85037-6918		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 07/02/2004	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 05/01/2020	PERMIT EXPIRES: 03/31/2025	
SAMPLING LOCATION VERIFIED ON: 12/18/2020		RCRA NOTICE: 01/05/2005		
SLUG CONTROL PLAN EVALUATION DATE: 12/18/2020		COMPLIANCE SAMPLING POINT No: 21828.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	2	1	3
Number of IU Sampling Days	2	1	1	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	1	0
Number of Permit Cond. Violations	0	0	1	0
Compliance Status	I	C	I	C
Evaluated as of:	05/28/2020	07/22/2020	10/16/2020	01/14/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Reporting	04/29/2020	N/A	N/A	N/A	Late SMR		
3 rd	Reporting	08/29/2020	N/A	N/A	N/A	Late SMR		
3 rd	Permit Condition	09/30/2020	N/A	N/A	N/A	Failure to Sample BOD, TSS		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A	A	A		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Banner Estrella Medical Center

Process Flow: 113,960 (GPD) Average

General Information and type of wastewater treatment	This facility conducts normal hospital operations. Wastewater treatment consists of stream segregation and physical separation.
First Quarter	
Second Quarter	On 06/03/2020 an NOV was issued for a late SMR submission. The SMR was due by 04/28/2020 and was received on 05/20/2020, twenty-two days late. All requirements of the NOV were met.
Third Quarter	On 09/14/2020 an NOV was issued for a late SMR submission. The SMR was due by 08/28/2020 and was received on 09/02/2020, five days late. All requirements of the NOV were met.
Fourth Quarter	On 11/18/2020 an NOV was issued for failure to sample for BOD and TSS in the third quarter of 2020. All requirements of the NOV were met.

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Banner Health - Banner University Medical Center Phoenix Campus		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1111 East McDowell Road Phoenix, Arizona 85006-2612		MAILING ADDRESS: 1021 East Willetta Street Phoenix, Arizona 85006-2770		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 12/28/1990	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 11/01/2019	PERMIT EXPIRES: 10/31/2024	
SAMPLING LOCATION VERIFIED ON: 12/08/2020		RCRA NOTICE: 12/28/1990		
SLUG CONTROL PLAN EVALUATION DATE: 12/08/2020		COMPLIANCE SAMPLING POINT No: 2710.04, 2710.05, 2710.06		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	3	0	4	0
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/04/2020	07/08/2020	10/08/2020	01/27/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Banner Health - Banner University Medical Center Phoenix Campus

Process Flow: 121,868 (GPD) Average

General Information and type of wastewater treatment	<p>Banner Good Samaritan Medical Center (Banner) is a Level One trauma hospital that provides emergency services and advanced heart and cardiovascular care. Services include: the Cavanagh Heart Center, Stroke Center and the Transplant Services Team. Banner is known for its success in handling high-risk obstetrics.</p> <p>The wastewater treatment consists of wastestream segregation and physical separation.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Barrel O' Fun Snack Foods Co. Southwest, LLC. (Shearer's Foods)		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 7330 West Sherman Street Phoenix, Arizona 85043-4751		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 06/07/2016	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 07/01/2016		PERMIT EXPIRES: 06/30/2021	
SAMPLING LOCATION VERIFIED ON: 11/20/2020		RCRA NOTICE: 06/13/2016		
SLUG CONTROL PLAN EVALUATION DATE: 11/20/2020		COMPLIANCE SAMPLING POINT No: 33399.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	2	3	3	2
Number of IU Sampling Days	3	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	1	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	I	C
Evaluated as of:	04/27/2020	07/22/2020	10/19/2020	01/08/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Reporting	08/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Barrel O' Fun Snack Foods Co. Southwest, LLC. (Shearer's Foods)

Process Flow: 336,174 GPD (Average)

General Information and type of wastewater treatment	<p>Shearer's Foods – Barrel O' Fun Snack Foods Co. Southwest, LLC. manufactures potato chips, kettle chips, tortilla chips, popcorn, caramel corn, kettle corn, and cheese puffs.</p> <p>The wastewater treatment consists of equalization, pH adjustment, coagulation, floatation, physical separation, and solids dewatering. All process wastewater passes through a 25,000-gallon underground pit/lift station. Processing Area wastewater is piped to a grease interceptor prior to the lift station. Pit wastewater is pumped to holding tanks and then pH adjustment. After chemical dosing, effluent is treated in a CAF with polymer and then sent through a filter press. Resulting liquor is returned to the pit. A new diverter valve discharges effluent into the pretreatment area trench to the pit from the sampling point in the event of noncompliance.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 08/28/2020, Class Wastewater Discharge Permit No. 2009-33399 was issued to Barrel O' Fun and included a name change from Shearer's Foods, LLC. – Barrel O' Fun Snack Foods Southwest to Barrel O' Fun Snack Foods Co. Southwest, LLC.</p> <p>On 08/31/2020 an NOC was issued for submitting an incomplete June 2020 SMR with missing sampling results and lab report. An NOC was issued in lieu of an NOV due to a lab merger at the analytical laboratory causing confusion in the sample reporting.</p> <p>On 09/10/2020, an NOV was issued for submitting a late Self-Monitoring Report (SMR) which was due on 08/28/2020. The SMR was received on 09/03/2020; 6 days late. All requirements of the NOV were met.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Benchmark Electronics, Inc.			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 3201 East Harbour Drive Phoenix Arizona 85034-7227		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 05/01/2018	
TTO CERTIFICATION DATE SUBMITTED: 01/22/2021		PERMIT EFFECTIVE: 03/08/2019	PERMIT EXPIRES: 02/29/2024	
SAMPLING LOCATION VERIFIED ON: 11/10/2020		RCRA NOTICE: 03/05/2019		
SLUG CONTROL PLAN EVALUATION DATE: 11/30/2020		COMPLIANCE SAMPLING POINT No: 45967.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	3	4	4	0
Number of IU Sampling Days	2	2	3	3
Number of Parameter Violations	0	0	2	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	I	C
Evaluated as of:	04/02/2020	07/08/2020	10/07/2020	01/22/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit Mg/ L	Number of Measurements per Quarter
3 rd	Parameter	08/19/2020	Composite	City	IU	Zinc	17.8/ 3.5 (D)	5
3 rd	Parameter	08/31/2020	Composite	City	IU	Zinc	6.817/ 1.48 (MAV)	3
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A	N	A, L	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Benchmark Electronics, Inc.

Process Flow: 2,798 (GPD) Average

General Information and type of wastewater treatment	<p>Benchmark conducts plating, assembly, and machining operations to support manufacture of multilayer printed circuit boards (PCBs) which are base components onto which semiconductors and integrated circuits are affixed. Pretreatment with the Total Treat CPS-50 system includes acid neutralization, ion exchange, flocculation and precipitation, sludge collection, filter press, and a separate gold recovery process for the gold process rinses.</p>
First Quarter	<p>An NOV was issued on 02/18/2020 for failure to sample Molybdenum in the second half of 2019 (July – December). All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	<p>On 09/21/2020 an NOV and TISM were issued for a daily and monthly average Zinc violation that occurred on 08/19/2020 and 08/31/2020. The IU met all the requirements.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Bottling Group, LLC. – The Pepsi Beverages Company

Process Flow: 96,221 (GPD) Average

General Information and type of wastewater treatment	This facility manufactures carbonated and non-carbonated soft drinks. Wastewater consists of pH neutralization.
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Café Valley Bakery, Inc.			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE 7000 W. Buckeye Rd. ADDRESS: Phoenix, Arizona 85043-4306			MAILING ADDRESS: Same	
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 02/06/2013	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 03/01/2018	PERMIT EXPIRES: 02/28/2023	
SAMPLING LOCATION VERIFIED ON: 11/02/2020		RCRA NOTICE: 02/28/2013		
SLUG CONTROL PLAN EVALUATION DATE: 11/02/2020		COMPLIANCE SAMPLING POINT №: 27064.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	3	4	4	0
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/11/2020	07/17/2020	11/06/2020	01/21/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Café Valley Bakery, Inc.

Process Flow: 37,043 (GPD) Average

General Information and type of wastewater treatment	<p>The facility receives raw bulk ingredients and mixes, bakes, packages and delivers bakery products to customers. The clean-in-place system used to clean some piping and mixing vats generates wastewater as a batch discharge whenever it is used.</p> <p>Café Valley uses a 3,200 gallon, 3 compartment underground oil and solids interceptor to remove solids from the effluent from this facility. This interceptor discharges to a 7,500-gallon flow equalization tank. The 7,500-gallon flow equalization tank discharges to a pH adjustment system. The pH adjustment system consists of the 7500-gallon flow equalization tank, a sodium hydroxide injection system, a sulfuric acid injection system, a mechanical mixing tank, and a continuous pH monitor.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Carl T. Hayden Medical Center
 Process Flow: 136,410 GPD (Average)

General Information and type of wastewater treatment	<p>Carl T. Hayden VA Medical Center is a full service hospital that provides surgery, dental, x-ray, psychiatric, rehabilitation care and neurological services to military veterans and their families. The facility has over 400 beds. The wastewater treatment consists of stream segregation and physical separation.</p>
First Quarter	
Second Quarter	<p>A Notice of Concern (NOC) was issued on 05/06/2020, due to exceeding the reporting limit of 0.0 µg/L for the parameter alpha-BHC on 03/10/2020 at a concentration of 0.06 µg/L. No requirements were issued with the NOC.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Cassavant Assembly & Processing, LLC.

Process Flow: 5,440 GPD (Average)

General Information and type of wastewater treatment	<p>The metal finishing facility conducts passivation, anodizing, non-destructive testing, painting and coating operations. Wastewater treatment consists of waste stream segregation, ion exchange, adsorption and chemical reduction as well as pH adjustment.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Celgene Corporation

Process Flow: 54,072 (GPD) Average

General Information and type of wastewater treatment	<p>Celgene Corporation operations involve the compounding, filling, labeling, packaging, warehousing and shipping of branded and generic sterile pharmaceutical injectables.</p> <p>Celgene Corporation has two compliance sampling points; one was deactivated due to water reuse system installation in the 1st Quarter of 2019. Pretreatment consists of waste stream segregation, physical separation and pH adjustment.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Certified Inspection Service Company Inc.

Process Flow: 2,055 (GPD) Average

General Information and type of wastewater treatment	<p>Certified Inspection Service Company, Inc. (Certified Inspection) performs inspections on newly manufactured aerospace parts. Non-destruct analyses are performed through fluorescent penetrant dye inspections, magnetic particle inspections, or x-ray inspections. The facility also performs ancillary chemical cleaning processes and passivation services.</p> <p>Pretreatment consists of a pH adjustment system. Waste water from the acid and alkaline room rinse tanks and rinse water from the x-ray process go to the large outdoor holding tank that is located next to the compliance sampling point. Concentrated sulfuric acid or sodium hydroxide are on an automatic dosing system.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: ChemResearch Company, Inc.			REPORT PERIOD: 01/01/2020 through 12/31/2020			
SERVICE ADDRESS: 1130 West Hilton Avenue Phoenix, Arizona 85007-4306			MAILING ADDRESS: 1101 West Hilton Avenue Phoenix, Arizona 85007-4305			
CATEGORICAL USER?	Yes	40 CFR 433.17	LIMITS APPENDIX:	E	BMR SUBMITTED:	02/09/1983
TTO CERTIFICATION DATE SUBMITTED:	01/21/2021	PERMIT EFFECTIVE:	01/01/2019	PERMIT EXPIRES:	12/31/2023	
SAMPLING LOCATION VERIFIED ON:	01/22/2020	RCRA NOTICE:	02/27/1990			
SLUG CONTROL PLAN EVALUATION DATE:	01/22/2020	COMPLIANCE SAMPLING POINT №:	1350.02, (CN Point 1350.03)			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Number of Inspections	1	0	0	0		
Number of City Sampling Days	0	5	3	3		
Number of IU Sampling Days	8	4	6	6		
Number of Parameter Violations	0	0	0	0		
Number of Inspection Violations	0	0	0	0		
Number of Reporting Violations	0	0	0	0		
Number of Permit Cond. Violations	0	0	0	0		
Compliance Status	S	C	C	C		
Evaluated as of:	06/30/2020	08/25/2020	11/20/2020	02/05/2021		

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A(2), L	N	N	E, F		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant |
| B - Administrative Order (AO) | G - Restriction of Flow | Non-Compliance (SNC) In Prior Reporting Year |
| C - Civil Action Filed | H - Permit Revocation | L - Temporary Increase in IU Self-Monitoring (TISM) |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: ChemResearch Co., Inc.

Process Flow: 41,298 (GPD) Average

General Information and type of wastewater treatment	<p>ChemResearch Company, Inc., is a metal finisher that performs Type I chromic-acid anodizing, Type II and III sulfuric-acid anodizing, manganese and zinc phosphating, hard chrome, electroless nickel, nickel, silver, gold, copper, chem-film chromium conversion coating, passivation, zincate coating, aluminum coloring, grinding, painting, and non-destructive testing, caustic fume scrubber bleed-off, and laboratory operations.</p> <p>Cyanide-bearing wastewaters are treated through two-stage alkaline chlorination followed by a holding tank. Chromium-bearing wastewaters collect into equalization Tank 1 for pumped feed through two-stage chromium reduction. General wastewaters collect into equalization Tank 2 for pumped feed through two-stage metal precipitation, along with the pre-treated cyanide-bearing and chromium-bearing wastewaters, to a lift station. The treated wastewaters are pumped through chemical-aided Lamella clarification, final pH adjustment and discharge to the sewers. The cyanide destruction, chromium reduction, metals precipitation, and final pH adjustment steps are all outfitted with process monitoring meters for pH, ORP, or both. The precipitate solids removed by the Lamella clarifier are dewatered through sludge decanting and filter pressing. Nickel-bearing spents are batch treated for solids removal through the filter press. Chrome plating baths are treated by in-line ion exchange for reuse.</p>
First Quarter	<p>On 01/23/2020 the City became aware of a daily Cadmium exceedance that occurred on 12/06/2019. An NOV, 30-Day Resample, and TISM were issued on 02/18/2020. All requirements of the NOV have been met.</p> <p>On 02/18/2020 an NOV was issued for a late 24-Hour Notification, due 12/19/2019, and received 01/23/2020, 35 days late. All requirements of the NOV have been met.</p> <p>On 03/06/2020 the IU was notified of 1st Quarter Significant Noncompliance (SNC) for 2020 for submitting a report over 30 days past the required due date. A 24-Hour Notification Reporting Violation was 35 days late.</p>
Second Quarter	
Third Quarter	<p>On 07/07/2020 a Notice to Show Cause was issued as a result of a late reporting violation and SNC occurring in the 1st Quarter of 2020. On 08/12/2020 a Show Cause Proceeding was held to discuss violations occurring during the enforcement period 12/01/2019 through 05/01/2020.</p>
Fourth Quarter	<p>A Pretreatment Settlement Agreement was reached on 10/20/2020 which included monetary penalties of \$525. The full penalty was collected during 2020.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 525.00 Collected \$ 525.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Chromalloy Arizona				REPORT PERIOD: 01/01/2020 through 12/31/2020			
SERVICE ADDRESS: 5161 West Polk Street Phoenix Arizona 85043-2720				MAILING ADDRESS: Same			
CATEGORICAL USER? Yes		40 CFR 433.17		LIMITS APPENDIX: E		BMR SUBMITTED: 04/30/1990	
TTO CERTIFICATION DATE SUBMITTED: 01/22/2021				PERMIT EFFECTIVE: 01/01/2019		PERMIT EXPIRES: 12/31/2023	
SAMPLING LOCATION VERIFIED ON: 08/26/2020				RCRA NOTICE: 06/22/1990			
SLUG CONTROL PLAN EVALUATION DATE: 09/08/2020				COMPLIANCE SAMPLING POINT No: 2760.01			
		1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Number of Inspections		0	0	1	0		
Number of City Sampling Days		0	4	2	0		
Number of IU Sampling Days		1	1	1	1		
Number of Parameter Violations		0	0	0	0		
Number of Inspection Violations		0	0	0	0		
Number of Reporting Violations		0	0	0	0		
Number of Permit Cond. Violations		0	0	0	0		
Compliance Status		C	C	C	C		
Evaluated as of:		04/09/2020	07/09/2020	10/05/2020	01/22/2021		

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Chromalloy Arizona

Process Flow: 4,512 (GPD) Average

General Information and type of wastewater treatment	<p>Processes consist of Platinum, Rhodium, and Nickel-plating operations associated with the thermal infusion coating process.</p> <p>Pretreatment processes include flocculation followed by pH adjustment to achieve precipitation of metals, followed by clarification and filtering before discharge. X-ray fixer is treated with an electrolytic silver recovery unit followed by a metal exchange filter to recover remaining silver.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Cintas Corporation – Roosevelt Street			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 4804 West Roosevelt Street Phoenix, Arizona 85043-2809		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 06/16/2017	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 09/01/2017	PERMIT EXPIRES: 08/31/2022	
SAMPLING LOCATION VERIFIED ON: 11/16/2020		RCRA NOTICE: N/A		
SLUG CONTROL PLAN EVALUATION DATE: 11/16/2020		COMPLIANCE SAMPLING POINT No: 5375.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	5	0	3	0
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	04/01/2020	07/27/2020	10/9/2020	01/12/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>A - Notice of Violation (NOV)
B - Administrative Order (AO)
C - Civil Action Filed
D - Criminal Action Filed
E - Pretreatment Settlement Agreement (PSA)</p> | <p>F - Assessment of Monetary Penalties
G - Restriction of Flow
H - Permit Revocation
I - Compliance Schedule Issued
J - Disconnection from Sewer</p> | <p>K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year
L - Temporary Increase in IU Self-Monitoring (TISM)
N – No Enforcement Action</p> |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Cintas Corporation – Roosevelt Street

Process Flow: 45,634 GPD (Average)

General Information and type of wastewater treatment	<p>This facility is a commercial laundry that processes soiled linens, mats, mops, and towels from industrial, governmental, and commercial users. Wastewater treatment consists of equalization, diffused air floatation, coagulation and flocculation.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Cintas Corporation				REPORT PERIOD: 01/01/2020 through 12/31/2020				
SERVICE ADDRESS: 5501 West Hadley Street Phoenix Arizona 85043-4600				MAILING ADDRESS: Same				
CATEGORICAL USER? No		40 CFR Local Limits		LIMITS APPENDIX: A		BMR SUBMITTED: 07/28/1995		
TTO CERTIFICATION DATE SUBMITTED: N/A				PERMIT EFFECTIVE: 03/01/2020		PERMIT EXPIRES: 02/28/2025		
SAMPLING LOCATION VERIFIED ON: 08/27/2020				RCRA NOTICE: 12/28/1990				
SLUG CONTROL PLAN EVALUATION DATE: 08/27/2020				COMPLIANCE SAMPLING POINT №: 5316.01				
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Number of Inspections		0	0	1	0			
Number of City Sampling Days		3	3	0	4			
Number of IU Sampling Days		1	1	1	1			
Number of Parameter Violations		0	0	0	0			
Number of Inspection Violations		0	0	0	0			
Number of Reporting Violations		0	0	0	0			
Number of Permit Cond. Violations		0	0	0	0			
Compliance Status		C	C	C	C			
Evaluated as of:		05/04/2020	07/27/2020	10/22/2020	01/26/2021			

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Cintas Corporation

Process Flow: 53,331 (GPD) Average

General Information and type of wastewater treatment	<p>The facility is a commercial laundry.</p> <p>The wastewater treatment consists of a screen filter, three-compartment interceptor and pH adjustment.</p>
First Quarter	<p>The renewed Wastewater Discharge Permit № 2003-5316 was issued on 02/14//2020, the permit replaces all previously issued Permits and became effective on 03/01/2020 and expires on 02/28/2025.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Cleanpart Southwest LLC				REPORT PERIOD: 01/01/2020 through 12/31/2020				
SERVICE 3844 East University Drive Suite 2 ADDRESS: Phoenix, Arizona 85034-7221				MAILING ADDRESS: Same				
CATEGORICAL USER? Yes		40 CFR 433.17		LIMITS APPENDIX: E		BMR SUBMITTED: 05/04/2009		
TTO CERTIFICATION DATE SUBMITTED: 01/22/2021				PERMIT EFFECTIVE: 07/01/2019		PERMIT EXPIRES: 06/30/2024		
SAMPLING LOCATION VERIFIED ON: 09/02/2020				RCRA NOTICE: 02/10/2010				
SLUG CONTROL PLAN EVALUATION DATE: 09/02/2020				COMPLIANCE SAMPLING POINT No: 26452.01				
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0		0		1		0	
Number of City Sampling Days	0		0		1		0	
Number of IU Sampling Days	1		1		1		6	
Number of Parameter Violations	0		0		1		2	
Number of Inspection Violations	0		0		0		0	
Number of Reporting Violations	0		0		0		0	
Number of Permit Cond. Violations	0		0		0		0	
Compliance Status	C		C		S		I	
Evaluated as of:	04/22/2020		07/22/2020		10/26/2020		01/22/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Parameter	08/13/2020	Grab/ Composite	Federal	City	TTO	2472.2 µg/L	1
4 th	Parameter	10/14/2020	Grab/ Composite	Federal	City	TTO	3400.6 µg/L	6
4 th	Parameter	10/22/2020	Grab/ Composite	Federal	City	TTO	3700.6 µg/L	6
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	A(2), L		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Cleanpart Southwest LLC
 Process Flow: 1,421 (GPD) Average

General Information and type of wastewater treatment	<p>CleanPart Southwest LLC cleans equipment used in the semiconductor manufacturing industry by removing deposited materials by abrasive blasting or chemically using acids or caustic solutions. The parts are then rinsed with D I water, dried with compressed air, and then blasted with CO2 ice particles. Finally, the parts are packaged for shipment in a clean room environment.</p> <p>The pretreatment system consists of a series of tanks (or stages) wherein chemicals are added to the wastewater to cause precipitation, flocculation, coagulation, clarification, and pH adjustment, then batch discharged via a spigot compliance sampling point.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	<p>On 09/14/2020 the City became aware of a daily maximum Total Toxic Organics (TTO) exceedance that occurred during City monitoring on 08/13/2020. An NOV, 30-Day Resample, and TISM were issued on 10/02/2020. All requirements of the NOV were met.</p> <p>On 11/06/2020 the City became aware of violations of the daily maximum limit for TTO during required Temporary Increase in Self-Monitoring (TISM) sampling on 10/14/2020 and 10/22/2020. An NOV was issued on 12/04/2020 and all requirements of the NOV were met.</p> <p>On 12/11/2020 the IU was notified of 3rd Quarter Significant Non-Compliance (SNC) for violations of the Phoenix City Code Chapter 28 and Wastewater Discharge Permit No.1907-26452, for the Daily Maximum Chronic exceedance of TTO.</p> <p>A Notice of Concern (NOC) was issued on 02/05/2021, for exceeding the April 2005 SROG Best Management Practices Technical Memorandum – Fluoride BMP, 33 mg/L, on 10/14/2020 with a concentration of 2000 mg/L. No requirements were issued with the NOC.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Crothall Laundry Services Inc. – The Commercial Linen Exchange		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 4445 South 36 th Street Phoenix, Arizona 85040-2901		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 03/28/2014	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 04/01/2019	PERMIT EXPIRES: 03/31/2024	
SAMPLING LOCATION VERIFIED ON: 05/26/2020		RCRA NOTICE: 04/02/2014		
SLUG CONTROL PLAN EVALUATION DATE: 05/26/2020		COMPLIANCE SAMPLING POINT No: 32079.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	4	4	5	0
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	1	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	I	C	C
Evaluated as of:	04/22/2020	07/17/2020	10/12/2020	01/22/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st 2 nd	Reporting Parameter	03/29/2020 06/11/2020	N/A Grab	N/A City	N/A IU	Late SMR pH	10.8/10.5 SU	13
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A (2)	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Crothall Laundry Services Inc.- The Commercial Linen Exchange

Process Flow: 154,971 (GPD) Average

General Information and type of wastewater treatment	<p>This facility is an industrial laundry which launders hospital linens, uniforms and floor mops; operations exclude dry cleaning processes. Wastewater treatment consists of pH neutralization.</p>
First Quarter	
Second Quarter	<p>On 04/09/2020, an NOV was issued for submitting a late self-monitoring report which was due on 03/28/2020. The SMR was received on 03/30/2020; two days late. All requirements of the NOV were met.</p> <p>On 06/11/2020, the IU notified the City of a pH exceedance. An NOV, 30-day resample, and TISM were issued on 06/30/2020. The IU met all requirements of the NOV.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Dignity Health - St. Joseph's Hospital & Medical Center		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 350 West Thomas Road Phoenix Arizona 85013-4409		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: NA	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 11/20/2017	PERMIT EXPIRES: 06/30/2022	
SAMPLING LOCATION VERIFIED ON: 12/15/2020		RCRA NOTICE: 12/28/1990		
SLUG CONTROL PLAN EVALUATION DATE: 12/15/2020		COMPLIANCE SAMPLING POINT No: 2690.05, 2690.06, 2690.07, 2690.08, 2690.10		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	4	2	5
Number of IU Sampling Days	2	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	05/14/2020	09/01/2020	10/20/2020	01/27/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Reporting	01/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Dignity Health - St. Joseph's Hospital & Medical Center

Process Flow: 232,252 (GPD) Average

General Information and type of wastewater treatment	<p>This facility is a large full service hospital and neurological research center.</p> <p>Wastewater treatment consists of gravity separation of grease wastes and BMPs to limit or eliminate the discharge of solvents, metals, and grease pollutants from various locations throughout the hospital.</p>
First Quarter	<p>On 02/14/2020, an NOV was issued for submitting a late self-monitoring report which was due on 01/28/2020. The SMR was received on 02/07/2020; 10 days late. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: District Photo, Inc.

Process Flow: 8,138 (GPD) Average

General Information and type of wastewater treatment	<p>This facility produces photographic prints from digital images: 5333sq/ft. of paper per hour and digital printing – 5 million sheets per year. Pretreatment consists of electrolytic silver recovery, ion exchange, equalization, and batch pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: DS Services of America, Inc.

Process Flow: 118,492 (GPD) Average

General Information and type of wastewater treatment	<p>DS Services produces and packages purified drinking water that is marketed under multiple brands. Water from an on-site well is purified by reverse osmosis, carbon filtration, microfiltration, distillation and ozone contact. Pretreatment consists of equalization and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Dunn-Edwards Corporation

Process Flow: 4,729 GPD (Average)

General Information and type of wastewater treatment	<p>Dunn-Edwards Corporation (Dunn-Edwards) is a paint manufacturing and distribution facility. Dunn-Edwards manufactures high quality water based latex architectural coatings. The operation consists of a batch and filling process. The manufacturing processes which generate wastewater or have the potential to generate wastewater are from the paint making letdown tank cleaning and from the paint filling manifold/pop tank cleaning. The facility currently produces about 70,000 gallons of paint per day.</p>
First Quarter	
Second Quarter	<p>The renewed Class A Wastewater Discharge Permit № 2006-33198 was issued on 05/12/2020, the permit replaces all previously issued Permits and became effective on 06/01/2020 and expires on 05/31/2025.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Entrepix, Inc.

Process Flow: 4,820 (GPD) Average

General Information and type of wastewater treatment	<p>This facility performs chemical mechanical polishing, Semiconductor Equipment Zubeloer (SEZ) wet planning operations and related wafer polishing operations. Pretreatment consists of pH neutralization and micro filtration. IU opts to sample TTOs quarterly.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: FlipChip International, LLC

Process Flow: 37,284 GPD (Average)

General Information and type of wastewater treatment	<p>This facility processes silicon wafers by utilizing photoresist, etching, sputtering, and cleaning operations. Pretreatment consists of ion exchange and pH neutralization.</p>
First Quarter	<p>On 01/14/2020 an NOV was issued for failure to sample for copper for November 2019. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: FM Industries, Inc.

Process Flow: 14,953 (GPD) Average

General Information and type of wastewater treatment	<p>FM Industries, Inc. performs anodizing and nickel seal on aluminum parts.</p> <p>Pretreatment consists of wastestream segregation and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Frontier Group

Process Flow: 364 (GPD) Average

General Information and type of wastewater treatment	<p>Frontier Group performs metal finishing operations for commercial and aerospace applications. Pretreatment consists of wastestream segregation, precipitation, solids dewatering, filtration and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Global Healing Center

Process Flow: 293 GPD (Average)

General Information and type of wastewater treatment	<p>The facility manufactures liquid and powder types of encapsulated supplements with primarily natural and organic ingredients for health purposes. The manufactured products include magnesium, turmeric, probiotics, vitamin D3, vitamin E and more. Global Healing Center is federally regulated by 40 CFR Part 439.47 (Pharmaceutical Manufacturing) – Subpart D (Mixing/Compounding and Formulation) given that the medicinal chemicals and botanical products compounded onsite (SIC Code 2833) fall under this regulation. There is no pretreatment currently onsite.</p>
First Quarter	<p>After review of the December 2019 SMR the City discovered that Global Healing Center failed to sample for pH from the week of 12/15/2019 -12/21/2019. An NOV for Permit Conditions – Failure to sample was issued on 02/26/2020. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Gregory Packaging, Inc.

Process Flow: 35,884 GPD (Average)

General Information and type of wastewater treatment	<p>The facility is a juice and beverage manufacturer that packages final products for customers (mostly wholesale to schools and grocery stores) which includes a variety of sizes of packaging and ingredients. The primary treatment at the facility is pH adjustment with sodium hydroxide or sulfuric acid prior to mixing and discharge to the compliance sampling point.</p>
First Quarter	
Second Quarter	<p>On 06/03/2020, an NOC was issued for IU failure to sample weekly pH for the month of April during the week of 04/05/2020. All requirements of the NOC were met.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Hadrian Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 3602 West Washington Street Phoenix, Arizona 85009-4767		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 10/28/2016	
TTO CERTIFICATION DATE SUBMITTED: 01/27/2021	PERMIT EFFECTIVE: 09/01/2020	PERMIT EXPIRES: 08/31/2025		
SAMPLING LOCATION VERIFIED ON: 06/03/2020	RCRA NOTICE: 06/06/2016			
SLUG CONTROL PLAN EVALUATION DATE: 09/27/2019	COMPLIANCE SAMPLING POINT №: 33387.01			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	3	0	2	2
Number of IU Sampling Days	3	4	3	3
Number of Parameter Violations	1	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	04/27/2020	07/27/2020	10/28/2020	01/28/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	03/31/2020	Composite	Federal	City	Zinc	1.86/1.48 mg/L (MAV)	3
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Hadrian Inc.

Process Flow: 721 GPD (Average)

General Information and type of wastewater treatment	<p>The IU manufactures and powder coats galvanized metal washroom partitions and lockers. The core metal finishing process includes iron phosphate coating. Phosphating rinses are discharged without pretreatment.</p>
First Quarter	
Second Quarter	<p>On 03/25/2020 the City became aware of a zinc monthly average exceedance collected during City sampling. A NOV and 30-day Resample were issued on 04/01/2020. The IU met all requirements.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Heligear Acquisition Co. dba Northstar Aerospace – Phoenix

Process Flow: 1,012 (GPD) Average

General Information and type of wastewater treatment	<p>This facility performs chemical etching and chrome conversion coating on aluminum, stainless steel, steel, titanium, and other exotic metals. Radiographic film processing is conducted on some parts as a quality control test.</p> <p>Wastewater treatment includes wastestream segregation, gravity settling, electrolytic recovery, recycling, evaporation, and ion exchange.</p>
First Quarter	<p>On 01/14/2020 an amended Notice to Show Cause was issued as a result of effluent and reporting violations resulting in Significant Noncompliance status. On 01/24/2020 a Show Cause Meeting was held to discuss violations occurring during the enforcement period 02/01/2019 through 10/14/2019. A Pretreatment Settlement Agreement was reached on 03/24/2020 which included monetary penalties of \$6,135. All of the monetary penalties were collected during 2020.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 6,135.00 Collected \$ 6,135.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Heligear Acquisition Co. – Northstar Aerospace (Phoenix)

Process Flow: 383 GPD (Average)

General Information and type of wastewater treatment	<p>This facility performs alkaline cleaning, acid etching, non-destructive penetrant testing, cadmium and nickel brush plating on aluminum, steel, and titanium aerospace parts. The wastewater treatment includes ion exchange followed by pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Holsum Bakery, Inc.				REPORT PERIOD: 01/01/2020 through 12/31/2020				
SERVICE ADDRESS: 2322 West Lincoln Street Phoenix, Arizona 85009-5827				MAILING ADDRESS: Same				
CATEGORICAL USER? No		40 CFR Local Limits		LIMITS APPENDIX: A		BMR SUBMITTED: 10/01/1995		
TTO CERTIFICATION DATE SUBMITTED: N/A				PERMIT EFFECTIVE: 01/01/2020		PERMIT EXPIRES: 12/31/2024		
SAMPLING LOCATION VERIFIED ON: 11/20/2020				RCRA NOTICE: 08/21/1995				
SLUG CONTROL PLAN EVALUATION DATE: 11/20/2020				COMPLIANCE SAMPLING POINT №: 5313.01				
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0		2		0		1	
Number of City Sampling Days	4		0		4		0	
Number of IU Sampling Days	1		1		1		1	
Number of Parameter Violations	1		0		0		0	
Number of Inspection Violations	0		0		0		0	
Number of Reporting Violations	0		0		0		0	
Number of Permit Cond. Violations	0		0		0		0	
Compliance Status	I		C		C		C	
Evaluated as of:	06/30/2020		08/25/2020		12/04/2020		02/10/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	03/29/2020	Continuous	City	IU	pH	4.9 / 5.0 SU	Continuous
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Holsum Bakery, Inc.

Process Flow: 26,956 GPD (Average)

General Information and type of wastewater treatment	<p>This facility is an industrial bakery that mixes, bakes, and packages bread and bakery products from raw bulk ingredients. Wastewater treatment includes gravity separation via grease interceptor and pH neutralization. The facility installed an additional pH Neutralization System, Lift Station, and Grease Interceptor for pretreatment of the east half of the facility wastewater in 2018.</p>
First Quarter	<p>On 02/26/2020, a pH Waiver was issued for high pH discharge that occurred on 01/24/2020. No requirements were made as a result of the pH Waiver.</p> <p>On 03/18/2020, a pH Waiver was issued for high pH discharge that occurred on 03/16/2020. No requirements were made as a result of the pH Waiver.</p>
Second Quarter	<p>On 04/03/2020, an NOV was issued for a continuous pH effluent violation that occurred on 03/29/2020. All requirements of the NOV were met.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Honeywell International Inc.
Former Peoria Avenue Facility/EW-1
 Process Flow: 51,335 GPD (Average)

General Information and type of wastewater treatment	This is a groundwater extraction site with no pretreatment or manufacturing processes.
First Quarter	
Second Quarter	
Third Quarter	On 07/29/2020, a Notice of Concern (NOC) was issued for exceedances of the reporting concentration for 1,1-Dichloroethylene on 07/07/2020, 07/08/2020, 07/09/2020, and 07/10/2020. There were no requirements made of the IU as a result of the NOC.
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Honeywell International Inc. Former Peoria Avenue Facility/MW-10		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2251 West Sierra Street Phoenix Arizona 85029-3602		MAILING ADDRESS: 111 South 24th Street, MS 158 Phoenix, Arizona 85034-2802		
CATEGORICAL USER?	No	40 CFR	Local Limits	LIMITS APPENDIX: A
BMR SUBMITTED:		07/11/1997		
TTO CERTIFICATION DATE SUBMITTED:	N/A	PERMIT EFFECTIVE:	10/01/2017	PERMIT EXPIRES:
09/30/2022				
SAMPLING LOCATION VERIFIED ON:		RCRA NOTICE:		
05/22/2020		07/11/1997		
SLUG CONTROL PLAN EVALUATION DATE:		COMPLIANCE SAMPLING POINT No:		
05/22/2020		5383.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	6	0	2	0
Number of IU Sampling Days	1	2	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/07/2020	09/04/2020	12/2/2020	02/19/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Honeywell International Inc.
Former Peoria Avenue Facility/MW-10

Process Flow: 40,860 GPD (Average)

General Information and type of wastewater treatment	This is a groundwater extraction site with no pretreatment or manufacturing processes.
First Quarter	On 03/23/2020, the City became aware of exceedances of the reporting limits for 1,1-Dichloroethylene during City sampling on 03/18/2020 . A Notice of Concern without requirements was issued on 04/09/2020.
Second Quarter	
Third Quarter	The City became aware of exceedances of the reporting limits for 1,1-Dichloroethylene during City sampling on 07/07/2020 and 07/08/2020 . A Notice of Concern without requirements was issued on 07/29/2020.
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Honeywell International, Inc. Honeywell Aerospace – Phoenix R & O
 Process Flow: 21,574 (GPD) Average

General Information and type of wastewater treatment	<p>This facility repairs and overhauls turbine engines using steam cleaning, caustic and acid cleaning, chromate conversion coating and associated operations. The wastewater treatment consists of stream segregation, chemical reduction, precipitation, flocculation sedimentation and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Honeywell International, Inc. Honeywell Aerospace- Phoenix R & O		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1944 East Sky Harbor Circle Northwest Phoenix, Arizona 85034-3442		MAILING ADDRESS: 1944 East Sky Harbor Circle Northwest Mail Stop 2101-C Phoenix, Arizona 85034-3442		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: X	BMR SUBMITTED: 06/25/1992	
TTO CERTIFICATION DATE SUBMITTED: 01/15/2021	PERMIT EFFECTIVE: 07/01/2018	PERMIT EXPIRES: 06/30/2023		
SAMPLING LOCATION VERIFIED ON: 12/10/2020	RCRA NOTICE: 02/04/1992			
SLUG CONTROL PLAN EVALUATION DATE: 12/10/2020	COMPLIANCE SAMPLING POINT №: 2990.01			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	3	3	0
Number of IU Sampling Days	1	1	2	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/01/2020	07/20/2020	10/23/2020	01/14/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

A - Notice of Violation (NOV)	F - Assessment of Monetary Penalties	K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year
B - Administrative Order (AO)	G - Restriction of Flow	L - Temporary Increase in IU Self-Monitoring (TISM)
C - Civil Action Filed	H - Permit Revocation	
D - Criminal Action Filed	I - Compliance Schedule Issued	
E - Pretreatment Settlement Agreement (PSA)	J - Disconnection from Sewer	N - No Enforcement Action

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Honeywell International, Inc. Honeywell Aerospace – Phoenix R & O
 Process Flow: 21,574 (GPD) Average

General Information and type of wastewater treatment	This facility repairs and overhauls turbine engines using steam cleaning, caustic and acid cleaning, chromate conversion coating and associated operations. The wastewater treatment consists of stream segregation, chemical reduction, precipitation, flocculation sedimentation and pH neutralization.
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Honeywell International, Inc.- Honeywell Engines Product Center		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 111 South 34th Street Phoenix, Arizona 85034-2802		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 11/02/1983	
TTO CERTIFICATION DATE SUBMITTED: 01/28/2020	PERMIT EFFECTIVE: 07/01/2017	PERMIT EXPIRES: 06/30/2022		
SAMPLING LOCATION VERIFIED ON: 11/10/2020	RCRA NOTICE: 02/27/1990			
SLUG CONTROL PLAN EVALUATION DATE: 11/10/2020	COMPLIANCE SAMPLING POINT №: 1510.06, (1510.09 - CN Point)			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	3	3	2
Number of IU Sampling Days	28	28	25	26
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	1	0	0
Compliance Status	C	I	C	C
Evaluated as of:	06/25/2020	09/03/2020	02/01/2021	02/17/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Permit Condition	06/30/2020	N/A	N/A	N/A	Failure to Sample		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Honeywell International, Inc.- Honeywell Engines Product Center

Process Flow: 37,117 (GPD) Average

General Information and type of wastewater treatment	<p>Manufacturer of turbine engines that performs caustic and acid cleaning, electrolytic and electroless plating, which includes the use of Cadmium, Copper, Nickel, and Chromium plating and anodizing.</p> <p>The wastewater treatment consists of stream segregation, chemical oxidation, chemical reduction, hydroxide precipitation, pH neutralization, physical separation and sedimentation.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 07/06/2020, an NOV was issued for IU Failure to Sample, which is a Permit Conditions violation. During the month of May 2020, the IU failed to sample Cadmium, Chromium, Copper, Lead, Nickel, Silver, and Zinc. All requirements of the NOV have been met.</p> <p>On 08/06/2020, an NOC was issued for Late Reporting - Notice of Violation (NOV) Resample Results. The results required by the 07/06/2020 NOV were submitted to the IPP 5 days late.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: HonorHealth Deer Valley Medical Center				REPORT PERIOD: 01/01/2020 through 12/31/2020				
SERVICE 19829 North 27th Avenue ADDRESS: Phoenix Arizona 85027-4001				MAILING ADDRESS: Same				
CATEGORICAL USER? No		40 CFR Local Limits		LIMITS APPENDIX: A		BMR SUBMITTED: 12/28/1990		
TTO CERTIFICATION DATE SUBMITTED: N/A				PERMIT EFFECTIVE: 07/01/2017		PERMIT EXPIRES: 06/30/2022		
SAMPLING LOCATION VERIFIED ON: 11/12/2020				RCRA NOTICE: 12/28/1990				
SLUG CONTROL PLAN EVALUATION DATE: 11/12/2020				COMPLIANCE SAMPLING POINT No: 5374.01, 5374.02, 5374.03				
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0		0		0		1	
Number of City Sampling Days	4		0		0		3	
Number of IU Sampling Days	5		2		1		1	
Number of Parameter Violations	1		0		0		0	
Number of Inspection Violations	0		0		0		0	
Number of Reporting Violations	0		0		0		0	
Number of Permit Cond. Violations	0		0		0		0	
Compliance Status	C		C		C		C	
Evaluated as of:	04/15/2020		07/16/2020		10/07/2020		01/28/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	01/10/2020	Composite	City	IU	Mercury	0.0047/0.0023 mg/L	8
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A, L	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: HonorHealth Deer Valley Medical Center

Process Flow: 83,535 (GPD) Average

General Information and type of wastewater treatment	<p>John C. Lincoln Hospital – Deer Valley is a 203-bed, not-for-profit, full service hospital. Services include an emergency department, cardiac care, inpatient and outpatient surgery, oncology, an orthopedic unit, medical imaging and pediatrics.</p> <p>The wastewater treatment consists of wastestream segregation and physical separation. A three compartment Grease Interceptor pre-treats the discharge from the kitchen.</p>
First Quarter	<p>On 02/06/2020 an NOV and TISM were issued for an exceedance in Mercury on 01/10/2020 during a self-monitoring sampling event. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: HonorHealth John C. Lincoln Hospital North Mountain

Process Flow: 82,084 GPD (Average)

General Information and type of wastewater treatment	<p>HonorHealth John C. Lincoln Hospital North Mountain is a 262-bed, acute care hospital. It is the first hospital in the Phoenix area to be designated a Magnet Hospital. Services include an Emergency and Level I Trauma Center, critical care, inpatient and outpatient surgery, oncology, an orthopedic unit, diagnostic imaging and outpatient therapy.</p> <p>The wastewater peretreatment consists of wastestream segregation and physical separation. A 3-compartment grease interceptor pretreats wastewater from the kitchen.</p>
First Quarter	<p>.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: HonorHealth Sonoran Crossing Medical Center

Process Flow: 21,099 GPD (Average)

General Information and type of wastewater treatment	<p>HonorHealth Sonoran Medical Center (HH Sonoran) is a hospital and health care facility that provides inpatient services, obstetrics and gynecological care, orthopedic care, surgical care, emergency services, and ambulatory (outpatient) services to the Greater Phoenix area. Pretreatment onsite consists of a 3000-gallon grease interceptor which receives all fats, oils and grease waste from the food service kitchen. In addition, there is a 500-gallon decontamination tank that does not discharge to the sewer.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	<p>On 10/14/2020, Industrial Wastewater Discharge Permit 2011-31009 was mailed to the facility with an effective date of 11/01/2020 and an expiration date of 10/31/2025.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Hydro Extrusion North America, LLC. – Plant 2 Extrusion Operation

Process Flow: 296 GPD (Average)

General Information and type of wastewater treatment	<p>Hydro Extrusion North America, LLC - Plant 2 Extrusion Operation manufactures aluminum parts and tubing via extrusion press forming. Pretreatment consists of wastestream segregation, gravity separation of oil and grease, filtration, and pH adjustment, a compliance sampling point as well as an evaporator. The facility samples for Oil and Grease in lieu of Total Toxic Organics.</p>
First Quarter	<p>A Pretreatment Settlement Agreement (PSA) was reached on 03/09/2020 which included monetary penalties of \$6,396 and a compliance schedule. All monetary penalties were collected in 2020 and requirements of the compliance schedule are in the process of being met. The PSA and penalty amounts are included for each Hydro Extrusion SIU Compliance Status Report; however, only one PSA was reached and a total penalty of \$6,396 was collected.</p> <p>On 03/11/2020, a Notice of Concern (NOC) was issued for failure to locate pH calibration logs for January 2020 and first two weeks of February 2020.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 6,396.00 Collected \$ 6,396.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Hydro Extrusion North America, LLC – Plant 1 Remelt Operation		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 249 South 51st Avenue Phoenix Arizona 85043-3715		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 467.35	LIMITS APPENDIX: G	BMR SUBMITTED: 02/28/2003	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 03/05/2018	PERMIT EXPIRES: 12/31/2022	
SAMPLING LOCATION VERIFIED ON: 11/16/2020		RCRA NOTICE: 02/28/1990		
SLUG CONTROL PLAN EVALUATION DATE: 11/16/2020		COMPLIANCE SAMPLING POINT No: 21490.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	3	3	0
Number of IU Sampling Days	4	3	3	3
Number of Parameter Violations	1	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	04/27/2020	07/27/2020	10/28/2020	01/26/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1st	Parameter	01/31/2020	Composite	City	IU	Oil & Grease Late 24-Hour Notification	356/180.84 mg/L (MAV)	4
1st	Reporting	03/02/2020	N/A	N/A	N/A			
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A (2), E, F, I	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Hydro Extrusion North America, LLC – Plant 1 Remelt Operation
 Process Flow: 6,283 (GPD) Average

General Information and type of wastewater treatment	<p>Hydro Extrusion North America, LLC – Plant 1 Remelt Operation is a foundry/cast house that performs direct chill casting and homogenizing of aluminum billets. The pretreatment consists of emulsion breaking, gravity separation of oil and grease, and filtration. The facility samples for Oil and Grease in lieu of Total Toxic Organics.</p>
First Quarter	<p>A Pretreatment Settlement Agreement was reached on 03/09/2020 which included monetary penalties of \$6,396 and a compliance schedule. All monetary penalties were collected in 2020 and requirements of the compliance schedule are in the process of being met. The PSA and penalty amounts are included for each Hydro Extrusion SIU Compliance Status Report; however, only one PSA was reached and a total penalty of \$6,396 was collected.</p> <p>On 03/10/2020, an NOV and 30-day resample were issued for an Oil & Grease exceedance that occurred on 01/31/2020. All requirements of the NOV were met.</p> <p>On 03/10/2020, an NOV was issued for a late 24-Hour Notification of an Oil & Grease exceedance. The notification was due on 02/20/2020, and received on 03/02/2020, 12 days late. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 6,396.00 Collected \$ 6,396.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Hydro Extrusion North America, LLC - Plant 1 Extrusion Operation

Process Flow: 4,878 (GPD) Average

General Information and type of wastewater treatment	<p>Hydro Extrusion North America, LLC - Plant 1 Extrusion Operation, manufactures parts and tubing via an aluminum ingot extrusion forming press. The facility samples for Oil and Grease in lieu of Total Toxic Organics.</p> <p>Pretreatment consists of gravity separation of oil and grease, filtration, and pH adjustment.</p>
First Quarter	<p>A Pretreatment Settlement Agreement was reached on 03/09/2020 which included monetary penalties of \$6,396 and a compliance schedule. All monetary penalties were collected in 2020 and requirements of the compliance schedule are in the process of being met. The PSA and penalty amounts are included for each Hydro Extrusion SIU Compliance Status Report; however, only one PSA was reached and a total penalty of \$6,396 was collected.</p> <p>On 03/11/2020, a Notice of Concern (NOC) was issued for failure to locate pH calibration logs for January 2020 and first two weeks of February 2020.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 6,396.00 Collected \$ 6,396.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Liquid Environmental Solution of Arizona LLC – Magnolia Street		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1095 West Magnolia Street Phoenix, Arizona 85007		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 07/07/2017	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 08/01/2019	PERMIT EXPIRES: 11/30/2022	
SAMPLING LOCATION VERIFIED ON: 11/05/2020		RCRA NOTICE: 02/04/2018		
SLUG CONTROL PLAN EVALUATION DATE: 11/05/2020		COMPLIANCE SAMPLING POINT №: 27287.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	2	4	3	0
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	1	0	0
Compliance Status	C	I	C	C
Evaluated as of:	04/22/2020	07/08/2020	10/06/2020	01/07/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Permit Condition	04/05/2020	NA	N/A	N/A	Failure to sample pH		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Liquid Environmental Solutions of Arizona LLC –
Magnolia Street
 Process Flow: 40,040 GPD (Average)

General Information and type of wastewater treatment	<p>This facility (LES Magnolia) collects and processes hauled animal or vegetable grease-laden wastewater from grease interceptors (new Tricanter centrifuge w/centrate), waste water from tallow bin cleaning, and contaminated stormwater collected from the permitted facility. LES Magnolia also collects used cooking oil for recycling and resale.</p>
First Quarter	
Second Quarter	<p>On 06/10/2020, an NOV was issued for IU failure to sample for pH during the first week of April 2020. All requirements of the NOV were met.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Liquid Environmental Solutions of Arizona LLC			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 5159 West Van Buren Street Phoenix Arizona 85043-3270		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 437.47	LIMITS APPENDIX: Q	BMR SUBMITTED: 11/01/2003	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 12/1/2019		PERMIT EXPIRES: 08/31/2022	
SAMPLING LOCATION VERIFIED ON: 06/11/2020		RCRA NOTICE: 06/06/1996		
SLUG CONTROL PLAN EVALUATION DATE: 06/11/2020		COMPLIANCE SAMPLING POINT No: 21741.03, 21741.06, 21741.07		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	4	3	3	0
Number of IU Sampling Days	21	14	17	16
Number of Parameter Violations	0	2	1	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	I	I	C
Evaluated as of:	05/07/2020	09/04/2020	10/15/2020	01/31/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Reporting	02/01/2020	N/A	N/A	N/A	Late NOV Response		
2 nd	Parameter	05/07/2020	Composite	City	IU	Arsenic (Daily)	0.27/0.13 mg/L	6
2 nd	Parameter	06/24/2020	Composite	City	City	Mercury	0.00264/0.0023 mg/L	7
3 rd	Parameter	08/31/2020	Composite	Federal	IU	DEHP (MAV)	117/107 ug/L	3
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A (2), L	N	A (3)	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Liquid Environmental Solutions of Arizona LLC
 Process Flow: 69,482 (GPD) Average

General Information and type of wastewater treatment	<p>Liquid Environmental Solutions of Arizona LLC is a Centralized Waste Treatment facility receiving and treating non-hazardous liquid waste. Treatment includes wastestream segregation, physical separation, emulsion breaking, dissolved air flotation, chemical precipitation, pH adjustment, biologically active aerated treatment, and a lamella clarifier. The pretreatment system is separated into the following categories: Metal bearing wastes, organic wastes, oily wastes, non-categorical and domestic wastes.</p>
First Quarter	<p>On 01/14/2020 an NOV, 30-day Resample, and TISM were issued for exceeding the daily maximum limit for Mercury on 11/01/2019. The violation was reported by Liquid Environmental Solutions of Arizona, LLC. on 11/25/2019, and the analytical results were received by the City of Phoenix on 12/24/2019. All requirements of the NOV were met.</p> <p>On 02/18/2020, an NOV was issued for submitting a late NOV response letter which was due on 01/31/2020. The NOV response was received on 02/13/2020; 13 days late. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	<p>On 07/07/2020, an NOV was issued for exceeding the daily maximum limit for Arsenic due to an effluent violation that occurred on 05/07/2020 during City sampling at the 21741.06 Compliance Sampling Point. All requirements of the NOV were met.</p> <p>On 07/23/2020, an NOV was issued for exceeding the daily maximum limit for Mercury due to effluent violations that occurred on 06/24/2020 during City sampling at the 21741.03 Compliance Sampling Point. All requirements of the NOV were met.</p> <p>On 09/23/2020, an NOV was issued for exceeding the monthly average limit for DEHP due to an average calculated on 08/31/2020. The IU performed sampling twice and did not exceed the daily limit. All requirements of the NOV were met.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Marlyn Nutraceuticals Inc. - Naturally Vitamins, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 4404 East Elwood Street Phoenix Arizona 85040-1909		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 439.47	LIMITS APPENDIX: L	BMR SUBMITTED: 01/2001	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 07/01/2020	PERMIT EXPIRES: 06/30/2025	
SAMPLING LOCATION VERIFIED ON: 11/16/2020		RCRA NOTICE: 04/12/2001		
SLUG CONTROL PLAN EVALUATION DATE: 11/16/2020		COMPLIANCE SAMPLING POINT №: 20485.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	2	0	1
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	04/01/2020	07/02/2020	10/02/2020	01/20/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			K	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Marlyn Nutraceuticals Inc. - Naturally Vitamins, Inc.

Process Flow: 1,574 (GPD) Average

General Information and type of wastewater treatment	<p>This Facility mixes and packages vitamins and supplements.</p> <p>No wastewater treatment is performed prior to discharge.</p>
First Quarter	
Second Quarter	<p>The renewed Class A Wastewater Discharge Permit № 2007-20485 was issued on 06/22/2020, the permit replaces all previously issued Permits and became effective on 07/01/2020 and expires on 06/30/2020.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Mastel Linen, Inc.

Process Flow: 33,949 (GPD) Average

General Information and type of wastewater treatment	<p>Mastel Linen, Inc. is an industrial laundry facility that launders linens from various high end resorts and doctors' offices. All of the washer units are plumbed to drain to a trench drain leading to a pH neutralization process, lint shaker, and then to the compliance sample point. Lint screens are placed within the trench drain to prevent excess lint from entering the pretreatment system. Dry cleaning equipment was added during 2016 with discharges specifically prohibited in the amended permit.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Mayo Clinic Arizona- Mayo Clinic Hospital

Process Flow: 191,738 (GPD) Average

General Information and type of wastewater treatment	<p>This is a large full-service hospital. Wastewater treatment consists of physical separation and stream segregation. Acids that are used in the laboratory are pH neutralized prior to discharge. Current expansions onsite will increase average process flow and a new building will require an additional compliance sampling point.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Mega Metals, LLC.			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 1323 North 22nd Avenue Phoenix Arizona 85009-3714		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 421.306	LIMITS APPENDIX: R	BMR SUBMITTED: 11/30/2012	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 09/01/2018		PERMIT EXPIRES: 08/31/2023	
SAMPLING LOCATION VERIFIED ON: 09/17/2020		RCRA NOTICE: 03/20/2012		
SLUG CONTROL PLAN EVALUATION DATE: 09/17/2020		COMPLIANCE SAMPLING POINT No: 27341.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	0	3	0	0
Number of IU Sampling Days	4	3	3	2
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/08/2020	09/04/2020	10/20/2020	01/31/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Mega Metals LLC.

Process Flow: 7,836 (GPD) Average

General Information and type of wastewater treatment	<p>The facility performs crushes and washes titanium turnings for recycle. Pretreatment consists of wastestream segregation, gravity separation of oils, equalization, clay polymer adsorption and clarification, fabric filtration, pH neutralization, and canister filtration.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

CITY OF PHOENIX SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Metco Metal Finishing, LLC.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 3508 East Corona Avenue Phoenix Arizona 85040-2842		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 06/17/2015	
TTO CERTIFICATION DATE SUBMITTED: 01/27/2021		PERMIT EFFECTIVE: 02/01/2020	PERMIT EXPIRES: 01/31/2025	
SAMPLING LOCATION VERIFIED ON: 12/15/2020		RCRA NOTICE: 06/28/2015		
SLUG CONTROL PLAN EVALUATION DATE: 12/15/2020		COMPLIANCE SAMPLING POINT No: 32746.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	3	4	4	0
Number of IU Sampling Days	5	4	5	4
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	05/08/2020	09/04/2020	10/13/2020	02/07/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)			3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Enforcement Status			N	N			N	N

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Metco Metal Finishing, LLC.

Process Flow: 5,373 (GPD) Average

General Information and type of wastewater treatment	<p>The facility performs caustic cleaning, aluminum anodizing, chromate conversion coating, electroless nickel plating and electroplating of copper, tin, and zinc. Pretreatment consists of stream segregation, metals precipitation, filtration and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Mission Linen Supply, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2652 South 16th Street Phoenix Arizona 85034-6704		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 02/28/1990	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 06/01/2018	PERMIT EXPIRES: 05/31/2023	
SAMPLING LOCATION VERIFIED ON: 06/24/2020		RCRA NOTICE: 02/28/1990		
SLUG CONTROL PLAN EVALUATION DATE: 06/24/2020		COMPLIANCE SAMPLING POINT No: 1780.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	8	7	7	4
Number of IU Sampling Days	4	3	3	4
Number of Parameter Violations	1	0	1	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	I	C
Evaluated as of:	05/13/2020	08/14/2020	11/30/2020	02/12/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	01/29/2020	Grab	City	City	pH	10.7/10.5 S.U.	4
3 rd	Parameter	09/01/2020	Grab	City	City	pH	10.7/10.5 S.U.	8
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A,L	N	A,L	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Mission Linen Supply, Inc.

Process Flow: 142,545 (GPD) Average

General Information and type of wastewater treatment	<p>The facility is a commercial laundry. The facility launders uniforms, linens and various textiles.</p> <p>Wastewater pretreatment consists of hydroxide precipitation, filtration, oil floatation, and pH neutralization.</p>
First Quarter	<p>On 01/29/2020, a Field Notice of Violation (NOV) was issued for a pH violation that occurred during City monitoring with a result of 10.7 S.U., the allowable limitation range is 5.0-10.5 S.U. A TISM was issued on 02/05/2020. All requirements of the NOV were met.</p>
Second Quarter	
Third Quarter	<p>On 09/01/2020, a Field Notice of Violation (NOV) was issued for a pH violation that occurred during City monitoring with a result of 10.7 S.U., the allowable limitation range is 5.0-10.5 S.U. A TISM was issued on 09/10/2020. All requirements of the NOV were met.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Mistras Inspection Services, Inc.

Process Flow: 8,474 (GPD) Average

General Information and type of wastewater treatment	<p>This facility conducts chromate conversion coating, chromic and nitric acid passivation, anodizing, chemical etching, dye penetrant testing, masking, and X-ray testing. Pretreatment consists of stream segregation, hydroxide precipitation, sedimentation, filtration, and pH neutralization.</p>
First Quarter	<p>On 03/13/2020, a Notice of Concern (NOC) was issued for a for a pH exceedance of 11.2 S.U. that occurred on 03/03/2020. The pH sample was taken out of standard operating procedures (SOPs) during City sampling, while effluent discharge was halted, and thus did not qualify as a compliance sample. All requirements of the NOC were met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Modern Industries, Inc.

Process Flow: 16,279 GPD (Average)

General Information and type of wastewater treatment	
Modern Industries performs electropolishing and cleaning of stainless steel parts for the semiconductor industry and anodization, aluminum oxide conversion coating, and electro polish of aluminum aerospace parts. Pretreatment consists of precipitation, settling, dewatering, filtration and pH adjustment.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: MPP Group of Companies

Process Flow: 40,765 (GPD) Average

General Information and type of wastewater treatment	<p>This facility performs anodizing, dyeing, and nickel seal on aluminum parts. The wastewater treatment consists of pH neutralization, collection tanks, clarifier, filter press and an interceptor.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Niagara Bottling, LLC		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 275 South 67th Avenue Phoenix, Arizona 85043-3427		MAILING ADDRESS: 2560 East Philadelphia Street Ontario California 91761-7768		
CATEGORICAL USER?	No	40 CFR	Local Limits	LIMITS APPENDIX: A
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 05/01/2020		PERMIT EXPIRES: 04/30/2025
SAMPLING LOCATION VERIFIED ON: 01/14/2020		RCRA NOTICE: 12/15/2010		
SLUG CONTROL PLAN EVALUATION DATE: 01/14/2020		COMPLIANCE SAMPLING POINT No: 27191.02		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	1	0	0	0
Number of City Sampling Days	4	5	2	0
Number of IU Sampling Days	1	0	3	2
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	1	0	0
Compliance Status	C	I	C	C
Evaluated as of:	04/14/2020	07/21/2020	10/14/2020	01/12/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Permit Condition	06/30/2020	N/A	N/A	N/A	Failure to sample BOD, Copper, Lead, and TSS		
		1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)
Enforcement Status		N		N		A		N

Enforcement Status Codes

A - Notice of Violation (NOV)	F - Assessment of Monetary Penalties	K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year
B - Administrative Order (AO)	G - Restriction of Flow	L - Temporary Increase in IU Self-Monitoring (TISM)
C - Civil Action Filed	H - Permit Revocation	
D - Criminal Action Filed	I - Compliance Schedule Issued	
E - Pretreatment Settlement Agreement (PSA)	J - Disconnection from Sewer	N- No Enforcement Action

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Niagara Bottling, LLC

Process Flow: 218,311 GPD (Average)

General Information and type of wastewater treatment	<p>This facility manufactures bottled drinking water using microfiltration, granulated activated carbon, reverse osmosis and mineral addition. Wastewater treatment consists of pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 08/08/2020, an NOV was issued for IU failure to sample for BOD, Copper, Lead, and TSS during the second quarter of 2020. All requirements of the NOV were met.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: NXP USA, Inc. - 52nd ST Superfund Site - OU 1

Process Flow: 225,765 (GPD) Average

General Information and type of wastewater treatment	<p>NXP USA, Inc. - 52nd Street Superfund Site Operable Unit 1 (OU-1) is a groundwater remediation site. The groundwater is treated by two volatile organic compound air strippers, then run through four liquid phase granular activated carbon (GAC) filters before being discharged. This facility completed construction of a new discharge pipeline to the SRP Old Cross Cut Canal in 2016. This pipeline is used as the primary discharge option for the treated water from the integrated groundwater treatment plant. During the times that SRP will not allow discharge to the canal, the facility will discharge the treated groundwater to the City of Phoenix Sewer system.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Phoenix Children's Hospital		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1919 East Thomas Road Phoenix, Arizona 85016		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 08/28/2002	
TTO CERTIFICATION DATE SUBMITTED: N/A	PERMIT EFFECTIVE: 08/01/2018		PERMIT EXPIRES: 06/30/2022	
SAMPLING LOCATION VERIFIED ON: 12/22/2020		RCRA NOTICE: 02/28/1996		
SLUG CONTROL PLAN EVALUATION DATE: 01/23/2020		COMPLIANCE SAMPLING POINT No: 21169.02, 21169.03, 21169.04, 21169.05		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	2	0	5
Number of IU Sampling Days	2	6	1	1
Number of Parameter Violations	0	1	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	I	C	C
Evaluated as of:	04/30/2020	08/14/2020	12/08/2020	02/18/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Parameter	04/14/2020	Composite	City	IU	Copper Zinc	3.0/1.5 mg/L 4.8/3.5 mg/L	8
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Phoenix Children's Hospital
 Process Flow: 153,549 GPD (Average)

General Information and type of wastewater treatment	<p>This facility is a 360 bed full service hospital specializing in complete care for children to include medical and surgical operations. The wastewater pretreatment consists of two three stage interceptors which collect hospital cafeteria food wastes. There is a sand/oil interceptor for the helipad. Regulated biohazard wastes are contained and shipped off-site for disposal.</p>
First Quarter	<p>.</p>
Second Quarter	<p>On 05/20/2020, an NOC was issue for a Late SMR; the March 2020 SMR was due on 04/28/2020 and submitted 05/11/2020, 13 days late. The Covid-19 pandemic was determined to be the cause of the late submittal and therefore an NOC was issued in lieu of an NOV.</p> <p>On 05/22/2020, an NOV, 30-day resample, and TISM were issued for a copper and zinc exceedance that occurred on 04/14/2020. All requirements of the NOV were met. An NOC was issued on 05/22/2020 for late 24-hour notification of the above exceedances as the Covid-19 pandemic was determined to the cause of the late submittal.</p>
Third Quarter	<p>A review meeting was conducted on 09/22/2020 for numerous late reporting concerns.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Phoenix Indian Medical Center			REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 4212 North 16th Street Phoenix, Arizona 85016-5319		MAILING ADDRESS: Same			
CATEGORICAL USER?	No	40 CFR	Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 12/28/1990
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 02/01/2017		PERMIT EXPIRES: 01/31/2022	
SAMPLING LOCATION VERIFIED ON: 12/09/2020		RCRA NOTICE: 12/28/1990			
SLUG CONTROL PLAN EVALUATION DATE: 12/09/2020		COMPLIANCE SAMPLING POINT No: 2600.02			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0	0	0	1	
Number of City Sampling Days	0	4	0	3	
Number of IU Sampling Days	1	1	1	1	
Number of Parameter Violations	0	0	0	0	
Number of Inspection Violations	0	0	0	0	
Number of Reporting Violations	0	0	0	0	
Number of Permit Cond. Violations	1	0	0	0	
Compliance Status	I	C	C	C	
Evaluated as of:	04/20/2020	07/28/2020	10/26/2020	01/28/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1st	Permit Condition	03/22/2020	N/A	N/A	N/A	Failure to Sample pH		
		1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)			
Enforcement Status		A, K	E, I	N	N			

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Phoenix Indian Medical Center
 Process Flow: 88,845 (GPD) Average

General Information and type of wastewater treatment	<p>This facility is a full service hospital with medical, dental, and surgical operations. Wastewater treatment consists of solids and amalgam separation as well as fats, oils and grease treatment via interceptor.</p>
First Quarter	<p>On 01/02/2020 a Notice to Show Cause was issued as a result of three mercury violations in a 90-day period and SNC status during the 3rd quarter of 2019. On 02/03/2020 a Show Cause Proceeding was held to discuss violations occurring during the enforcement period of 09/01/2019 through 10/30/2019.</p>
Second Quarter	<p>A Pretreatment Settlement Agreement was reached on 04/25/2020 which included a compliance schedule. The requirements of the compliance schedule are currently being met.</p> <p>On 04/30/2020, an NOV was issued for failure to correctly sample and analyze pH during the week of 03/16/2020 through 03/22/2020. All requirements of the NOV were met.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Phoenix Manufacturing, Inc.

Process Flow: 8,427 GPD (Average)

General Information and type of wastewater treatment	<p>Phoenix Manufacturing, Inc. receives raw material in the form of rolls of sheet metal and manufactures evaporative coolers and electrical wiring boxes. The fabrication of the product consists in the rolls being cut, punched, and bent, to form components. The components are spot welded then put through a zinc phosphating process, powder coated, and assembled for shipment. The zinc phosphating process is regulated under 40 CFR 433.15.</p> <p>The wastewater pretreatment consists of metal hydroxide precipitation and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: PMA Photometals of Arizona, Inc. dba PMA Industries of Arizona, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 18008 North Black Canyon Highway Phoenix, Arizona 85053-1715		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 03/19/2020	
TTO CERTIFICATION DATE SUBMITTED: 02/05/2021	PERMIT EFFECTIVE: 05/01/2020	PERMIT EXPIRES: 04/30/2025		
SAMPLING LOCATION VERIFIED ON: 10/23/2020	RCRA NOTICE: 04/24/2020			
SLUG CONTROL PLAN EVALUATION DATE: 10/23/2020	COMPLIANCE SAMPLING POINT No: 46927.01, 46927.02			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	2	1	0	1
Number of City Sampling Days	N/A	1	0	1
Number of IU Sampling Days	N/A	3	3	2
Number of Parameter Violations	N/A	0	1	0
Number of Inspection Violations	N/A	0	0	0
Number of Reporting Violations	N/A	0	1	0
Number of Permit Cond. Violations	N/A	0	0	0
Compliance Status	N/A	C	I	C
Evaluated as of:	04/24/2020	08/14/2020	10/28/2020	02/09/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Reporting	08/08/2020	N/A	N/A	N/A	24-Hour Notification		
3 rd	Parameter	07/17/2020	Composite	City	IU	Selenium (Daily)	0.26/0.10 mg/L	1
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N/A	N	A(2)	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: PMA Photometals of Arizona, Inc. dba PMA Industries of Arizona, Inc.
 Process Flow: 1,206 GPD (Average)

General Information and type of wastewater treatment	<p>PMA Photometals of Arizona, Inc. dba PMA Industries of Arizona, Inc. (PMA) is a manufacturer of photosensitive anodized aluminum, etched metal, screen printed and vinyl products and parts. Regulated manufacturing processes performed onsite include: pumice scrub, panel polishing, developing, etching, stripping, and photo/graphics. Chemical etching performed involves commercial etching and coating of images onto metal through use of iron, sodium chlorate and hydrochloric acid (metal finishing operation under 40 CFR 433). Electrophoretic deposition is the final stage (painting process).</p> <p>Wastewater treatment consists of two systems, WWT System 1 and 2. WWT System 1 receives etching, polishing and developer rinses primarily. Wastewater is collected in a holding and equalization tank, then is treated further in the reactor and neutralizer tanks, flocculator tank, clarifier, final discharge tank, and two filter presses. This wastestream can be reclaimed and recycled using RO treatment. WWT System 2 receives stripper rinses and concentrated developer wastewater. Wastewater is collected and processed in the primary and secondary Developer Treatment Tanks and associated filter press.</p>
First Quarter	
Second Quarter	<p>Class A Wastewater Discharge Permit № 2005-46927 was issued on April 24, 2020 to PMA Photometals of Arizona, Inc. dba PMA Industries of Arizona, Inc. The Permit went into effect on May 1, 2020 and expires on April 30, 2025.</p>
Third Quarter	<p>On 08/07/2020 the IU became aware of a selenium exceedance that occurred on 07/17/2020. The city was not alerted until 08/19/2020, 11 days late. An NOV for Late Reporting – 24 Hour Notification was issued on 09/01/2020, and an NOV for Effluent Limits (Self-Monitoring) was also issued on 09/01/2020. All requirements of the NOVs were met.</p>
Fourth Quarter	<p>On 11/11/2020 a Notice of Concern (NOC) was issued for a prohibited and Unlawful Discharge of Gamma-BHC at 0.01 µg/L.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Prudential Overall Supply				REPORT PERIOD: 01/01/2020 through 12/31/2020					
SERVICE ADDRESS: 5102 West Roosevelt Street Phoenix, Arizona 85043-2716				MAILING ADDRESS: Same					
CATEGORICAL USER?	No	40 CFR:	Local Limits	LIMITS APPENDIX:	A	BMR SUBMITTED:	02/28/1990		
TTO CERTIFICATION DATE SUBMITTED: N/A				PERMIT EFFECTIVE: 06/01/2018		PERMIT EXPIRES: 05/31/2023			
SAMPLING LOCATION VERIFIED ON: 09/11/2020				RCRA NOTICE: 02/28/1990					
SLUG CONTROL PLAN EVALUATION DATE: 09/11/2020				COMPLIANCE SAMPLING POINT №: 1960.02					
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)		
Number of Inspections		0		0		1		0	
Number of City Sampling Days		4		0		4		0	
Number of IU Sampling Days		1		1		1		1	
Number of Parameter Violations		0		0		0		0	
Number of Inspection Violations		0		0		0		0	
Number of Reporting Violations		0		0		0		0	
Number of Permit Cond. Violations		0		0		0		0	
Compliance Status		C		C		C		C	
Evaluated as of:		07/20/2020		08/31/2020		10/24/2020		02/09/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance

If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A, K	N	E, F	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Prudential Overall Supply

Process Flow: 36,013 (GPD) Average

General Information and type of wastewater treatment	<p>The facility is an industrial laundry and launders a variety of articles including shop towels, bar mops, napkins, grill pads, floor mats and industrial uniforms. The wastewater treatment consists of filtration, hydroxide precipitation, flocculation, sedimentation, and pH neutralization.</p>
First Quarter	<p>On 02/13/2020, an NOV was issued for submitting late quarterly sampling results which were due on 11/29/2019. The quarterly sampling results were received on 02/06/2020; 70 days late. All requirements of the NOV were met.</p> <p>On 02/13/2020, a letter was issued notifying the IU of Significant Non-Compliance (SNC) status for 4th Quarter of 2019 for submitting quarterly sampling results 30 or more days past the due date; the laboratory sample results were submitted 70 days late.</p>
Second Quarter	<p>On 06/09/2020 a Notice to Show Cause was issued as a result of a Significantly Non-Compliant late reporting violation.</p>
Third Quarter	<p>On 07/14/2020 a Show Cause Proceeding was held to discuss violations occurring during the enforcement period 10/01/2019 through 02/28/2020. A Pretreatment Settlement Agreement was reached on 09/28/2020 which included monetary penalties of \$4,500. All penalties have been collected during 2020.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 4,550.00 Collected \$ 4,550.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Quantum Global Technology, LLC dba Quantum Clean		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 3925 East Watkins Street, Suite 100 Phoenix, Arizona 85034-7208		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 05/17/2000	
TTO CERTIFICATION DATE SUBMITTED: 01/19/2021	PERMIT EFFECTIVE: 08/01/2020	PERMIT EXPIRES: 07/31/2025		
SAMPLING LOCATION VERIFIED ON: 10/22/2020	RCRA NOTICE: 06/08/2011			
SLUG CONTROL PLAN EVALUATION DATE: 10/22/2020	COMPLIANCE SAMPLING POINT No: 27319.01			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	2	0	3	0
Number of IU Sampling Days	7	9	2	7
Number of Parameter Violations	1	0	1	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	S	C	I	C
Evaluated as of:	07/17/2020	08/25/2020	11/20/2020	02/10/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	03/12/2020	Composite	Federal	City	Total Toxic Organics	23.7718 / 2.130 mg/L	5
3 rd	Parameter	08/26/2020	Composite	Federal	City	Total Toxic Organics	3.660/2.130 mg/L	1
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A, L	A, L	N	A, L		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Quantum Global Technology, LLC dba Quantum Clean
 Process Flow: 1,885 (GPD) Average

General Information and type of wastewater treatment	<p>Quantum Clean performs chemical cleaning and metallic coating of semiconductor manufacturing components. Wastewater generated consists of spent peroxide, acid, caustic, acid scrubber blowdown, ammonium scrubber blowdown, and copper solutions. Spent copper solutions are shipped off-site for treatment and disposal. The other solutions are segregated for batch pretreatment via metals precipitation, filter press dewatering, and pH neutralization.</p>
First Quarter	<p>On 01/21/2020 the City became aware of a daily maximum Total Toxic Organics (TTO) exceedance that occurred during City monitoring on 12/11/2019. An NOV, 30-Day Resample, and TISM were issued on 02/03/2020. All requirements of the NOV were met.</p> <p>A Notice of Concern (NOC) was issued on 02/10/2020 for exceeding the Fluoride Best Management Practice (BMP) target concentration. The discharge to the sewer on 12/11/2019 was 3000 mg/L, exceeding the BMP target concentration of 33.0 mg/L. There are no requirements for this NOC.</p>
Second Quarter	<p>On 05/07/2020 the City became aware of a daily maximum Total Toxic Organics (TTO) exceedance that occurred during City monitoring on 03/12/2020. An NOV, 30-Day Resample, and TISM were issued on 05/13/2020. All requirements of the NOV were met.</p> <p>A Notice of Concern (NOC) was issued on 05/13/2020 for exceeding the Fluoride Best Management Practice (BMP) limit. The discharge to the sewer on 03/12/2020 was 3900 mg/L, exceeding the BMP limits of 33.0 mg/L. All requirements of the NOC were met.</p> <p>A Notice of Concern (NOC) was issued on 05/13/2020 for Prohibited and Unlawful Discharge of a prohibited substance. 4,4' -DDT was discharged to the sewer on 03/12/2020. There are no requirements for this NOC.</p>
Third Quarter	<p>On 07/07/2020 the IU was notified of 1st Quarter Significant Non-Compliance for Daily Maximum Technical Review Criteria (TRC) for the TTO exceedances occurring in December 2019 and March 2020.</p> <p>On 09/29/2020 the City became aware of a daily maximum Total Toxic Organics (TTO) exceedance that occurred during City monitoring on 08/26/2020. An NOV, 30-Day Resample, and TISM were issued on 10/22/2020. All requirements of the NOV were met.</p>
Fourth Quarter	<p>On 12/14/2020 a Notice to Show Cause was issued as a result of the two TTO violations resulting in 1st Quarter 2020 Significant Non-Compliance. The Show Cause Hearing took place on January 12, 2021 and discussed violations occurring during the enforcement period 10/01/2019 through 07/31/2020.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Quantum Global Technologies, LLC				REPORT PERIOD: 01/01/2020 through 12/31/2020			
SERVICE ADDRESS: 2101 West Roosevelt Street Phoenix Arizona 85009-3702				MAILING ADDRESS: 1901 AM Drive, Suite 200 Quakertown, Pennsylvania 18951-6403			
CATEGORICAL USER?	Yes	40 CFR	433.17	LIMITS APPENDIX:	E	BMR SUBMITTED:	01/27/2006
TTO CERTIFICATION DATE SUBMITTED: 01/27/2021				PERMIT EFFECTIVE: 11/01/2016		PERMIT EXPIRES: 10/31/2021	
SAMPLING LOCATION VERIFIED ON: 12/22/2020				RCRA NOTICE: 10/05/2005			
SLUG CONTROL PLAN EVALUATION DATE: 12/22/2020				COMPLIANCE SAMPLING POINT No: 23398.01			
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0		0		0		1
Number of City Sampling Days	1		0		1		0
Number of IU Sampling Days	3		3		3		5
Number of Parameter Violations	0		0		1		2
Number of Inspection Violations	0		0		0		0
Number of Reporting Violations	0		0		0		1
Number of Permit Cond. Violations	0		0		0		0
Compliance Status	C		C		I		I
Evaluated as of:	07/17/2020		08/25/2020		11/20/2020		02/08/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Parameter	09/02/2020	Composite	Federal	IU	Nickel (MAV)	2.6/2.38 mg/L	3
4 th	Reporting	10/15/2020	N/A	N/A	N/A	24-Hour Notification		
4 th	Parameter	11/04/2020	Composite	Federal	IU	Chromium (Daily)	3.7/2.77 mg/L	4
4 th	Parameter	11/30/2020	Composite	Federal	IU	Chromium (MAV)	3.7/1.71 mg/L	3
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	A (2)		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Quantum Global Technologies, LLC

Process Flow: 487 (GPD) Average

General Information and type of wastewater treatment	<p>This facility performs semiconductor and aerospace equipment / parts cleaning using abrasive blasting and chemical cleaning consisting of acid and caustic solutions. Pretreatment consists of precipitation, settling, dewatering, filtration and pH adjustment.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	<p>On 11/25/2020, NOVs were issued for nickel effluent and late 24-Hour Notification violations. On 10/27/2020 the City became aware of a monthly average nickel exceedance that occurred on 09/02/2020. The IU became aware of the effluent exceedance on 10/14/2020 and should have reported to the City no later than 10/15/2020. The City was notified of the exceedance on 10/27/2020, 12 days late. All requirements of the NOVs were met.</p> <p>On 12/22/2020 the City became aware of a daily maximum and a monthly average limits exceedance for Chromium. An NOV, 30-Day Resample, and TISM were issued on 01/6/2021. Completion of NOV requirements is still pending.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Rexam Beverage Can Company			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE 211 North 51st Avenue ADDRESS: Phoenix, Arizona 85043-3704			MAILING ADDRESS: Same	
CATEGORICAL USER? Yes	40 CFR	465.45	LIMITS APPENDIX: J	BMR SUBMITTED: 07/27/1987
TTO CERTIFICATION DATE SUBMITTED: N/A			PERMIT EFFECTIVE: 10/01/2017	PERMIT EXPIRES: 09/30/2022
SAMPLING LOCATION VERIFIED ON: 03/10/2020			RCRA NOTICE: 02/27/1991	
SLUG CONTROL PLAN EVALUATION DATE: 03/10/2020			COMPLIANCE SAMPLING POINT No: 5475.01	
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	1	0	0	0
Number of City Sampling Days	4	4	4	0
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	04/27/2020	08/04/2020	10/09/2020	01/11/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none"> A - Notice of Violation (NOV) B - Administrative Order (AO) C - Civil Action Filed D - Criminal Action Filed E - Pretreatment Settlement Agreement (PSA) | <ul style="list-style-type: none"> F - Assessment of Monetary Penalties G - Restriction of Flow H - Permit Revocation I - Compliance Schedule Issued J - Disconnection from Sewer | <ul style="list-style-type: none"> K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year L - Temporary Increase in IU Self-Monitoring (TISM) N- No Enforcement Action |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Rexam Beverage Can Company

Process Flow: 62,680 (GPD) Average

General Information and type of wastewater treatment	<p>Rexam Beverage Can Americas manufactures two-piece beverage cans from aluminum coil stock. In lieu of sampling for TTO's, the facility monitors for Oil and Grease using EPA method 1664A - SGT-HEM, as delineated in 40 CFR 465.03(c). The wastewater treatment consists of oil and grease gravity separation, stream segregation, lime addition, hydroxide precipitation, filtration, dewatering, and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 08/14/2020, a Notice of Concern (NOC) was issued for the submission of a late self monitoring report (SMR) which was due on 07/28/2020. The SMR was received on 08/04/2020; 7 days late. An NOC was issued in lieu of an NOV due to Covid-19 concerns.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Safeway, Inc. Phoenix Ice Cream Plant

Process Flow: 66,039 GPD (Average)

General Information and type of wastewater treatment	<p>This facility manufactures and packages ice cream from raw bulk products. Wastewater pretreatment consists of physical separation and pH adjustment. Waste product is shipped off-site for animal (hog) feed.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Sagamore Camelback, LLC.

Process Flow: 11,194 (GPD) Average

General Information and type of wastewater treatment	<p>A dewatering system is continuously operated to ensure proper management of the 5-level subsurface parking garage as rising groundwater elevations intersect the parking levels. Previously contaminated groundwater from the dewatering wells, combined with accumulated stormwater and hand sinks is no longer treated as of 2017 but simply discharged through the sampling point.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Sav-On Plating, Inc.
 Process Flow: 15,704 (GPD) Average

General Information and type of wastewater treatment	Sav-On Plating performs chromate conversion coating, alkaline zinc and cadmium plating using barrel and rack plating methods. Pretreatment processes consist of stream segregation, chemical reduction, hydroxide precipitation, dewatering, and pH neutralization.
First Quarter	
Second Quarter	
Third Quarter	A renewed Class A Wastewater Discharge Permit № 2008-5300 was issued on 07/15/2020, the permit replaces all previously issued Permits and became effective on 08/01/2020 and expires on 07/31/2020.
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Shamrock Foods Company-Dairy Division			REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2228 North Black Canyon Highway Phoenix, Arizona 85009-2707		MAILING ADDRESS: Same			
CATEGORICAL USER?	No	40 CFR	Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: N/A
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 05/01/2018		PERMIT EXPIRES: 04/30/2023	
SAMPLING LOCATION VERIFIED ON: 12/04/2020		RCRA NOTICE: 02/28/1990			
SLUG CONTROL PLAN EVALUATION DATE: 12/04/2020		COMPLIANCE SAMPLING POINT No: 2090.05			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	1	0	0	1	
Number of City Sampling Days	4	4	3	3	
Number of IU Sampling Days	6	6	7	8	
Number of Parameter Violations	0	0	0	0	
Number of Inspection Violations	0	0	0	0	
Number of Reporting Violations	0	0	0	0	
Number of Permit Cond. Violations	1	0	0	0	
Compliance Status	I	C	C	C	
Evaluated as of:	04/30/2020	07/20/2020	10/27/2020	01/26/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Permit Condition	02/24/2020	N/A	N/A	N/A	Failure to Maintain Pretreatment Equipment		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Shamrock Foods Company-Dairy Division

Process Flow: 600,792 (GPD) Average

General Information and type of wastewater treatment	<p>The facility processes milk into sour cream, cottage cheese, skim milk, 2% milk, and whole milk along with specialty protein and flavored or seasonal products. The facility also makes orange juice from concentrate, non-dairy creamer, and bottles one gallon jugs of filtered water. Products are segregated via two plants called the High Temperature – Short Term Plant (HTST) and the Extended Shelf Life (ESL) Plant. There is a blow mold for plastic bottle creation as well onsite. Wastewater pretreatment consists of gravity separation, Dissolved Air Flootation (DAF) and pH adjustment.</p>
First Quarter	<p>On 02/24/2020, an NOV was issued for IU Failure to Maintain Pretreatment Equipment as a result of a tank on-site overflowing with wastewater and solids. All requirements of the NOV were met.</p>
Second Quarter	<p>On 04/03/2020, an Amended Review Meeting Letter was issued in order to discuss the Failure to Maintain Pretreatment Equipment NOV that was issued on 02/24/2020.</p> <p>On 06/02/2020, the Review Meeting took place with IPP staff and facility representatives from Shamrock Foods Company – Dairy Division. As a result of the Review Meeting, the facility is required to provide monthly pretreatment upgrade updates.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Signetix, Inc.

Process Flow: 4,319 (GPD) Average

General Information and type of wastewater treatment	<p>The facility process consists of immersing a substratum metal into a phosphate cleaning solution, rinsing the metal and applying a powder coating. Rinsate wastewater generated from the cleaning process is pH neutralized prior to discharge.</p>
First Quarter	<p>On 01/14/2020 a Show Cause Proceeding was held to discuss violations occurring during the enforcement period 04/01/2019 through 09/30/2019. A Pretreatment Settlement Agreement was reached on 04/06/2020 which included monetary penalties of \$3,184 and a compliance schedule. All of the monetary penalties have been collected during 2020 and the requirements of the compliance schedule are in the process of being met.</p>
Second Quarter	
Third Quarter	
Fourth Quarter	<p>On 01/25/2021 an NOC was issued for exceeding the Best Management Practices (BMP) target concentration of 0.38 mg/L on multiple occasions during 2020 for molybdenum. There were no requirements associated with the NOC.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 3,184.00 Collected \$ 3,184.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Sky Chefs, Inc. – LSG Sky Chefs		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 3555 South 28 th Street Phoenix, Arizona 85040-8603		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: N/A	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 11/01/2020	PERMIT EXPIRES: 03/31/2024	
SAMPLING LOCATION VERIFIED ON: 07/29/2020		RCRA NOTICE: 04/15/2019		
SLUG CONTROL PLAN EVALUATION DATE: 07/29/2020		COMPLIANCE SAMPLING POINT No: 46461.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	0	2	0	0
Number of IU Sampling Days	1	1	2	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	1	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	04/22/2020	07/22/2020	10/08/2020	01/14/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Reporting	03/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			E, F, A	A	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Sky Chefs, Inc.

Process Flow: 3,845 GPD (Average)

General Information and type of wastewater treatment	<p>The facility prepares and processes food for commercial airlines and convenience stores.</p> <p>Pretreatment consists of physical separation via a grease interceptor and a pH neutralization tank.</p>
First Quarter	<p>A Pretreatment Settlement Agreement was reached on 03/06/2020 which included monetary penalties of \$66,973.32 and a compliance schedule. The penalties were collected in the 1st Quarter of 2020 and requirements of the compliance schedule are in the process of being met.</p> <p>On 01/15/2020 the City issued an NOV for the two instances of pH excursions that occurred on 12/24/2019 and were reported on 12/26/2019. The IU continuously monitors pH so a 30-day Resample and TISM were not necessary. The IU met all requirements.</p>
Second Quarter	<p>On 04/08/2020, an NOV was issued for submitting a late self-monitoring report which was due on 03/28/2020. The SMR was received on 04/06/2020; 9 days late. All requirements of the NOV were met.</p>
Third Quarter	
Fourth Quarter	<p>On 10/21/2020, the Amended Class A Wastewater Discharge Permit 2011-46461 was mailed out. The Permit became effective on 11/01/2020 and expires on 03/31/2024.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 66,973.32 Collected \$ 66,973.32

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Southwest Orthopedic and Spine Hospital, LLC. – OASIS Hospital		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 750 North 40 th Street Phoenix, Arizona 85008-6486		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 01/28/2018	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 08/01/2020	PERMIT EXPIRES: 07/31/2025	
SAMPLING LOCATION VERIFIED ON: 11/13/2020		RCRA NOTICE: 07/01/2019		
SLUG CONTROL PLAN EVALUATION DATE: 11/13/2020		COMPLIANCE SAMPLING POINT №: 29573.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	N/A
Number of City Sampling Days	0	4	0	N/A
Number of IU Sampling Days	1	1	2	N/A
Number of Parameter Violations	0	0	0	N/A
Number of Inspection Violations	0	0	0	N/A
Number of Reporting Violations	0	0	0	N/A
Number of Permit Cond. Violations	0	0	0	N/A
Compliance Status	C	C	C	N/A
Evaluated as of:	07/17/2020	08/25/2020	11/20/2020	N/A

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N/A		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Southwest Orthopedic and Spine Hospital, LLC. – OASIS Hospital

Process Flow: 9,983 GPD (Average)

General Information and type of wastewater treatment	<p>Southwest Orthopedic and Spine Hospital, LLC. – OASIS Hospital is a surgical hospital that offers specialized services, including orthopedic procedures, total joint replacement, and sports medicine. Pretreatment consists of a 3000 Gallon Grease Interceptor.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 07/16/2020, a Notice of Concern was issued for Permit Conditions – Prohibited and Unlawful Discharge. The discharge to sewer exceeded the reporting limit of 0.0 µg/L for the parameter gamma-BHC on 06/23/2020 at a concentration of 0.08 µg/L. There are no requirements for this NOC.</p> <p>Southwest Orthopedic and Spine Hospital, LLC. – OASIS Hospital was reclassified from a Class A to a Class B type Permit. The Class A Wastewater Discharge Permit № 1907-29573 was terminated on 7/31/2020 and the new Class B Wastewater Discharge Permit № 2008-29573 went into effect on 08/01/2020. The Southwest Orthopedic and Spine Hospital, LLC. – OASIS Hospital average and maximum wastewater discharge flows from July 2019 through May 2020 decreased from original submitted baseline flows to the extent that the facility is no longer considered a Significant Industrial User.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Specialty Textile Services

Process Flow: 56,272 (GPD) Average

General Information and type of wastewater treatment	
Specialty Textile is a commercial laundry which launders linens from resort hotels and restaurants. Pretreatment consists of gravity separation for lint and pH neutralization.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: StandardAero Aviation Holdings Inc. (formerly PAS Technologies)		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1021 North 22 nd Avenue Phoenix, Arizona 85009-3717		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 433.17	LIMITS APPENDIX: E	BMR SUBMITTED: 05/05/2006	
TTO CERTIFICATION DATE SUBMITTED: 01/26/2020		PERMIT EFFECTIVE: 04/03/2020	PERMIT EXPIRES: 03/31/2025	
SAMPLING LOCATION VERIFIED ON: 08/10/2020		RCRA NOTICE: 05/24/2006		
SLUG CONTROL PLAN EVALUATION DATE: 08/10/2020		COMPLIANCE SAMPLING POINT No: 23571.02, 23571.03		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	3	1	3	1
Number of IU Sampling Days	4	7	4	10
Number of Parameter Violations	0	0	0	1
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	1
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	I
Evaluated as of:	05/08/2020	09/04/2020	12/03/2020	02/08/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
4 th	Parameter	10/01/2020	Composite	City	City	Cadmium (Daily)	0.0698/0.047 mg/L	9
4 th	Reporting	11/21/2020	N/A	N/A	N/A	Late Sample Results		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	A		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: StandardAero Aviation Holdings Inc.

Process Flow: 18,220 (GPD) Average

General Information and type of wastewater treatment	<p>This facility performs chrome electroplating, sulfuric acid anodize, nickel seal, chrome conversion coating, passivation and electroless nickel plating of aerospace and commercial market metal components. Pretreatment consists of stream segregation, hydroxide precipitation, chemical reduction, sedimentation, filtration and pH neutralization. The facility recently added a new sampling point for the cyanide/cadmium destruction unit used to treat cyanide wastewater.</p>
First Quarter	
Second Quarter	<p>Class A Wastewater Discharge Permit No. 2004-23571 was renewed on 04/03/2020 with an expiration of 03/31/2025 and incorporated the name change from PAS Technologies to StandardAero Aviation Holdings Inc. among other additions.</p>
Third Quarter	
Fourth Quarter	<p>On 10/16/2020 the City became aware of a daily cadmium exceedance that occurred on 10/01/2020 during City sampling. An NOV with 30-day resample and TISM requirements was issued on 10/29/2020. The 30-day resample was submitted late; it was due on 11/20/2020 and was not submitted until 12/28/2020, 38 days late. On 01/14/2021, an NOV for late reporting of sample results was issued. All requirements of the NOV were met.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: SUMCO Southwest Corporation		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS:	19801 North Tatum Boulevard Phoenix, Arizona 85050-4201	MAILING ADDRESS: Same		
CATEGORICAL USER?	Yes	40 CFR 469.28	LIMITS APPENDIX: T	BMR SUBMITTED: 03/27/1997
TTO CERTIFICATION DATE SUBMITTED:	08/25/2020	PERMIT EFFECTIVE:	03/01/2017	PERMIT EXPIRES: 02/28/2022
SAMPLING LOCATION VERIFIED ON:	08/18/2020	RCRA NOTICE: 01/16/1997		
SLUG CONTROL PLAN EVALUATION DATE:	08/25/2020	COMPLIANCE SAMPLING POINT No: 5340.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	7	5	0	3
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	07/20/2020	08/31/2020	11/30/2020	02/10/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: SUMCO Southwest Corporation

Process Flow: 934,992 (GPD) Average

General Information and type of wastewater treatment	<p>The facility grows, cuts, etches, and polishes silicon crystals. SUMCO treats three separate waste streams:</p> <ol style="list-style-type: none"> 1. All etchants which include fluoride, peroxide and silicon dioxide/cleaning wastes discharge continuously and flow through a series of equalization and pH adjustment tanks called the Acid Waste Neutralization (AWN) system which then flows to the compliance sample point. 2. Chromium bearing wastes are treated in batches and are gravity fed to a series of tanks which include equalization tank, metals precipitation tank, pH adjustment and a filter press. The liquids from the filter press are sent to the AWN system and then flows to the compliance sample point. The settled solids from the filter press are stored in a drum for shipment to an off-site disposal/recycling facility. 3. Water is used to cool vacuum pumps during the silicon growing process and act as a water curtain to remove particulates from the airstream which protect the pumps. These wastewaters are collected in a holding tank and treated for arsenic. Wastewaters are pumped to a series of tanks which include coagulation, pH adjustment, clarification and dewatering. The settled solids from the dewatering are stored in a drum for disposal off site.
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Sumitomo Chemical Advanced Technologies, LLC.

Process Flow: 963 GPD (Average)

General Information and type of wastewater treatment	<p>Sumitomo Chemical Advanced Technologies, LLC. (Sumitomo) is a custom Gallium Arsenide epitaxial wafer manufacturing facility. The III-V Division in Phoenix, AZ provides GaAs, AlGaAs, InGaP, InGaAs, InAlAs, and InP epitaxial services for fiber optic. Digital communication and wireless applications. Sumitomo manufactures custom wafers for the compound semiconductor market. Compound semiconductor epitaxial wafers are used in a variety of commercial applications including: wireless communications, LED manufacturing, and solar energy conversion. Sumitomo uses Metalorganic Chemical Vapor Deposition (MOCVD) to apply epitaxial layers onto gallium arsenide wafers.</p> <p>Wastewater from Arsenic contaminated metal parts cleaning, process area containment sumps, and bleed-off from wet air scrubbers for Arsenic process and Metal Organic Chemical Vapor Deposition process are conveyed to a batch pretreatment system consisting of an equalization tank, metal hydroxide reaction and precipitation tank, sludge tank, filter press, arsenic ion exchange adsorption system, and pH neutralization before discharging to sewer at compliance sampling point.</p>
First Quarter	
Second Quarter	<p>On 04/14/2020, Class A Wastewater Discharge Permit 2004-21502 was mailed out with an effective date of 04/14/2020 and an expiration date of 02/28/2025.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: The Proctor & Gamble Manufacturing Company

Process Flow: 30,875 (GPD) Average

General Information and type of wastewater treatment	This facility manufactures a natural fiber laxative (Metamucil). Pretreatment consists of physical separation and pH neutralization.
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Unifirst Corporation

Process Flow: 73,481 (GPD) Average

General Information and type of wastewater treatment	<p>The facility is an industrial laundry. They launder uniforms and various textiles. Wastewater pretreatment consists of segregation of wastestreams, oily waste removal, flocculation, dissolved air flotation, and pH neutralization.</p>
First Quarter	
Second Quarter	
Third Quarter	<p>On 8/14/2020, an NOC was issued for submitting a late self-monitoring report which was due on 07/28/2020. The SMR was received on 07/31/2020; 3 days late. However, due to Covid -19 related issues, an NOC was issued in lieu of an NOV.</p>
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Upper Crust Bakery			REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 3655 West Washington Street Phoenix, Arizona 85009-4759		MAILING ADDRESS: Same		
CATEGORICAL USER?	No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 05/15/2017
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 10/01/2018	PERMIT EXPIRES: 05/31/2022	
SAMPLING LOCATION VERIFIED ON: 12/14/2020		RCRA NOTICE: 06/02/2017		
SLUG CONTROL PLAN EVALUATION DATE: 12/14/2020		COMPLIANCE SAMPLING POINT No: 33224.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	1	0	0	1
Number of City Sampling Days	3	0	4	2
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	1	1	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	1	0	0
Number of Permit Condition Violations	4	0	0	0
Compliance Status	I	I	C	C
Evaluated as of:	04/24/2020	07/28/2020	10/27/2020	01/08/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Parameter	01/01/2020	Grab	City	IU	pH (Instant.)	12.08/10.5 SU	Continuous
1 st	Permit Condition	03/02/2020 & 03/03/2020	N/A	N/A	N/A	PCC 28-8 (c)		
1 st	Permit Condition	03/02/2020 & 03/03/2020	N/A	N/A	N/A	PCC 28-45(b)		
2 nd	Parameter	05/23/2020	Grab	City	IU	pH (Instant.)	13.78/10.5 SU	Continuous
2 nd	Reporting	06/29/2020	N/A	N/A	N/A	Late SMR		
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A(3), K	N	A(2)	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Upper Crust Bakery
 Process Flow: 34,610 (GPD) Average

General Information and type of wastewater treatment	<p>This facility produces baked goods including muffins, breads, scones, croissants, and cakes. The facility recently upgraded to a pretreatment system that includes pH neutralization and a new grease interceptor. Grease and solids retention have become a concern at the facility and the facility is investigating additional pretreatment options including more frequent deep clean-outs/pumping of the entire system.</p>
First Quarter	<p>On 01/02/2020 the City became aware of a continuous pH excursion occurring on 01/01/2020. The excursion lasted 456 minutes, with a maximum reading of 12.08 S.U. An NOV was issued on 01/07/2020. The IU met all requirements.</p> <p>On 03/03/2020 the City became aware of two reported Sanitary Sewer Overflows (SSOs) that occurred on 03/02/2020 and 03/03/2020. These were caused by a buildup of large quantities of a viscous substance containing yeast, fats and oils downstream of the IU. The IU is in violation of Phoenix City Code Section 28-8(c) and permit conditions prohibiting unlawful discharge of solid or viscous pollutants that may cause obstruction to the flow in sewers. In addition, the IU is in violation of PCC Section 28-45(b) requiring IUs to provide pretreatment necessary to comply with pretreatment requirements. NOV's were issued on 03/06/2020 and 03/10/2020 for the above violations occurring on both days. The IU is currently implementing changes to pretreatment and processes to alleviate the harm to Sewer.</p>
Second Quarter	
Third Quarter	<p>On 05/23/2020 the City became aware of a continuous pH excursion occurring on 05/23/2020. The excursion lasted 46 minutes, with a maximum reading of 13.78 S.U. An NOV was issued on 07/15/2020. The IU met all requirements.</p> <p>On 07/15/2020, an NOV was issued for submitting a late self-monitoring report which was due on 06/28/2020. The SMR was received on 06/29/2020, 1 day late. All requirements of the NOV were met.</p>
Fourth Quarter	<p>On 10/12/2020 the City became aware of a continuous pH excursion occurring on 10/11/2020. The excursion lasted 8 minutes, with a maximum reading of 12.225 S.U. Since the IU met all criteria for a pH waiver, a pH waiver was granted in lieu of an NOV.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No
 Penalties this reporting Year: Assessed \$0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Valleywise Health Behavioral Center - Maryvale Campus

Process Flow: 50,682 GPD (Average)

General Information and type of wastewater treatment	<p>Valleywise Health Behavioral Center - Maryvale Campus opened their renovated hospital in 2020 with a 24/7 Emergency Department that includes radiology, ultrasounds, computerized tomography (CT), laboratory and pharmacy services and a Behavioral Health Unit that provides inpatient mental health services for court-ordered psychiatric evaluation and treatment.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Maricopa Integrated Health System

Process Flow: 127,774 GPD (Average)

General Information and type of wastewater treatment	<p>This is a large, full service hospital and medical complex. Wastewater treatment is a three stage interceptor after the cafeteria and physical separation.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Vital Pharmaceuticals, Inc. dba Bang Energy

Process Flow: 30,146 GPD (Average)

General Information and type of wastewater treatment	<p>Vital Pharmaceuticals, Inc. dba Bang Energy was founded in 1993 and manufactures sports supplements, performance beverages and nutrition products including a variety of energy drinks, protein powder, supplements and multivitamins. The Phoenix facility is dedicated to beverage production including ultrafiltration and reverse osmosis (RO) treatment, sodium hypochlorite destruction, ozone disinfection and destruction, dry/powder product mixing, and flavor blending. Pretreatment consists of pH neutralization using sulfuric acid and sodium hydroxide.</p>
First Quarter	
Second Quarter	<p>Class A Wastewater Discharge Permit № 2007-32346 was issued on June 17, 2020 to Vital Pharmaceuticals, Inc. dba Bang Energy. The Permit went into effect on July 1, 2020 and expires on June 30, 2025.</p>
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF PHOENIX
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: World Resources Company		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 8113 West Sherman Street Tolleson Arizona 85353-4025		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 12/07/1998	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 04/01/2017	PERMIT EXPIRES: 03/31/2022	
SAMPLING LOCATION VERIFIED ON: 06/03/2020		RCRA NOTICE: 12/16/2001		
SLUG CONTROL PLAN EVALUATION DATE: 06/03/2020		COMPLIANCE SAMPLING POINT No: 5404.01		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	1
Number of City Sampling Days	2	1	2	1
Number of IU Sampling Days	10	4	2	8
Number of Parameter Violations	0	0	1	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	I	C
Evaluated as of:	04/30/2020	07/27/2020	10/27/2020	01/28/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
3 rd	Parameter	08/12/2020	Composite	City	City	Cadmium	0.0508 mg/L / 0.047 mg/L	2
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	A		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: World Resources Company

Process Flow: 39,843 (GPD) Average

General Information and type of wastewater treatment	<p>The facility receives metal-laden waste sludge from off site and performs material blending and compounding, solar, and thermal drying, and product formulating.</p> <p>The pretreatment process consists of hydroxide precipitation, flocculation, sedimentation, ion exchange and pH adjustment.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	<p>On 10/09/2020, an NOV was issued for Effluent Limits (City-Monitoring) for an exceedance of the parameter Cadmium that took place during City-Monitoring on 08/12/2020. All requirements of the NOV were met.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

SECTION 2.4
CITY OF SCOTTSDALE

POTW PRETREATMENT ANNUAL REPORT

CITY OF SCOTTSDALE, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 91st Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020524

Person to Contact Concerning City of Scottsdale Information Contained in the Report:

Carie Wilson
Water Quality Manager
8787 East Hualapai Drive, PO Box 25089
Scottsdale, Arizona 85255-0176
480-312-8732

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all CITY OF SCOTTSDALE attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

1-27-2021

Date



Brian K. Biesemeyer
Executive Director

Water Resources Division, City of Scottsdale, Arizona



INTRODUCTION

2020 Annual Report

City of Scottsdale Water Resources – Industrial Pretreatment

Located in the Salt River Valley in central Arizona, Scottsdale is known for its art galleries, specialty shops, golf courses, restaurants, resorts, and nightlife. It is also a popular retirement and tourist community and features numerous cultural activities throughout the year.

In 1888, U.S. Army Chaplain Winfield Scott visited the Salt River Valley, was impressed with its potential, and subsequently made a down payment on 640 acres to start a farming operation at \$3.50 per acre. Scott's purchase, near the heart of present-day downtown Scottsdale, would be the impetus for the development of the city that bears his name.

On June 25, 1951, with a population of about 2,000 living within an area of less than a square mile, the town incorporated. Malcolm White was appointed its first mayor, and Scottsdale adopted "The West's Most Western Town" as its official motto. The following decades brought even more growth in population and land area, as the city pushed northward into the high Sonoran Desert and experienced several building booms. By 1980, its population of more than 88,000 covered 88.6 square miles. By 1990, it had reached more than 130,000 in population and expanded to roughly its present size – about 185 square miles. By 2000, the city was home to more than 202,000. As of 2019, the estimated population was 255,310.

Scottsdale Water is full-service water utility, providing water, sewer and recycled water services. Following Scottsdale Water's vision of *water sustainability through stewardship, innovation and people*, Scottsdale Water has won several prestigious awards including the Association of Metropolitan Water Agencies' Sustainable Water Utility Management Award (2018) – the highest industry recognition conferred to municipal water agencies. In 2019, Scottsdale Water was recognized with Arizona Forward's Sustainability Champion Crescordia Award, which recognizes an organization or program that has created a culture of sustainability both in their organization and the community, demonstrated a meaningful impact in advancing sustainable programs, and serves as a model for environmental leadership. The utility also received the EPA's Utility of the Future Today designation (2016) and Scottsdale Water's Citizens Academy was named Public Education Program of the Year in 2017 by the WaterReuse Association. The biannual, multiweek Citizens Academy provides residents and stakeholders an inside look at all facets of Scottsdale Water's operations and programs. A key part of the academy focuses on Scottsdale's water reclamation program with a tour inside the Advanced Water Treatment facility, widely recognized as one of the world's

most innovative water purification projects. Scottsdale Water's Advanced Water Treatment plant is one of the most sophisticated indirect potable reuse facilities in the world, recharging an average of 1.7 billion gallons of purified recycled water into the aquifer annually, and received the state's first direct potable reuse permit in 2019. Through recharge efforts at the Advanced Water Treatment Facility, Scottsdale was the first city in Arizona to achieve safe yield – pumping more water into the aquifer than it takes out. Scottsdale first achieved this significant accomplishment in 2006 and has done so every year since.

The city is governed by a mayor and a city council, all of who are elected “at large” to represent the entire city. A city manager is responsible for the executive leadership of the city staff, as well as implementing council policies, developing programs and budgets to respond to council goals, and ensuring the citizens receive effective and efficient services.

Scottsdale Water's Industrial Pretreatment Program was approved by the US Environmental Protection Agency in 1983, and presently holds permits with one non-significant industrial user and four significant industrial users (SIUs) that are sampled and inspected regularly. The Pretreatment group also manages an inspection program for food service establishments and automotive service/repair facilities to ensure compliance with local and federal regulations and help prevent pollution from entering the environment.



POLLUTION PREVENTION PROGRAM SUMMARY

2020 Annual Report

City of Scottsdale Water Resources – Industrial Pretreatment

INTRODUCTION

Through its Industrial Pretreatment Program, the city of Scottsdale works to reduce or eliminate pollution at its source by implementing a Pollution Prevention Program. Reducing the amount of pollution that enters the collections system means there is less waste to control, treat, or dispose of at the treatment plant, resulting in lower risk to public health and the environment. Scottsdale Water continues to participate with the Sub-Regional Operating Group (SROG) cities on a cooperative basis to implement Pollution Prevention and Best Management Practice (BMP) procedures and techniques.

POINT SOURCE CONTROL PROGRAMS

LOCAL LIMITS

Monthly samples at the Princess meter station, where wastewater is discharged from Scottsdale at its southern boundary, were collected by city of Phoenix. The city of Scottsdale collected split samples in cooperation with Liberty Utilities at the Dove Valley meter station, located at the northernmost wastewater service boundary of Scottsdale.

Data collected during these sampling events was used in the determination of allowable discharge limitations of process wastewater from industrial and commercial users that make use of the municipal sanitary system. The city's Industrial Pretreatment Program regulates permitted industrial user facilities based upon the local limits established by SROG.

PERMITTED SIU PROGRAM

Scottsdale Water staff sampled the wastestream(s) of all permitted Significant Industrial Users (SIU) on a quarterly basis during the year. As a condition of the industrial wastewater permit, all SIUs must submit quarterly self-monitoring reports to the city to verify compliance with federal, categorical, and/or local pretreatment discharge limits. In typical years, Scottsdale Water's Industrial Pretreatment staff conducts at least one inspection at every permitted facility. In 2020, due to the Covid-19 pandemic, select facilities requested to postpone the annual inspection, a practice that EPA recommended as a measure to protect the health and safety of inspectors, the regulated community, and the public.

FOOD SERVICE ESTABLISHMENTS (FOG PROGRAM)

The Pretreatment group monitors grease traps and interceptors at 1,068 food service establishments (FSE) through its Fats, Oils, and Grease (FOG) program to ensure adequate pumping frequencies are met to protect the city's collections system. In 2020, a total of 2,341 inspections were performed at FSEs, including bars, hotels, night clubs, and golf courses. Inspectors perform visual checks of the grease capturing device, review recent pumping manifests, and discuss kitchen best management practices (BMP) that should be utilized to reduce wastes from entering the collections system.

AUTOMOTIVE SERVICE & REPAIR FACILITIES (POG PROGRAM)

There are 149 automotive service and/or repair shops that have sand/oil separators in Scottsdale, and each of these facilities is inspected at least annually to ensure compliance with local ordinances. Pretreatment staff completed 273 Petroleum, Oils, and Grease (POG) inspections, which include a visual check of the interceptor and a review of recent pumping manifests. Inspectors also review automotive shop BMPs with staff and distribute educational materials when appropriate.

INDUSTRIAL WASTE SURVEYS

Scottsdale Water works to identify new businesses that may have the potential to impact the POTW, based on the type of business they conduct and any site-specific concerns that are observed. Such facilities are added to the database and if upon the initial visit the inspector finds a reason to return for routine inspection, the facility is put on a routine, annual inspection cycle. Surveys include a walkthrough of inside spaces to identify any processes in place, chemicals used/stored, locations and quantity of drains and an inspection of outdoor areas to identify potential stormwater concerns. In 2020, the Pretreatment group performed inspections at 81 commercial facilities and entered the information into a database to track compliance and schedule future inspections.

EDUCATIONAL SOURCE CONTROL PROGRAMS

The city of Scottsdale currently promotes educational source control through the city's Pollution Prevention Program, which includes the Water Resources Citizens Academy for residents and stakeholders, Household Hazardous Waste Program, Electronic Recycling Waste Collection Program, Waste Minimization Program, and the Curbside Recycling Program. Through these educational programs large amounts of waste materials including toxic chemicals have been diverted from normal waste streams such as the municipal sewer or local landfill. All disposal and recycling is handled by licensed contractors and facilities.

COMMUNITY OUTREACH/EDUCATION

In typical years, Water Quality staff participates in several outreach events to educate the public on pollution prevention topics. Due to the Covid-19 pandemic, all major events were canceled in 2020 and therefore, large-scale outreach attempts could not be made. Education continued to be provided to business owners during routine inspections, as described above.

ENVIRONMENTAL ADVISORY COMMISSION

The Environmental Advisory Commission is a City Council appointed group whose purpose is to advise the Council on issues related to preservation and enhancement of the local environment. The city of Scottsdale has taken every opportunity to establish community participation programs in which citizens can become involved. Boards, commissions, and committees in various area of interest have been organized for residents to take an active role in their city government. The Environmental Advisory Commission provides guidance on the prioritization of current and future environmental activities and recommends environmental policies to the City Council.

EDUCATIONAL PUBLICATIONS AND WEBSITES

The city distributes several publications to help educate residents and employees on environmental issues and current environmental-related events. The information is also made available on departmental websites pertaining to Pollution Prevention and related information.

Educational Publications that Include Pollution Prevention Topics		
Publication	Format	Distribution
CityLine	Weekly Newsletter	E-Mailed to Scottsdale employees
Scottsdale Update	Weekly Newsletter	E-mailed to subscribers (employees and the public)
Environmental eNews	Periodic Newsletter	E-mailed to subscribers (employees and the public)
Pipeline: Scottsdale Water News	Departmental Website	www.scottsdaleaz.gov/water
Revised Scottsdale Code	Departmental Website	https://www.municode.com/library/az/scottsdale/codes/code_of_ordinances

CITY OF SCOTTSDALE

SUMMARY OF PRETREATMENT PROGRAM EXPENDITURES

January 1, 2020 – December 31, 2020 – Total Pretreatment Expenditures **\$367,482**

PRETREATMENT PROGRAM PERSONNEL

<u>Title</u>	<u>FTEs 2019</u>	<u>FTEs 2020</u>
Regulatory Compliance Manager	0.2	0.2
Water Quality Coordinator	1.0	1.0
Water Quality Specialists*	4.0	4.0

***This position shares responsibilities in other water quality programs**

PRETREATMENT PROGRAM EXPENDITURES

Laboratory Services	\$5,306.00
Operating Supplies and Expenses	\$350,301.00
Annual Software Maintenance/Support	\$11,875.00

PRETREATMENT EQUIPMENT INVENTORY

<u>Equipment Name</u>	<u>Purchased 2020</u>	<u>Total 2020</u>
pH Meter	0	3
Gas Detectors	0	2
Portable Auto-Sampler	2	6
Vehicles	0	5
Computers / Software	0	9
Area Velocity Probes	0	3
Samplers / pH	0	1

**CITY OF SCOTTSDALE
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
1.	HonorHealth - Osborn 7400 East Osborn Road Scottsdale, Arizona 85251-6432	91 st Ave	8062	Local Limits
2.	HonorHealth - Shea 9003 East Shea Boulevard Scottsdale, Arizona 85260-6709	91 st Ave	8062	Local Limits
3.	HonorHealth - Thompson Peak Pkwy 7400 East Thompson Peak Parkway Scottsdale, Arizona 85255-4109	91 st Ave	8062	Local Limits
4.	Mayo Clinic Scottsdale 13400 East Shea Boulevard Scottsdale Arizona 85259-5499	91 st Ave	8062	Local Limits

CITY OF SCOTTSDALE

**PRETREATMENT PERFORMANCE SUMMARY
ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST**

ADDITIONS

The following Significant Industrial Users were added in 2020:

None

DELETIONS

The following Significant Industrial Users have ceased operations in 2020:

None

RECLASSIFICATIONS

The following Significant Industrial Users have been reclassified in 2020:

None

NAME CHANGES

The following Significant Industrial Users changed their names in 2020:

None		

City of Scottsdale
PRETREATMENT PERFORMANCE SUMMARY
91st Avenue Wastewater Treatment Plant

I. General Information						
Control Authority Name: City of Scottsdale				NPDES No.: AZ0020524		
Address: 8787 East Hualapai Drive		City: Scottsdale		State: Arizona		ZIP: 85255
Contact Person: Carie Wilson				Contact Telephone Number: (480) 312-8718		
Reporting Period: January 1 – December 31, 2020			Categorical IUs: 0		Significant Non-Categorical IUs: 4	
II. Significant Industrial User Compliance						
	Categorical		Non-categorical		Total SIUs	
	No.	%	No.	%	No.	%
1.	No. of SIUs in Full Compliance		4	100%	4	100%
2.	No. of SIUs in Inconsistent Compliance		0	0%	0	0%
3.	No. of SIUs in Significant Noncompliance		0	0%	0	0%
4.	No. of Parameter Violations		0		0	
5.	No. of Reporting Violations		0		0	
6.	No. of Permit Condition Violations		0		0	
III. Compliance Monitoring Program						
	Categorical		Non-categorical		Total SIUs	
	No.	%	No.	%	No.	%
1.	No. of Control Documents Issued		4		4	
2.	No. of Non sampling Inspections Conducted		3		3	
3.	No. of Facilities Inspected (Non sampling)		3		3	
4.	No. of Sampling Visits Conducted		16		4	
5.	No. of Facilities Sampled		4		4	
IV. Enforcement Actions						
	Categorical		Non-categorical		Total SIUs	
	No.	%	No.	%	No.	%
1.	Notices of Violations Issued to SIUs		0		0	
2.	Temporary Increase in IU Self-Monitoring		0		0	
3.	Administrative Orders Issued to SIUs		0		0	
4.	Compliance Schedules Issued		0		0	
5.	Settlement Agreements		0		0	
6.	Other Actions		0		0	
7.	Amount of Penalties Collected (Total Dollars / IUs Assessed)		\$ 0.00 / 0		\$ 0.00 / 0	

**CITY OF SCOTTSDALE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: General Dynamics Mission Systems		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 8201 E McDowell Road		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 01/18/1980	
TTO CERTIFICATION DATE SUBMITTED: 1/25/2021	PERMIT EFFECTIVE: 01/30/2017	PERMIT EXPIRES: 01/30/2022		
SAMPLING LOCATION VERIFIED ON: 7/23/2020	RCRA NOTICE: 08/17/2013			
SLUG CONTROL PLAN EVALUATION DATE: 01/25/2021	Non-Significant Industrial User			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	0
Number of City Sampling Days	0	0	1	0
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	04/20/2020	07/15/2020	10/19/2020	1/25/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: GENERAL DYNAMICS MISSIONS SYSTEMS

Process Flow: 600 GPD

General Information and type of wastewater treatment	<p>This facility has been issued a Non-Significant Industrial User Discharge Permit as of 01/22/2018. Most all major process waste streams have been removed or moved to other locations. They requested their batch sled pretreatment system be removed. Due to years of sampling data showing compliance, they were granted this new permit. The 6,000-gal waste stream retention sump is still in place as well as their sampling compliance point. They now discharge in batches of 5,000 – 6,000 gallons roughly every 3-4 weeks. They are notified in advance of the city’s sampling event to provide enough discharge to allow for a flow-weighted composite sample. They discharge at a rate of 30 gallons per minute, resulting in a 5-hr. sampling window during this batch discharge.</p>
First Quarter	<p>No activities conducted by the City or facility. PCR submitted. No enforcement actions.</p>
Second Quarter	<p>No activities conducted by the City or facility. PCR submitted. No enforcement actions.</p>
Third Quarter	<p>The City conducted 1 day of sampling during the quarter. PCR submitted. No enforcement actions.</p>
Fourth Quarter	<p>No activities conducted by the City or facility. PCR submitted. No inspection completed due to Covid-19 restrictions.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF SCOTTSDALE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: HonorHealth – Osborn		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE 7400 East Osborn Road ADDRESS: Scottsdale, Arizona 85251		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 11/15/1991	
TTO CERTIFICATION DATE SUBMITTED: 05/06/2020		PERMIT EFFECTIVE: 01/01/2016	PERMIT EXPIRES: 12/31/2021	
SAMPLING LOCATION VERIFIED ON: 01/14/2020		RCRA NOTICE: 08/17/1992		
SLUG CONTROL PLAN EVALUATION DATE: 01/30/2015				
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	2	2	2	2
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	04/13/2020	07/21/2020	10/26/2020	01/25/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Scottsdale Healthcare - Osborn

Process Flow: 120,000 GPD (Average)

General Information and type of wastewater treatment	<p>HonorHealth – Osborn is a part of the HonorHealth network of hospitals. It is a full-service hospital (SIC 8062) and is permitted as a non-categorical Significant Industrial User. HonorHealth – Osborn utilizes Best Management Practices (BMPs) as their primary treatment of process water. There is no physical pretreatment system in place.</p>
First Quarter	<p>City of Scottsdale and HonorHealth Osborn separately conducted quarterly sample monitoring of the facility. No enforcement actions.</p>
Second Quarter	<p>City of Scottsdale and HonorHealth Osborn separately conducted quarterly sample monitoring of the facility. No enforcement actions.</p>
Third Quarter	<p>City of Scottsdale and HonorHealth Osborn separately conducted quarterly sample monitoring of the facility. No enforcement actions.</p>
Fourth Quarter	<p>City of Scottsdale and HonorHealth Osborn separately conducted quarterly sample monitoring of the facility. City staff conducted an inspection at the facility. No enforcement actions.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF SCOTTSDALE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: HonorHealth – Shea		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 9003 EAST SHEA BLVD		MAILING ADDRESS: SAME		
CATEGORICAL USER? No	40 CFR Local limits	LIMITS APPENDIX: A	BMR SUBMITTED: 11/15/1991	
TTO CERTIFICATION DATE SUBMITTED: 1/29/2020	PERMIT EFFECTIVE: 1/1/2016	PERMIT EXPIRES: 12/31/2021		
SAMPLING LOCATION VERIFIED ON: 1/29/2020	RCRA NOTICE: 8/17/1992			
SLUG CONTROL PLAN EVALUATION DATE: 1/23/2020				
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	2	2	2	2
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	4/23/2020	7/14/2020	10/23/2020	1/25/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: HonorHealth – Shea

Process Flow: 28,800 (GPD) Average

General Information and type of wastewater treatment	<p>HonorHealth Shea Medical Center is a part of the HonorHealth network of hospitals. It is a full-service hospital (SIC 8062) and is permitted as a non-categorical Significant Industrial User (SIU). HonorHealth utilizes Best Management Practices (BMPs) as their primary treatment of process wastewater. There is no physical pretreatment system in place.</p>
First Quarter	<p>The city conducted two days of sampling during the quarter. HonorHealth – Shea conducted their required quarterly self-monitoring. No enforcement actions.</p>
Second Quarter	<p>The city conducted two days of sampling during the quarter. HonorHealth – Shea conducted their required quarterly self-monitoring. No enforcement actions.</p>
Third Quarter	<p>The city conducted two days of sampling during the quarter. HonorHealth – Shea conducted their required quarterly self-monitoring. No enforcement actions.</p>
Fourth Quarter	<p>The city conducted two days of sampling during the quarter and HonorHealth – Shea conducted their required quarterly self-monitoring. The annual inspection was conducted during this quarter. No enforcement actions.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF SCOTTSDALE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: HonorHealth – Thompson Peak		REPORT PERIOD: 01/01/2020 through 12/31/2020			
SERVICE: 7400 E. Thompson Peak Pkwy		MAILING ADDRESS: Same			
ADDRESS: Scottsdale, AZ 85255-4109		CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: N/A
TTO CERTIFICATION DATE SUBMITTED: 1/22/2021		PERMIT EFFECTIVE: 10/01/2018		PERMIT EXPIRES: 9/30/2023	
SAMPLING LOCATION VERIFIED ON: 1/13/2020		RCRA NOTICE: 10/01/2009			
SLUG CONTROL PLAN EVALUATION DATE: 01/14/2021					
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0	0	0	1	
Number of City Sampling Days	2	2	2	2	
Number of IU Sampling Days	1	1	1	1	
Number of Parameter Violations	0	0	0	0	
Number of Inspection Violations	0	0	0	0	
Number of Reporting Violations	0	0	0	0	
Number of Permit Cond. Violations	0	0	0	0	
Compliance Status	C	C	C	C	
Evaluated as of:	4/20/2020	7/9/2020	10/20/2020	1/22/2021	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: HONORHEALTH – THOMPSON PEAK

Process Flow: 79,000 (GPD) Average

General Information and type of wastewater treatment	<p>The Thompson Peak location is a part of the HonorHealth network of hospitals. The facility is a full-service hospital with a certified Chest Pain Center, emergency department, and inpatient/outpatient surgery center. HonorHealth – Thompson Peak is a non-categorical Significant Industrial User (SIU) and utilizes pH neutralization in its laboratory sinks and implements Best Management Practices (BMPs). There is no physical pretreatment system in place.</p>
First Quarter	<p>The city conducted one sampling event during the quarter. HonorHealth – Thompson Peak conducted their required quarterly self-monitoring. No enforcement actions.</p>
Second Quarter	<p>The city conducted one sampling event during the quarter. HonorHealth – Thompson Peak conducted their required quarterly self-monitoring. No enforcement actions.</p>
Third Quarter	<p>The city conducted one sampling event during the quarter. HonorHealth – Thompson Peak conducted their required quarterly self-monitoring. No enforcement actions.</p>
Fourth Quarter	<p>The city conducted one sampling event during the quarter and inspected the facility once. HonorHealth – Thompson Peak conducted their required quarterly self-monitoring. No enforcement actions.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No

Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

**CITY OF SCOTTSDALE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Mayo Clinic		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 13400 E Shea Blvd, Scottsdale, AZ 85259		MAILING ADDRESS: Same		
CATEGORICAL USER? NO	40 CFR: LOCAL LIMITS	LIMITS APPENDIX: A	BMR SUBMITTED: N/A	
TTO CERTIFICATION DATE SUBMITTED: 01/13/21		PERMIT EFFECTIVE: 01/01/2016	PERMIT EXPIRES: 12/31/2021	
SAMPLING LOCATION VERIFIED ON: 02/10/20		RCRA NOTICE: 12/28/1990		
SLUG CONTROL PLAN EVALUATION DATE: 01/13//2021				
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	0
Number of City Sampling Days	2	2	2	2
Number of IU Sampling Days	1	1	1	1
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	04/21/2020	07/15/2020	10/09/2020	01/13/2021

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)
Enforcement Status			N	N	N	N	N	N

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: MAYO CLINIC

Process Flow: 26,677 gpd (average)

General Information and type of wastewater treatment	<p>This is a large full-service hospital. Wastewater treatment consists of physical separation via gravity interceptors and stream segregation. Any acids that are used in the laboratory are pH neutralized prior to discharge. No sampling violations.</p>
First Quarter	<p>City of Scottsdale and Mayo Clinic separately conducted quarterly sample monitoring of the facility. No sampling violations. PCR submitted.</p>
Second Quarter	<p>City of Scottsdale and Mayo Clinic separately conducted quarterly sample monitoring of the facility. No sampling violations. PCR submitted.</p>
Third Quarter	<p>City of Scottsdale and Mayo Clinic separately conducted quarterly sample monitoring of the facility. No sampling violations. PCR submitted.</p>
Fourth Quarter	<p>City of Scottsdale and Mayo Clinic separately conducted quarterly sample monitoring of the facility. No sampling violations. PCR submitted. An annual inspection was postponed due to Covid restrictions at the Mayo facility. The additional inspection at the adjacent TGEN Research Center was postponed as well.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

SECTION 2.5
CITY OF TEMPE

POTW PRETREATMENT ANNUAL REPORT

CITY OF TEMPE, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 91st Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020524

Person to Contact Concerning City of Phoenix Information Contained in the Report:

Richard Dalton
Environmental Compliance Supervisor
Post Office Box 5002
Tempe, Arizona 85280
480-350-2851

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all CITY OF TEMPE attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

2/5/2021

Date:

Tara Ford

Tara Ford
Deputy Municipal Utilities Director – Water Utilities
City of Tempe, Arizona



INTRODUCTION

Tempe, with a population of 195,850, is the eighth largest city in the State of Arizona. Tempe is located in the heart of the Phoenix Metropolitan Area and is bordered by Scottsdale, Mesa, Phoenix, Guadalupe and Chandler. The average annual rainfall is 9.33 inches, the average high temperature is 87 degrees Fahrenheit (°F), the average low temperature is 55°F and the combined average temperature is 71°F.

Charles Trumbull Hayden founded the City in 1872 when he established Hayden Milling and Farming Ditch Company (at one time, Hayden Flour Mills was the oldest continuously operating business in the State). Tempe, incorporated in 1894, presently encompasses approximately 40 square miles and the elevation ranges from 1,140 feet to 1,495 feet. Additionally, the Town of Guadalupe is part of the Tempe's potable water service area, and an upstream user of the Tempe Sanitary Sewer System, with a land area of 0.81 square miles, and a population of 6,631.

As a major city in the Phoenix Metropolitan Area, Tempe has a diversified economic base. It is primarily a manufacturing city, with firms including producers of electronics, propulsion equipment, advanced medical equipment, prefabricated housing, machine products and mobile homes. In addition, there are commercial services, shopping centers, banking, developers, lodging and the spectrum of services necessary to support the economic base. Tempe supports industrial parks, which house heavy, medium and light industrial activities. The economy of Tempe employs 121,873 people, with the largest workforce sectors being educational services, food services, industrial and retail trade.

Tempe is home to Arizona State University's (ASU) main campus. ASU is one of the five largest public universities in the nation, with an enrollment of approximately 150,000 students, where the majority of the students attend Tempe's 664-acre main campus. Tempe is also home to the 320-acre Arizona State University Research Park.

The United States Environmental Protection Agency (EPA) approved Tempe's Industrial Pretreatment Program in 1983. The objective of this program is to regulate discharges, primarily from non-domestic users (commercial and industrial facilities), which discharge toxic or unusually strong conventional wastes that must be treated by the Publicly Owned Treatment Works (POTW). Discharges from these facilities are controlled and regulated through the issuance discharge permits and enforcing national categorical standards, as well as custom local discharge limits based on the 91st Avenue Wastewater Treatment Plant carrying and receiving capacities.



Summary of Pretreatment Program Changes

January 1, 2020 through December 31, 2020

The City of Tempe Industrial Pretreatment Program (IPP) is under the oversight of the Water Utilities Division of the Municipal Utilities Department. There have been some changes within the IPP during calendar year 2020. One Significant Industrial User (SIU) changed their name due to a transfer of ownership, with all process operations remaining unchanged. Another SIU changed their name to reflect the location of their facility.

The Capital Improvement Program (CIP) Project, referenced in Tempe's 2019 Annual Pretreatment Report, to increase sewer capacity in an industrial section of Tempe was completed on schedule in early 2020. The SIU that requested additional capacity entered into an agreement with the City to reimburse the city for costs incurred to complete the CIP. The SIU made the first, of ten, annual installments in the amount of \$482,568 toward the total amount of \$4,825,680 for the CIP.

Tempe continues to utilize SAMSIPP and SwiftComply electronic compliance data and program management solutions, which support the IPP and FOG/TGC programs respectively. The SAMSIPP solution also manages the commercial/industrial, stormwater, and environmental call-out response inspection activities.

As of December 31, 2020, TGC membership consists of 219 food service establishments and four permitted industrial users. Information about the Tempe Grease Cooperative is available at <http://www.tempe.gov/grease>.

Tempe is currently in the process of reviewing and updating Tempe City Code, Chapter 27 as well as their Enforcement Response Plan and Rules and Procedures for Interceptors and Traps for Wastewater Pretreatment, as well as having internal discussion with respect to Navigable Waters Protection Rule and any potential impacts on the Pretreatment and Stormwater programs.

CITY OF TEMPE

Annual Best Management Practices Report

**Pollution Prevention through Point Source Control Measures
&
Educational Outreach Program Efforts
for January 1, 2020 through December 31, 2020**

Best Management Practices report as required by the
91st Avenue WWTP NPDES Permit No AZ0020524

CITY OF TEMPE

2020 ANNUAL BEST MANAGEMENT PRACTICES REPORT OF POLLUTION PREVENTION THROUGH POINT SOURCE CONTROL MEASURES & EDUCATIONAL OUTREACH PROGRAM EFFORTS

POLLUTION PREVENTION THROUGH POINT SOURCE CONTROL PROGRAMS

Information shown below constitutes continuous and ongoing efforts by the City of Tempe Municipal Utilities Department to prevent, reduce and/or eliminate pollutants from entering the sewer collection system.

POINT SOURCE CONTROL PROGRAM

The City of Tempe continues its efforts to identify controllable sources of pollutants discharged to the regional 91st Avenue Wastewater Treatment Plant, located within the City of Phoenix. The City continues to monitor potential commercial and industrial users to identify possible sources of arsenic, chromium, copper, cyanide, lead, nickel, selenium, zinc, Total Toxic Organics (TTO), other prohibited materials and materials identified at industrial facilities currently under permit with the City of Tempe.

The City continues to meet the requirements of the Phase I Stormwater Arizona Pollution Discharge Elimination System (AZPDES) Permit Number AZS000005-2010.

CITY OF TEMPE PERMANENT HOUSEHOLD PRODUCTS COLLECTION CENTER

The City of Tempe is committed to responding to the needs of its citizens and protecting the environment. The permanent Household Products Collection Center (HPCC) enables the City of Tempe to:


- Provide for the safe and convenient disposal of most common household products on a continuous basis;
- Enhance recycling of collected materials;
- Protect the environment and public health and safety by reducing the amount of illegal dumping; and
- Provide public education on the proper management of household chemicals.

Participation at the facility has decreased by 19 percent in 2020 with 6,383 visitors, which is a 28% decrease, that resulted in the diversion of 356,020 pounds of waste that could have otherwise been disposed of in a landfill or sanitary sewer system. The drop in participation was likely due to limited operating hours in which the facility was open to the public due to the COVID-19 pandemic.

HPCC is not able to accept radioactive materials, medical waste, ammunition or explosive materials. Information on proper disposal options for these materials is provided at the facility, and available on their website at: www.tempe.gov/householdproducts.

The Swap Area within HPCC allows residents to reuse virgin or near-virgin household materials and is one of the many source reduction activities the City is utilizing at HPCC. Others include:

- Evacuation of aerosol cans and bulking waste propellant and product;
- Recycling metal containers and cardboard;
- Bulking common materials in lieu of lab packing them for disposal;
- Bulking latex paint, which is then provided free-of-charge to various organizations for graffiti removal or used in the construction of new roadways;
- Recycling of used motor oil and antifreeze for post-consumer use.



HPCC is operated and managed by the City's Municipal Utilities Department and funded by the water/wastewater fund.

A complete HPCC report is available at: www.tempe.gov/householdproducts.

ENVIRONMENTAL SERVICES SECTION WEBPAGE

The City's websites provide information on various Departments, Divisions and Sections throughout the City, including the Environmental Services Section (ESS). These sites include information on staffing, information request forms, City activities, weather, career opportunities and an array of other City business, including compliance and enforcement documents utilized by ESS.

ESS continues to update its website, which is available to businesses and residents 24 hours a day, 365 days a year. Information available on the website

includes pollution prevention and source control, Best Management Practices (BMPs) and public outreach events. Access to online test entry in support of the Cross-Connection Control Program is also available on Tempe's Water Utilities Division website at www.tempe.gov/government/municipal-utilities/water.

ESS has developed, and regularly updates, a document and information section on its website. This allows permitted industries to complete and submit the semiannual and/or annual reports online.

RESIDENTIAL COMMUNITY OUTREACH – TEMPE TODAY

Community outreach is accomplished through Tempe Today, a newsletter of events and activities, as well as informational inserts provided in monthly water utility bills. The articles listed below highlight some of Tempe's pollution prevention activity in 2020. All newsletters and inserts are available at www.tempe.gov/tempetoday.

January 2020, included a notification, "*New trash and recycling collection days*", that advised Tempe residents that the city is using a new route management system that allows the city to better manage resources and reduce costs, which will improve service, reduce fuel use and lower Tempe's carbon footprint. Additional information is available at www.tempe.gov/SMART.

January 2020, included an article, "*Heed 'No Burn Day' warnings*". Arizona Department of Environmental Quality (ADEQ) regularly conducts tests on particulate matter (PM) to ensure air quality meets federal and state guidelines. The article advised residents that on days when PM is expected to be too high, a health watch or high pollution advisory is issued, resulting in a No Burn Day. Residents are not allowed to burn wood in their fireplaces, stoves, chimneys and fire pits on these days, however gas and electric fireplaces are permitted to use. Information is available at www.tempe.gov/AirQuality and residents can sign up for No Burn Day alerts at www.cleanairmakemore.com.

February 2020, included an article, "*Geeks Night Out is March 18*", an event where science, technology and engineering are blended into an evening of educational and fun activities. ESS routinely participates in this event by providing a demonstration on the impact that Fats, Oils and Grease (FOG) has on the environment, how to remove it at the source prior to entry into the sewer and what residents can do to minimize introduction of FOG into the sewer system at their residence with simple BMP information. Information on Geeks Night Out is available at www.tempe.gov/geeks.

February 2020, included an article, "*Heed 'No Burn Day' warnings*". ADEQ regularly conducts tests on particulate matter (PM) to ensure air quality meets federal and state guidelines. The article advised residents that on days when PM is expected to be too high, a health watch or high pollution advisory is issued, resulting in a No Burn Day. Residents are not allowed to burn wood in their fireplaces, stoves, chimneys and fire pits on these days, however gas and

electric fireplaces are permitted to use. Information is available at www.tempe.gov/AirQuality and residents can sign up for No Burn Day alerts at www.cleanairmakemore.com.

March 2020, included a ribbon advising residents about the April 2020, Zero Waste Day. This provides residents with the opportunity to clean out their attics, basements, closets and garages of used but usable items and pass them on to local people in need. More information is available at www.tempe.gov/ZeroWaste.

March 2020, included an article, *“Turn in old, expired meds”*, which highlighted Tempe’s partnership with the Arizona Drug Enforcement Administration to host a “take back” that allows residents to properly dispose of prescription and non-prescription medication in an environmentally responsible manner and thereby keep it out of the sewer system. The article advised residents of a disposal event on April 25, 2020, at the Apache Police Substation and the downtown Police Headquarters.

April 2020, included an article, *“Tempe partners with local nonprofit to reduce waste”*, which explains how The City of Tempe has partnered with local non-profit, Stardust, to help divert waste from landfills. Stardust offers home pick up for donations of new, excess or gently used building materials, appliances and furniture. Information about Stardust is at www.StardustBuilding.org

April 2020, included an article, *“April is Earth Month”*, which advised residents that Sustainable Tempe webpage offers information on the programs and projects happening in Tempe that help to create lasting, positive environmental changes. Residents can learn more about Tempe’s sustainability efforts at www.tempe.gov/SustainableTempe

June 2020, included an article, *“Are you monsoon-ready”?* that explained to residents how stormwater can be protected by avoiding the use of pesticides, herbicides, fertilizers and other outdoor chemical products when rain is likely. It also highlighted that by properly storing these chemicals under cover and cleaning up spills immediately after they occur, residents could prevent the introduction of these chemicals into a waterway. Information on monsoon safety is available at www.tempe.gov/monsoons.

June 2020, included an article, *“Keep stormwater safe during monsoon season”*, explaining that when it rains, excess fertilizer, pesticides, oil, gasoline and other chemicals can wash off lawns and driveways and create the potential to pollute waterways and groundwater aquifers. The article explains how residents can keep these pollutants from ending up in the stormwater by avoiding use when rain is likely, properly storing them under cover and cleaning up spills immediately after they occur.

June 2020, included a paragraph announcing that the *Zero Waste Day* scheduled in July 2020 was cancelled due to the COVID-19 pandemic.

July 2020, included an article, *“Is your pet monsoon ready”*, that reminded residents to pick up their pet’s waste before a storm occurs. The article also advised residents that pet waste contains bacteria and pathogens, and if it enters the storm drains it could pollute the water supply.

July 2020, included an article, *“Tempe is here to help you with monsoon clean up”*, that advises residents they can take all downed trees, shrubs and other green organics to our compost or request a Bulk Trash or Green Organics pickup outside of their regular pickup schedule for a fee.

October 2020, included an article, *“Zero Waste Day is Nov. 21”*, that advised residents about the November 2020, Zero Waste Day. The Zero Waste Day provided the platform to donate unwanted household waste in an environmentally responsible way. Residents were able to drop off e-waste, hazardous household items and documents, and the City recycled or donated items to charity as appropriate. The City also gave away recycled paint and Tempe-produced compost at no charge. More information about Zero Waste Days is available at www.tempe.gov/ZeroWaste.

November 2020, included an article, *“Downtown Tempe Festival of the Arts and Facebook Live Holiday Special”*, that announced the cancelation of the 2020 winter Tempe Festival of the Arts, which is a popular venue for public engagement as well as the distribution of material related to Tempe’s pollution prevention efforts, due to the COVID-19 pandemic.

December 2020, included an article, *“Recycle your holiday tree”*, that provided Tempe residents with information about an option to dispose of used holiday trees. The city offered residents two locations where they could drop off old holiday trees for proper disposal.

December 2020, included an article, *“Heed ‘No Burn Day’ warnings”*, ADEQ regularly conducts tests on particulate matter (PM) to ensure air quality meets federal and state guidelines. It advised residents that on days when PM is expected to be too high, a health watch or high pollution advisory is issued, resulting in a No Burn Day. Residents are not allowed to burn wood in their fireplaces, stoves, chimneys and fire pits on these days, however gas and electric fireplaces are permitted to use. Information is available at www.tempe.gov/AirQuality and residents can sign up for No Burn Day alerts at www.cleanairmakemore.com.

December 2020, included a ribbon that announced the January 2021 Zero Waste Day Event at the Tempe Fire Training Center. More information about Zero Waste Days is available at www.tempe.gov/ZeroWaste.

Outreach material is typically distributed to individuals attending public events. The spring and winter Tempe Arts Festival of the Arts, and several Zero Waste Day events were cancelled in 2020 due to the COVID-19 pandemic.

ESS staff participates on a Wastewater Data Analytics committee in partnership with ASU to support opioid reduction and outreach through the collection and analysis of wastewater at several points throughout the collection system. Additional information is available at www.tempe.gov/opioids.

The Wastewater Data Analytics committee expanded in 2020 to include an innovative partnership with scientists from ASU's Bio-Design Institute to prevent and reduce the spread of COVID-19, through wastewater-based epidemiology (WBE). WBE is the science of studying community sewage for public health information. Additional information is available at covid19.tempe.gov/

INDUSTRIAL AND COMMERCIAL INSPECTIONS AND COMMUNITY OUTREACH

The City of Tempe continues its public education outreach program by placing articles on pollution prevention, household recycling and BMPs in the *Tempe Today* newsletter. The publication of the *Tempe Environmental Bulletin*, a quarterly newsletter in electronic format, is distributed to Tempe Industrial Users and contains articles on pollution prevention.

BMP brochures including: “*Fats, Oils and Grease (FOG) Management for the Food Service Industry*”, and “*Why Does the City of Tempe Perform Industrial/Commercial Facility Inspections?*”. Additional relevant documents are distributed to commercial or industrial facilities during site inspections as appropriate. These documents are available, along with other BMP brochures at www.tempe.gov/stormwatertips.

As reported in the Pretreatment Performance Summary, staff performed 31 inspections at Significant Industrial Users (SIUs). ESS conducted 16 additional inspections at Industrial Users, permitted with either a Class II, III or IV discharge permit, during the period of January 1, 2020 through December 31, 2020. Additionally, staff performed 200 non-food service establishment commercial/industrial multi-media inspections.

The City received, and responded to, 130 calls during the 2020 calendar year. ESS works closely with other sections of the Water Utilities Division and other City Departments to prevent discharges to the sanitary and storm sewers that could adversely affect the system. Calls are summarized in the following manner:

Type of Call/Complaint	Count
Illegal Discharge (all types of waste)	9
FOG Related	8
Odor	7

For the Year Ending December 31, 2020

Other (Dust, Illegal Disposal)	22
SSO (5 Private; 4 City)	9
Stormwater (Pool discharges included)	75

During 2020, 429 City sampling events were completed; 261 of these events took place at categorical facilities, and the remaining 168 events were at non-categorical facilities. Permitted Industrial Users conducted a combined 1083 of their own sampling events in 2020 as well.

FATS, OILS AND GREASE PROGRAM

Between January 1, 2020 and December 31, 2020, 197 commercial FOG inspections were performed at food service establishments (FSEs).

The City maintains the Tempe Grease Cooperative, a compliance assistance program that allows FSEs to receive grease control device pump out services through city-procured contracts. City staff received and reviewed the service manifests for compliance for each of the 1,058 pump-out services that occurred in 2020 under this program.

PROFESSIONAL ASSOCIATIONS

ESS Staff are actively involved in various environmental, health and safety organizations such as the AZ Water Association (AZ Water), North American Hazardous Material Management Association (NAHMMA) and the Water Environment Federation (WEF).

CITY OF TEMPE

SUMMARY OF PRETREATMENT PROGRAM EXPENDITURES

January 1, 2020 – December 31, 2020 – Total Pretreatment Expenditures \$2,355,698

PRETREATMENT PROGRAM PERSONNEL

<u>Title</u>	<u>FTEs 2019</u>	<u>FTEs 2020</u>
Deputy Municipal Utilities Director – Water Utilities	1.0	1.0
Environmental Services Manager	1.0	1.0
Environmental Compliance Supervisor	1.0	3.0
Environmental Compliance Inspector	7.0	7.0
Water Quality Specialist	4.0	4.0
Environmental Services Program Assistant	1.0	1.0
Management Assistant II	1.0	0.0
Water Utilities Business Liaison	1.0	0.0
Administrative Assistant II	1.0	1.0

PRETREATMENT PROGRAM EXPENDITURES

Personnel	\$1,394,303
Equipment Operation & Maintenance	*\$186,965
Laboratory	\$214,029
ASU BioMarker Monitoring	\$288,771
Pollution Prevention	**\$251,630

*Based on Fiscal Year 19/20 and 20/21 Budget Reports

**Estimated Value + Tempe Grease Cooperative Expenses

PRETREATMENT EQUIPMENT INVENTORY

<u>Equipment Name</u>	<u>Purchased 2020</u>	<u>Total 2020</u>
ISCO Wastewater Sampler	11	30
ISCO Area Velocity Meters	0	10
ISCO Flow Meter Modules (pH/ultra-sonic)	1	10
ISCO Laser Flow Meters	0	5
Vehicles	2	13
Gas Detectors	0	5
Computers (desktop/laptop)	13	16

CITY OF TEMPE
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
1.	Acme Aerospace Inc. 528 West 21st Street Tempe AZ 85282	COP 91 st Ave	3692	461.15
2.	Advotech 632 West 24th Street Tempe AZ 85282	COP 91 st Ave	3674	469.18
3.	APS 1500 East University Drive Tempe AZ 85281	COP 91 st Ave	4911	423.16
4.	Arizona Finishing 2400 South Roosevelt Tempe, AZ 85282	COP 91 st Ave	3479	433.17
5.	Arizona Production & Packaging 7303 South Kyrene Road Tempe AZ 85283	COP 91 st Ave	2086	LOCAL LIMITS
6.	Arizona State University 1551 South Rural Road Tempe AZ 85281	COP 91 st Ave	8221	LOCAL LIMITS
7.	Arizona State University Macro Technology Works 7700 South River Parkway Tempe AZ 85284	COP 91 st Ave	3679	LOCAL LIMITS
8.	Array Photonics, Inc. 2507 West Geneva Drive Tempe AZ 85282	COP 91 st Ave	3471	469.18
9.	Coxreels, Inc 5865 South Ash Avenue Tempe AZ 85283	COP 91 st Ave	3499	433.17
10.	Foresight Finishing LLC 236 West Lodge Drive Tempe AZ 85283	COP 91 st Ave	3471	433.17
11.	Gorilla Industrial Coatings LLC 2605 South Industrial Park Avenue Tempe AZ 85282	COP 91 st Ave	3479	433.17
12.	Group Manufacturing 815 W Geneva Drive Tempe AZ 85282	COP 91 st Ave	3444	433.17
13.	Harrison Properties 1115 West Alameda Drive Tempe AZ 85282	COP 91 st Ave	2026	LOCAL LIMITS
14.	Honeywell International, Inc. 1300 W Warner Road Tempe AZ 85284	COP 91 st Ave	3471	433.17
15.	L-3 Communications Corporation ETO 1215 South 52nd Street Tempe AZ 85281	COP 91 st Ave	3672	433.15
16.	Lawrence Semiconductor Research Laboratory Inc 2300 West Huntington Drive Tempe AZ 85282	COP 91 st Ave	3674	469.18
17.	Medtronic Tempe Campus 2343 West Medtronic Way Tempe AZ 85281	COP 91 st Ave	3674	433.17/ 469.18

CITY OF TEMPE
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020

	COMPANY NAME AND ADDRESS	WWTP	SIC Code	Regulation
18.	Microchip Technology Inc. 1200 South 52nd Street Tempe AZ 85281	COP 91 st Ave	3674	469.18
19.	Photo Design of Arizona 3105 South Potter Drive Tempe AZ 85282	COP 91 st Ave	3479	433.17
20.	Precision Die & Stamping 1704 West 10th Street Tempe AZ 85281	COP 91 st Ave	3469	433.17
21.	Precision Powdercoat 1616 South Edward Tempe AZ 85281	COP 91 st Ave	3479	433.17
22.	Schreiber Foods Inc. 2122 South Hardy Drive Tempe AZ 85282	COP 91 st Ave	2022	LOCAL LIMITS
23.	Southwest Metal Finishing Inc. 2002 West Campus Tempe AZ 85282	COP 91 st Ave	3471	433.17
24.	SRP K7GS 7005 South Kyrene Road Tempe AZ 85283	COP 91 st Ave	4911	423.16
25.	Sun Orchard, Inc 1198 West Fairmont Drive Tempe AZ 85282	COP 91 st Ave	2033	LOCAL LIMITS
26.	Swire Coca-Cola, USA - Tempe Production Center1850 West Elliot Road Tempe, AZ 85284	COP 91 st Ave	2086	LOCAL LIMITS
27.	Trion Technology Inc 1025 South 52nd Street Tempe AZ 85281	COP 91 st Ave	3674	469.18
28.	United Dairymen of Arizona 2008 South Hardy Drive Tempe AZ 85282	COP 91 st Ave	2023	LOCAL LIMITS
29.	Versum Materials US, LLC 8555 South River Parkway Tempe, Arizona 85284	COP 91 st Ave	2889	LOCAL LIMITS

CITY OF TEMPE

PRETREATMENT PERFORMANCE SUMMARY ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST

ADDITIONS

The following Significant Industrial Users have commenced operations in 2020:

None

DELETIONS

The following Significant Industrial Users have ceased operations in 2020:

None

RECLASSIFICATIONS

The following Significant Industrial Users have been reclassified in 2020:

None

NAME CHANGES

The following Significant Industrial Users changed their names in 2020:

Solar Junction Corp
2507 West Geneva Drive
Tempe AZ 85282

IS NOW

Array Photonics, Inc.
2507 West Geneva Drive
Tempe AZ 85282

Medtronic Microelectronics Center
2343 West Medtronic Way
Tempe, AZ 85281

IS NOW

Medtronic Tempe Campus
2343 West Medtronic Way
Tempe, AZ 85281

City of Tempe
PRETREATMENT PERFORMANCE SUMMARY
91st Avenue Wastewater Treatment Plant

I. General Information						
Control Authority Name: City of Tempe			NPDES No.: AZ0020524			
Address: P.O. Box 5002		City: Tempe		State: Arizona		ZIP: 85282
Contact Person: Richard Dalton				Contact Telephone Number: (480) 350-2851		
Reporting Period: January 1 – December 31, 2020			Categorical IUs: 19		Significant Non-Categorical IUs: 10	
II. Significant Industrial User Compliance						
	Categorical		Non-categorical		Total SIUs	
	No.	%	No.	%	No.	%
1. No. of SIUs in Full Compliance	16	84	5	50	21	72
2. No. of SIUs in Inconsistent Compliance	3	16	5	50	8	28
3. No. of SIUs in Significant Noncompliance	0	0	0	0	0	0
4. No. of Parameter Violations	7		8		15	
5. No. of Reporting Violations	0		0		0	
6. No. of Permit Condition Violations	0		0		0	
III. Compliance Monitoring Program						
	Categorical		Non-categorical		Total SIUs	
	No.	%	No.	%	No.	%
1. No. of Control Documents Issued	9		0		9	
2. No. of Non-sampling Inspections Conducted	20		11		31	
3. No. of Facilities Inspected (Non-sampling)	19		10		29	
4. No. of Sampling Visits Conducted	261		168		429	
5. No. of Facilities Sampled	18		10		28	
IV. Enforcement Actions						
	Categorical		Non-categorical		Total SIUs	
	No.	%	No.	%	No.	%
1. Notices of Violations Issued to SIUs	3		7		10	
2. Temporary Increase in IU Self-Monitoring	0		0		0	
3. Administrative Orders Issued to SIUs	3		7		10	
4. Compliance Schedules Issued	0		0		0	
5. Settlement Agreements	0		0		0	
6. Other Actions	0		1		1	
7. Amount of Penalties Collected (Total Dollars / IUs Assessed)	\$0.00		\$ 13,125.00		\$ 13,125.00	

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Acme Aerospace Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 528 West 21 Street Tempe, AZ 85282		MAILING ADDRESS: 528 West 21st Street Tempe, AZ 85282		
CATEGORICAL USER? Yes	40 CFR 461	LIMITS APPENDIX: T-J	BMR SUBMITTED: 12/31/1989	
TTO CERTIFICATION DATE SUBMITTED: 9/1/2020		PERMIT EFFECTIVE: 11/25/2019	PERMIT EXPIRES: 11/24/2023	
SAMPLING LOCATION VERIFIED ON: 12/17/2020		RCRA NOTICE: 5/3/1993		
SLUG CONTROL PLAN EVALUATION DATE: 11/21/2019		COMPLIANCE SAMPLING POINT №: 5001		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	5	1	0	5
Number of IU Sampling Days	4	4	2	6
Number of Parameter Violations	2	1	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	I	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Daily Cat.	2/4/2020	Composite	Federal	City	Nickel	508/110mg/kg	5
1 st	Monthly Cat.	2/2020	Composite	Federal	City	Nickel	168/74mg/kg	5
2 nd	Monthly Cat.	6/2020	Composite	Federal	City	Nickel	84/74mg/kg	5
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A,B	A,B,F	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Acme Aerospace Inc.

Process Flow: 0.005234 MGD

General Information and type of wastewater treatment	<p>Acme Aerospace is a manufacturer of nickel/cadmium batteries and charging systems for the industrial, commercial, transportation, and aerospace industries, as well as several military applications. Acme is regulated under 40 CFR 461 - Subpart A, Cadmium Subcategory of the Battery Manufacturing Point Source Category.</p> <p>Nickel plating waste undergoes ion exchange, alkaline precipitation and filtration. Treatment is done in batch format. Acme self-monitors each batch discharge.</p>
First Quarter	<p>Acme Aerospace had a daily categorical and monthly categorical violation for nickel in February of 2020. An NOV/AO will be issued in the 2nd quarter.</p>
Second Quarter	<p>Acme Aerospace was issued a NOV/AO for nickel violations that occurred in the 1st quarter.</p> <p>Acme Aerospace had a nickel monthly categorical violation in June of 2020. An NOV/AO will be issued in the 3rd quarter.</p>
Third Quarter	<p>Acme Aerospace was issued a NOV/AO for nickel violations in the 3rd Quarter of 2020 with an associated administrative fine of \$4375.00 for the cumulative violations that occurred over the previous two consecutive quarters</p>
Fourth Quarter	<p>Acme Aerospace (Acme) met the Technical Review Criteria for Significant Non-Compliance (SNC) for two nickel parameter violations that occurred in 2020. After a conversation with Arizona Department of Environmental Quality, it was determined that formal SNC assignment and publication was not appropriate in this situation because Acme immediately ceased all process discharge and diverted all process wastewater to their onsite evaporator for treatment. The decision to eliminate process discharge while the investigation was occurring allowed Acme to identify the root cause and mitigate it, however that process took several months, and additional samples were not collected because there was no process discharge during that period. Additionally, the two exceedances did not result in any harm to the POTW or impact the health and safety of workers within the POTW.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 4,375 Collected \$ 4,375

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Advotech

Process Flow: 0.00155 MGD

General Information and type of wastewater treatment

Advotech is permitted as a Class I Significant Industrial User under CFR 469 - Electrical and Electronic Components Point Source Category, Subpart A - Semiconductor Subcategory (469.18 PSNS) due to dicing operations.

Wastewater is pumped through a 25-micron filter, then a 1-micron filter. Effluent flows through the filters, and dumps into a 120-gallon holding tank. The wastewater is then discharged to a floor sink via gravity and enters the City of Tempe sanitary sewer system.

First Quarter

No additional activity was performed this quarter.

Second Quarter

No additional activity was performed this quarter.

Third Quarter

No additional activity was performed this quarter.

Fourth Quarter

No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: APS

Process Flow: 0.074301 MGD

General Information and type of wastewater treatment

This facility consists of five 100-megawatt and two 55-megawatt natural gas combustion turbine electric generators; regulated as 40 CFR 403 (local limits).

The primary wastewater is the result of cooling tower blow downs. Arizona Public Service (A.P.S.) Company operates this facility on a seasonal basis.

First Quarter

No additional activity was performed this quarter.

Second Quarter

No additional activity was performed this quarter.

Third Quarter

No additional activity was performed this quarter.

Fourth Quarter

No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona Finishing

Process Flow: 0.004980 MGD

General Information and type of wastewater treatment	<p>Arizona Finishing conducts powder coating and painting of metal and plastic parts with the use of an alkaline cleaner, rinsed and coated with a phosphate-free coating prior to powder or spray coating. These processes are defined in the Code of Federal Regulations under 40 CFR 403, Part 433, Subpart A</p> <p>Pretreatment is pH neutralization and continuous pH monitoring of the effluent prior to discharge. Discharges include; overflow from the alkaline cleaning tank, overflow from the two water-rinsing tanks, and overflow from the phosphating tank.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>An Industrial Discharge Permit was reissued in the 4th quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Arizona Production & Packaging		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 7303 South Kyrene Road Tempe, AZ 85283		MAILING ADDRESS: 7303 South Kyrene Road Tempe, AZ 85283		
CATEGORICAL USER? No	40 CFR 403	LIMITS APPENDIX: T-A	BMR SUBMITTED: 3/10/2004	
TTO CERTIFICATION DATE SUBMITTED: 8/25/2020		PERMIT EFFECTIVE: 4/10/2019	PERMIT EXPIRES: 4/9/2023	
SAMPLING LOCATION VERIFIED ON: 09/29/2020		RCRA NOTICE: 11/16/2004		
SLUG CONTROL PLAN EVALUATION DATE: 3/6/2018		COMPLIANCE SAMPLING POINT №: 5045		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	1	0
Number of City Sampling Days	4	0	0	4
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	1	0	0
Compliance Status	C	I	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
2 nd	Instantaneous	5/2020	Instantaneous Grab	City	IU	pH	<5.0 or >10.5 S.U.	Continuous
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	A,B	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona Production & Packaging

Process Flow: 0.175781 MGD

General Information and type of wastewater treatment	<p>APP bottles both vitamin and herbal dietary supplements.</p> <p>All cleaning solutions used in the CIP system are adjusted with either an acid or sodium hydroxide to meet Local Limit pH standards. All batches are sampled for pH and logged prior to discharge.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>Arizona Production & Packaging had a pH exceedance in May. A Notice of Violation/Administrative Order, (NOV/AO) was issued in the 3rd quarter of 2020.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>Arizona Production & Packaging is working on an upgrade to their internal sewer lines to accommodate batch discharge volume and prevent H2S generation.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona State University

Process Flow: 1.43874 MGD

General Information and type of wastewater treatment	<p>Regulated wastes are generated from several sources on this campus. Those sources are: Science Buildings, the Physical Plant and the Fine Arts Building. These are being sampled by ASU. The private sewer system that connects with the City of Tempe collection system is sampled by Tempe. There are four sampling points that are outlined in the discharge permit.</p> <p>The hazardous waste is lab packed and shipped off-site by a contracted waste hauler.</p>
First Quarter	<p>The City of Tempe conducted non-compliance COVID 19 RNA Biomarker monitoring this quarter.</p>
Second Quarter	<p>The City of Tempe conducted non-compliance COVID 19 RNA Biomarker monitoring this quarter.</p>
Third Quarter	<p>The City of Tempe conducted non-compliance COVID 19 RNA Biomarker monitoring this quarter.</p>
Fourth Quarter	<p>The City of Tempe conducted non-compliance COVID 19 RNA Biomarker monitoring this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Arizona State University Macro Technology Works
Process Flow: 0.140256 MGD

General Information and type of wastewater treatment	<p>The Arizona State University Research Lab is a research facility in partnership with the following firms: DuPont Displays, Kodak, Honeywell, General Dynamics, Raytheon, Universal Display Corp., Kent Displays, E Ink, FlexICs, Three-Five Systems, General Atomics, Optiva, ECD, Southwall, the U.S. Display Consortium, and AGI. The primary project to be developed is a small, portable information screen that soldiers could use on the battlefield. The 250,000-square foot facility includes about 43,500 square feet of clean rooms and wet/dry labs that the University will use to develop the technologies that will go into the project.</p> <p>A large treatment facility is available for the wastewater generated. The primary discharge is from the production of RO reject water, which is neutralized prior to discharge. pH monitoring is taking place per the permit requirements. Discharge volumes are currently at an average of 57 gallons per minute.</p>
First Quarter	No additional activity was performed this quarter.
Second Quarter	No additional activity was performed this quarter.
Third Quarter	No additional activity was performed this quarter.
Fourth Quarter	No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Array Photonics, Inc.

Process Flow: MGD 0.015399

General Information and type of wastewater treatment	
Array Photonics, Inc. conducts multiple final assembly and packaging processes including Photo Lithography, Wet Etching, Deposition, Solvent Cleaning, Oxidation, Wafer Dicing/Grinding, Spin Coating Oven Baking and Parts Cleaning to produce solar cell products. Wastewater treatment consists of waste concentration and pH adjustment.	
First Quarter	No additional activity was performed this quarter.
Second Quarter	No additional activity was performed this quarter.
Third Quarter	No additional activity was performed this quarter.
Fourth Quarter	No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Coxreels, Inc		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 5865 South Ash Avenue Tempe, AZ 85283		MAILING ADDRESS: 5865 South Ash Avenue Tempe, AZ 85283		
CATEGORICAL USER? Yes	40 CFR 433	LIMITS APPENDIX: T-E	BMR SUBMITTED: 4/24/2012	
TTO CERTIFICATION DATE SUBMITTED: 09/14/2020		PERMIT EFFECTIVE: 11/13/2020	PERMIT EXPIRES: 11/12/2024	
SAMPLING LOCATION VERIFIED ON: 11/10/2020		RCRA NOTICE: 4/3/2015		
SLUG CONTROL PLAN EVALUATION DATE: 12/9/2020		COMPLIANCE SAMPLING POINT №: 5101		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	8	0	0	8
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Coxreels, Inc

Process Flow: 0.00497 MGD

General Information and type of wastewater treatment	<p>Coxreels manufactures metal parts that are assembled into retractable hose reels.</p> <p>Coxreels, Inc manufacturing process includes the coating (phosphating) of metal parts in addition to cleaning, machining, grinding, welding, sand blasting, solvent degreasing, and assembly. The phosphating operation prior to powder coating sheet metal and is regulated under 40 CFR 433-Metal Finishing (PSNS).</p> <p>Pretreatment is pH neutralization prior to discharge along with a sump settling tank. There is also continuous pH monitoring of the effluent prior to discharge.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Foresight Finishing LLC (Lodge Dr)

Process Flow: 0.020369 MGD

General Information and type of wastewater treatment	<p>Foresight Finishing LLC conducts Precious Metal Plating, including: Plating Preparation Process, Copper Cyanide, Nickel Electroplating, Electro-less Nickel Plating, Bright Tin, Palladium, Metal Strips, and Gold Cyanide. These processes are identified in 40 CFR 433 - Metal Finishing Point Source Category and is regulated by 40 CFR 433.17 (PSNS).</p> <p>Foresight Finishing is a precious metals gold plating facility and Foresight Finishing specializes in precious and non-precious metal plating. They provide copper, nickel, and gold plating for the following industries: aerospace, defense, medical, electronic, major OEMS, and general job shop facilities. Pretreatment consists of ion exchange filtration and pH adjustment at the end of the process.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Gorilla Industrial Coatings LLC

Process Flow: 0.0046 MGD

General Information and type of wastewater treatment

Gorilla Industrial Coatings is a phosphating and powder coating operation of aluminum or steel. This is a metal finishing operation regulated under 40CFR 433-Metal Finishing Point Source Category, Subpart A-Metal Finishing, Subcategory 433.17-Pretreatment Standards for New Sources (PSNS).
Currently, there is no pretreatment of process discharges at this facility. Overflow City water rinses are the only discharges entering the sanitary sewer.

First Quarter

No additional activity was performed this quarter.

Second Quarter

No additional activity was performed this quarter.

Third Quarter

No additional activity was performed this quarter.

Fourth Quarter

No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Group Manufacturing		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 815 West Geneva Drive Tempe, AZ 85282		MAILING ADDRESS: 3201 South Hardy Drive Tempe, AZ 85282		
CATEGORICAL USER? Yes	40 CFR 433	LIMITS APPENDIX: T-E	BMR SUBMITTED: 3/6/2007	
TTO CERTIFICATION DATE SUBMITTED: 8/31/2020		PERMIT EFFECTIVE: 4/4/2020	PERMIT EXPIRES: 4/3/2024	
SAMPLING LOCATION VERIFIED ON: 9/9/2020		RCRA NOTICE: 4/2/2008		
SLUG CONTROL PLAN EVALUATION DATE: 4/11/2016		COMPLIANCE SAMPLING POINT №: 5062		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	8	3	0	0
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	4	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Daily Cat.	1/28/2020	Composite	Federal	City	Chromium	4.42/2.77mg/L	4
1 st	Daily Cat.	1/30/2020	Composite	Federal	City	Chromium	3.52/2.77mg/L	4
1 st	Daily Cat.	1/31/2020	Composite	Federal	City	Chromium	3.33/2.77mg/L	4
1 st	Monthly Cat.	1/2020	Composite	Federal	City	Chromium	3.10/1.71mg/L	4
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A,B	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Group Manufacturing

Process Flow: 0.001598 MGD

General Information and type of wastewater treatment	<p>Group Manufacturing performs chromating on base material, which is a coating process identified as one of the six metal finishing operations under 40 CFR 433.17 - Metal Finishing Point Source Category , Subpart A - Metal Finishing Subcategory (PSNS).</p> <p>The wastewater treatment consists of pH neutralization.</p>
First Quarter	<p>Group Manufacturing had three Chromium daily categorical violations and one monthly categorical violation in January of 2020. An NOV/AO will be issued in the 2nd quarter.</p>
Second Quarter	<p>On April 30, 2020, Group Manufacturing was issued a NOV/AO for violations in the 1st quarter. Since the daily violations were due to a single root cause in January, Group will only assess one point for their daily violations.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>Group Manufacturing (Group) met the Technical Review Criteria for Significant Non-Compliance (SNC) for four Chromium parameter violations that occurred in 2020. After a conversation with the Arizona Department of Environmental Quality, it was determined that formal SNC assignment and publication was not appropriate in this situation because during the investigations by the city staff as well as Group, it was determined that it was possible that the chromium violations were not truly representative of process discharge conditions based on the fact that the suction line from the installed automatic sampling machine fell out of its placed position in the process waste stream into an internal retention sump that had accumulated solid sludge that was found to have chromium in it, but was not discharged into the sanitary sewer with the process waste. Our investigation concluded that it was possible that some of the sludge had mingled with the sample aliquots making it not possible to definitively defend the representativeness of the samples during those events. Based on Tempe's enforcement response plan, enforcement was reduced to a single occurrence with no administrative fines. Additionally, there was no harm to the POTW or impact on the health and safety of workers within the POTW during that time period.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Harrison Properties Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1115 West Alameda Drive Tempe, AZ 85282		MAILING ADDRESS: 1115 West Alameda Drive Tempe, AZ 85282		
CATEGORICAL USER? No	40 CFR 403	LIMITS APPENDIX: T-A	BMR SUBMITTED: 6/30/1982	
TTO CERTIFICATION DATE SUBMITTED: 7/28/2020		PERMIT EFFECTIVE: 4/1/2019	PERMIT EXPIRES: 3/31/2023	
SAMPLING LOCATION VERIFIED ON: 5/22/2020		RCRA NOTICE: 5/12/1993		
SLUG CONTROL PLAN EVALUATION DATE: 4/4/2019		COMPLIANCE SAMPLING POINT №: 5035		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	4	0	0	4
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	3	0	0	0
Compliance Status	I	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1 st	Instantaneous	1/2020	Instantaneous Grab	City	IU	pH*	<5.0 or >10.5 S.U.	Continuous
1 st	Instantaneous	2/2020	Instantaneous Grab	City	IU	pH	<5.0 or >10.5 S.U.	Continuous
1 st	Instantaneous	3/2020	Instantaneous Grab	City	IU	pH	<5.0 or >10.5 S.U.	Continuous
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A, B, F	A, B, F	E*	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Harrison Prpoerties Inc.
 Process Flow: 0.008872 MGD

General Information and type of wastewater treatment	Harrison Prpoerties Inc. generates process wastewater in the dairy processing operations (CIP) and is regulated under 40 CFR 403.5, Subpart B. Pretreatment includes solids removal interceptors, Best Management Practices, and pH neutralization.
First Quarter	Harrison Prpoerties Inc. had pH exceedances in January, Feburary, and March. Three separate Notice of Violation/Administrative Orders, (NOV/AO) were issued in the 1 st and 2 nd quarter.
Second Quarter	No additional activity was performed this quarter.
Third Quarter	Harrison Prpoerties Inc. entered into a Consent Order, (PSA), in the 3 rd quarter due to violations in the 1 st quarter.
Fourth Quarter	No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 8,750 Collected \$ 8,750

CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Honeywell International		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1300 West Warner Road Tempe, AZ 85284-2822		MAILING ADDRESS: 1300 West Warner Road MS 1201-1M Tempe, AZ 85284-2200		
CATEGORICAL USER? Yes	40 CFR 433	LIMITS APPENDIX: T-E	BMR SUBMITTED: 10/26/1983	
TTO CERTIFICATION DATE SUBMITTED: 8/24/2020	PERMIT EFFECTIVE: 5/1/2019		PERMIT EXPIRES: 4/30/2023	
SAMPLING LOCATION VERIFIED ON: 11/20/2020		RCRA NOTICE: 4/15/1993		
SLUG CONTROL PLAN EVALUATION DATE: 3/25/2020		COMPLIANCE SAMPLING POINT No: 5003		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	8	0	0	7
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Enforcement Status			N	N	N		N	

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Honeywell International

Process Flow: 0.172475 MGD

General Information and type of wastewater treatment

Honeywell is a manufacturer of fluid controls, actuation, power transfer and aerospace system components. The metal finishing of these products is regulated under 40 CFR 433.17.

Pretreatment includes metal precipitation, cyanide oxidization, chromium (+6) reduction and pH adjustment.

First Quarter

No additional activity was performed this quarter.

Second Quarter

No additional activity was performed this quarter.

Third Quarter

No additional activity was performed this quarter.

Fourth Quarter

No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: L3Harris		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1215 South 52nd Street Tempe, AZ 85281		MAILING ADDRESS: 1215 South 52nd Street Tempe, AZ 85281		
CATEGORICAL USER? Yes	40 CFR 433	LIMITS APPENDIX: T-E	BMR SUBMITTED: 7/3/1984	
TTO CERTIFICATION DATE SUBMITTED: 8/6/2020	PERMIT EFFECTIVE: 8/31/2019		PERMIT EXPIRES: 7/31/2023	
SAMPLING LOCATION VERIFIED ON: 6/25/2020	RCRA NOTICE: 12/18/1998			
SLUG CONTROL PLAN EVALUATION DATE: 4/13/2020	COMPLIANCE SAMPLING POINT №: 5023			
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	8	0	0	8
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	A,B	N	N		

Enforcement Status Codes

- | | | |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV)
B - Administrative Order (AO)
C - Civil Action Filed
D - Criminal Action Filed
E - Pretreatment Settlement Agreement (PSA) | F - Assessment of Monetary Penalties
G - Restriction of Flow
H - Permit Revocation
I - Compliance Schedule Issued
J - Disconnection from Sewer | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year
L - Temporary Increase in IU Self-Monitoring (TISM)
N- No Enforcement Action |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: L3Harris

Process Flow: 0.051374 MGD

General Information and type of wastewater treatment	<p>L3Harris is a manufacturer of optoelectronic crystals and infrared devices used in the production of military hardware. The operations are regulated under 40 CFR 433.15.</p> <p>This wastewater treatment system collects rinses from various process areas located within the facility, and is divided into two separate components. The first component consists of a neutralization system for the treatment of acids and alkali rinses (no metals). The second component is the ProChemTech metals removal system. All industrial wastewater is plumbed into the system and segregated into metal bearing and non-metal bearing waste streams.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>L3Harris was issued a Notice of Violation/Administrative Order, (NOV/AO) in the 2nd quarter of 2020 for violations occurring in the 2nd quarter of 2019.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Lawrence Semiconductor Research Laboratory Inc
 Process Flow: 0.0431 MGD

General Information and type of wastewater treatment	<p>Lawrence Semiconductor is permitted as a Class I Significant Industrial User under CFR 469 - Electrical and Electronic Components Point Source Category, Subpart A - Semiconductor Subcategory (469.18 PSNS) as a manufacturer of semiconductor componets dealing with vapor deposition equipment.</p> <p>Pretreatment consists of the addition of sodium hydroxide to their process reaction chambers an as needed and continuous basis for pH adjustment. Hydrofluoric acid, used in the pre-cleaning process of the wafers, is neutralized with ammonium hydroxide prior to discharge into the Tempe Sanitary Sewer System.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes **X** No
 Penalties this reporting Year: Assessed **\$ 0.00** Collected **\$ 0.00**

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Medtronic Tempe Campus

Process Flow: 0.08203 MGD

General Information and type of wastewater treatment	<p>Medtronic Microelectronics Center performs precious metal electroplating regulated under 40 CFR 433.17. The pretreatment process includes metal precipitation, filtration, and continuous pH neutralization. Internal self-monitoring is performed on a daily basis.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Microchip Technology Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1200 South 52nd Street Tempe, AZ 85281		MAILING ADDRESS: 1200 South 52nd Street Tempe, AZ 85281		
CATEGORICAL USER? Yes	40 CFR 469	LIMITS APPENDIX: T-F	BMR SUBMITTED: 3/28/1994	
TTO CERTIFICATION DATE SUBMITTED: 7/23/2020		PERMIT EFFECTIVE: 9/15/2017	PERMIT EXPIRES: 9/14/2021	
SAMPLING LOCATION VERIFIED ON: 11/23/2020		RCRA NOTICE: 3/28/1994		
SLUG CONTROL PLAN EVALUATION DATE: 5/3/2019		COMPLIANCE SAMPLING POINT №: 5029		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	8	0	0	8
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)
Enforcement Status			N	N		N		N

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Microchip Technology Inc.

Process Flow: 0.582830 MGD

General Information and type of wastewater treatment	<p>Microchip manufactures semiconductor devices regulated under 40 CFR 469.18 PSNS. Pretreatment consists of pH neutralization, using either sulfuric acid or sodium hydroxide.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

CITY OF TEMPE SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Photo Design Of Arizona		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 3105 South Potter Drive Tempe, AZ 85282		MAILING ADDRESS: 3105 South Potter Drive Tempe, AZ 85282		
CATEGORICAL USER? Yes	40 CFR 433	LIMITS APPENDIX: T-E	BMR SUBMITTED: 10/27/1994	
TTO CERTIFICATION DATE SUBMITTED: 8/4/2020		PERMIT EFFECTIVE: 4/1/2017	PERMIT EXPIRES: 3/31/2021	
SAMPLING LOCATION VERIFIED ON: 11/24/2020		RCRA NOTICE: 6/15/1993		
SLUG CONTROL PLAN EVALUATION DATE: 2/1/2018		COMPLIANCE SAMPLING POINT №: 5058		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	3	0	0	4
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Photo Design Of Arizona

Process Flow: 0.00118 MGD

General Information and type of wastewater treatment	<p>Photo Design of Arizona, Inc. is a printed circuit board manufacturing operation as listed in both the development document and guidance manual for Metal Finishing Point Source Category operations. Metal Finishing is listed as an EPA Categorical Industry under 40 CFR 403.6, and is regulated under 40 CFR 433. Photo Design is identified as a New Source since operations started after the promulgation date of July 15, 1983, of 40 CFR 433. Photo Design is also classified as a Significant Industrial User under 40 CFR 403.3(t)(1)(i).</p> <p>The pretreatment consists of electrolytic and polishing columns which flow to an evaporator and do not enter the sanitary sewer (zero waste discharge). Rinse waters are discharged to the POTW. Photo Design is required to analyze and document all batch discharges.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Precision Die & Stamping

Process Flow: 0.00158 MGD

General Information and type of wastewater treatment	<p>Precision Die & Stamping (PD&S) machines various metal parts regulated under 40CFR 433-Metal Finishing Point Source Category, Subpart A-Metal Finishing, Subcategory 433.17-Pretreatment Standards for New Sources (PSNS).</p> <p>The pretreatment system is an advanced water recycling system, which uses chemical precipitation to remove metals from the wastewater and pH adjustment of the treated effluent.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Precision Powdercoat

Process Flow: 0.0081 MGD

General Information and type of wastewater treatment	<p>Precision Powdercoat is a phosphater and powder coating operation of stereo amplifiers and speakers. This is a metal finishing operation regulated under 40CFR 433-Metal Finishing Point Source Category, Subpart A-Metal Finishing, Subcategory 433.17-Pretreatment Standards for New Sources (PSNS).</p> <p>Pretreatment of process discharge is continuously monitored for pH via a strip chart recorder. Rinse water makes up the majority of wastewater discharges entering the Tempe Sanitary Sewer System.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Schreiber Foods Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2122 South Hardy Drive Tempe, AZ 85282		MAILING ADDRESS: 2122 South Hardy Drive Tempe, AZ 85282		
CATEGORICAL USER? No	40 CFR 403	LIMITS APPENDIX: T-A	BMR SUBMITTED: 3/30/1985	
TTO CERTIFICATION DATE SUBMITTED: 8/19/2020		PERMIT EFFECTIVE: 3/01/2019	PERMIT EXPIRES: 2/28/2023	
SAMPLING LOCATION VERIFIED ON: 11/26/2020		RCRA NOTICE: 6/23/1993		
SLUG CONTROL PLAN EVALUATION DATE: 12/2/2019		COMPLIANCE SAMPLING POINT №: 5036		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	11	0	4	4
Number of IU Sampling Days	91	91	92	88
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Schreiber Foods Inc.

Process Flow: 0.193650 MGD

General Information and type of wastewater treatment	<p>Schreiber is a manufacturer of pasteurized processed cheese as defined under 21 CFR 133.169. Discharged wastewater is generated in the cleaning process and is regulated under 40 CFR 405, Subpart F. There are no specific categorical standards under 40 CFR 403.5, Subpart F.</p> <p>pH is adjusted by a Carbon Dioxide (CO2) injection system into a 6000-gal. mixing vault prior to discharging to the sewer.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Southwest Metal Finishing Inc.

Process Flow: 0.002649 MGD

General Information and type of wastewater treatment	<p>Southwest Metal Finishing performs metal finishing of aluminum parts by means of chemical processing: anodizing and chromic acid dyes. These processes are both listed under 40 CFR 433 - Metal Finishing Category, anodizing and conversion coating.</p> <p>Wastewater pretreatment is conducted through the use of a batch system, using chemical treatment for chromium, nickel removal and pH neutralization.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: SRP - KYRENE GENERATING STATION		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 7005 South Kyrene Road Tempe, AZ 85283		MAILING ADDRESS: PO Box 52025 Phoenix, AZ 85072		
CATEGORICAL USER? Yes	40 CFR 423	LIMITS APPENDIX: T-K	BMR SUBMITTED: 6/24/2013	
TTO CERTIFICATION DATE SUBMITTED: 8/31/2020		PERMIT EFFECTIVE: 11/15/2017	PERMIT EXPIRES: 11/14/2021	
SAMPLING LOCATION VERIFIED ON: 11/30/2020		RCRA NOTICE: 4/10/2014		
SLUG CONTROL PLAN EVALUATION DATE: 2/1/2019		COMPLIANCE SAMPLING POINT №: 5104		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	0	0	0	0
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

A - Notice of Violation (NOV) F - Assessment of Monetary Penalties K - Published in Newspaper for Significant
 B - Administrative Order (AO) G - Restriction of Flow Non-Compliance (SNC) In Prior Reporting Year
 C - Civil Action Filed H - Permit Revocation L - Temporary Increase in IU Self-Monitoring (TISM)
 D - Criminal Action Filed I - Compliance Schedule Issued
 E - Pretreatment Settlement Agreement (PSA) J - Disconnection from Sewer N- No Enforcement Action

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: SRP - KYRENE GENERATING STATION

Process Flow: MGD

General Information and type of wastewater treatment	<p>SRP- Kyrene 7 Generating Station (K7GS) consists of two distinct power plants: the KGS is on the east side and Unit K7 is on the west side of a 33 acre site. Electric power generating plants are regulated under 40 CFR 423.10 Steam Electric Power Generating Point Source Category.</p> <p>Well water is sent to a well water holding tank, where it goes into a filtration and chlorination process before being sent to the cooling tower (CT). Other low volume waste water is sent to the CT basin for reuse as cooling water make-up. These waters include HRSG blowdown, evaporative cooler blowdown, RO system reject, and laboratory sampling waters. The CT blowdown and filter backwash water are transferred to a 50,000-gallon wastewater tank prior to final discharge.</p>
First Quarter	<p>SRP is not sampled as a matter of course because their process blowdown wastewater is discharged to a surface water body regulated under an ADEQ issued AZPDES permit. SRP asked to retain the option to conditionally divert and discharge process wastewater into Tempe's Sanitary Sewer under certain emergency circumstances. Discharge conditions are identified in their Industrial User Permit.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>No additional activity was performed this quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Sun Orchard LLC		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1198 West Fairmont Drive Tempe, AZ 85282		MAILING ADDRESS: 1198 West Fairmont Drive Tempe, AZ 85282		
CATEGORICAL USER? No	40 CFR 403	LIMITS APPENDIX: T-A	BMR SUBMITTED: 11/30/1990	
TTO CERTIFICATION DATE SUBMITTED: 9/2/2020		PERMIT EFFECTIVE: 6/15/2017	PERMIT EXPIRES: 6/14/2021	
SAMPLING LOCATION VERIFIED ON: 6/30/2020		RCRA NOTICE: 5/15/1993		
SLUG CONTROL PLAN EVALUATION DATE: 5/22/2020		COMPLIANCE SAMPLING POINT №: 5064		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	4	0	0	4
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	2
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	I
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
4 th	Prohibited Discharge Prohibited Discharge	10/21/2020	Composite	City	City	4,4' - DDE	0.0051 mg/l None	2
4 th		10/22/2020	Composite	City	City	4,4' - DDE	0.017 mg/l None	2
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Sun Orchard LLC

Process Flow: 0.033955 MGD

General Information and type of wastewater treatment	<p>Sun Orchard is a producer and bottler of fresh orange juice as defined under 21 CFR 146.135. Wastewater consists of residue-rinses and mild chlorinated cleaning solution. This process is regulated under 40 CFR 407, Subpart C and local limits</p> <p>Pretreatment consists of batch pH adjustment. Process solid waste consisting of citrus hulls and excess pulp is recycled into cattle feed.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>Sun Orchard LLC (Sun Orchard) had parameter violations on 10/21/2020 and 10/22/2020. A Notice of Violation/Administrative Order, (NOV/AO) was issued in the 1st quarter of 2021.</p> <p>Sun Orchard met the Criteria for Chronic Significant Non-Compliance (SNC) for the two parameter violations that occurred in 2020. After a conversion with the Arizona Department of Environmental Quality, it was determined that formal SNC assignment and publication was not appropriate in this situation because city monitoring of all IUs was reduced in 2020 due to the COVID 19 pandemic, and by no fault of Sun Orchard's their sampling was performed in the 4th quarter of 2020. Additionally, the city performs all IU monitoring for the permitted IUs under the oversight the pretreatment program unless otherwise stipulated in a respective discharge permit. Tempe only became aware of the Sun Orchard results in late December, which did not give the city, or Sun Orchard, adequate time to perform enough additional monitoring within the SNC Quarter. Based on Tempe's enforcement response plan, enforcement was initiate for each occurrence which resulted in an administrative fine of \$3,750.00. Additionally, there was no harm to the POTW or impact on the health and safety of workers within the POTW during that time period.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Swire Coca-Cola, USA - Tempe Production Center
 Process Flow: 0.223214 MGD

General Information and type of wastewater treatment	<p>The City of Tempe regulates Swire Coca-Cola Bottling Company as a Class I Significant Industrial User based on process wastewater discharges of greater than 25,000 gallons per day.</p> <p>The pretreatment consists of two 1500-gallon FOG interceptors, two-stage pH neutralization using CO2 and Sodium Hydroxide, effluent flow monitoring and online pH monitoring/recording.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>An Industrial Discharge Permit was reissued in the 4th quarter.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes No
 Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Trion Technology Inc

Process Flow: 1,100 GPD

General Information and type of wastewater treatment	
<p>Trion Technology is a semiconductor manufacturer regulated under 40 CFR 469, Subpart A. Process waste is sent to a neutralization tank, where it is adjusted for pH with NaOH.</p>	
First Quarter	
<p>No additional activity was performed this quarter.</p>	
Second Quarter	
<p>No additional activity was performed this quarter.</p>	
Third Quarter	
<p>No additional activity was performed this quarter.</p>	
Fourth Quarter	
<p>No additional activity was performed this quarter.</p>	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**CITY OF TEMPE
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: United Dairymen of Arizona		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 2008 South Hardy Drive Tempe, AZ 85282		MAILING ADDRESS: P.O. Box 26877 Tempe, AZ 85285-6877		
CATEGORICAL USER? No	40 CFR 403	LIMITS APPENDIX: T-A	BMR SUBMITTED: 7/30/1982	
TTO CERTIFICATION DATE SUBMITTED: 8/3/2020		PERMIT EFFECTIVE: 10/1/2018	PERMIT EXPIRES: 9/30/2022	
SAMPLING LOCATION VERIFIED ON: 11/26/2020		RCRA NOTICE: 7/12/1993		
SLUG CONTROL PLAN EVALUATION DATE: 11/16/2018		COMPLIANCE SAMPLING POINT №: 5042		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	0	1
Number of City Sampling Days	11	0	4	4
Number of IU Sampling Days	91	91	92	92
Number of Parameter Violations	1	0	1	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	I	C	I	C
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
1st	Instantaneous	2/2020	Instantaneous Grab	City	IU	pH	<5.0 or >10.5 S.U.	Continuous
3rd	Instantaneous	8/2020	Instantaneous Grab	City	IU	pH	<5.0 or >10.5 S.U.	Continuous
			1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			A,B	N	A,B	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | N- No Enforcement Action |

Company Name: United Dairymen of Arizona

Process Flow: 1.381174 MGD

General Information and type of wastewater treatment

United Dairymen of Arizona is a milk receiving station (PSES), no limitations, receiving 7 to 12 million pounds of milk per day. Also on site is a butter manufacturing process (PSES), no limitations, and a dry milk process (PSES), no limitations. The facility is regulated by 40 CFR 405 PSES Subparts A, D, J, and L. All the above Subparts refer back to 40 CFR 403 for enforcement of discharge limitations.

The pretreatment consists of a number of interceptors for solids removal and pH neutralization of the final effluent. UDA has installed a high-strength caustic reclaim and BOD/TSS reduction system to reduce its high strength organic loadings and to control the pH of its effluent. UDA has also installed a 7,000-gallon lift vault and a 108,000-gallon surge/storage tank upstream of its final pH adjustment pretreatment system to prevent surcharging its final effluent pH treatment system and to allow for increased contact time for the commingled acid and caustic rinse waters.

First Quarter

United Dairymen of Arizona had a pH exceedance in February. A Notice of Violation/Administrative Order, (NOV/AO) was issued in the 1st quarter.

Second Quarter

No additional activity was performed this quarter.

Third Quarter

United Dairymen of Arizona had a pH exceedance in August. A Notice of Violation/Administrative Order, (NOV/AO) was issued in the 3rd quarter.

Fourth Quarter

No additional activity was performed this quarter.

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT

NAME: Versum Materials US, LLC		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 8555 South River Parkway Tempe, AZ 85282		MAILING ADDRESS: 8555 South River Parkway Tempe, AZ 85282		
CATEGORICAL USER? No	40 CFR 403	LIMITS APPENDIX: T-A	BMR SUBMITTED: 12/1/2010	
TTO CERTIFICATION DATE SUBMITTED: 9/20/2020		PERMIT EFFECTIVE: 4/25/2019	PERMIT EXPIRES: 4/23/2023	
SAMPLING LOCATION VERIFIED ON: 6/08/2020		RCRA NOTICE: 6/14/2017		
SLUG CONTROL PLAN EVALUATION DATE: 10/26/2018		COMPLIANCE SAMPLING POINT №: 5091		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	1	0	0
Number of City Sampling Days	4	0	0	0
Number of IU Sampling Days	0	0	0	0
Number of Parameter Violations	0	0	0	1
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	I
Evaluated as of:	03/31/2020	06/30/2020	9/30/2020	12/31/2020

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
 If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
4 th	Instantaneous	10/27	Instantaneous Grab	City	IU	pH	:5.0 or >10.5 S.U.	Continuous
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self-Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Versum Materials US, LLC

Process Flow: 0.04469 MGD

General Information and type of wastewater treatment	<p>Versum Materials develops and manufactures colloidal silica sols and particles for electronic applications. On site operations consist of blending specific product formulations and quality assurance testing of blended slurry. Quality assurance testing is performed inside a clean room where wafers and other electronic substrates are polished to smooth finishes.</p> <p>Waste is transferred from CMP to a mixing tank. Air agitation and chemical addition are used for pH adjustment in a second tank. Process is expected to be 20000 GPD.</p>
First Quarter	<p>No additional activity was performed this quarter.</p>
Second Quarter	<p>No additional activity was performed this quarter.</p>
Third Quarter	<p>No additional activity was performed this quarter.</p>
Fourth Quarter	<p>A pH violation occurred in the 4th quarter of 2020. A warning notification was issued in the 1st quarter. No formal enforcement action was initiated because this was a single four minutes occurrence and the user has no previous violation history.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

SECTION 2.6
TOWN OF GILBERT

POTW PRETREATMENT ANNUAL REPORT

TOWN OF GILBERT, ARIZONA

NPDES Permit Holder: City of Phoenix, Arizona

Period Covered by this Report: 01/01/2020 through 12/31/2020

Name of Wastewater Treatment Plant: 91st Avenue Wastewater Treatment Plant

NPDES Permit Number: AZ0020524

Person to Contact Concerning City of Gilbert Information Contained in the Report:

Edward Meza
Pretreatment Program Coordinator
900 E. Juniper Avenue
Gilbert, Arizona 85234
480-503-6463

As required by 40 C.F.R. Section 122.22(b)(2):

I certify under penalty of law that all TOWN OF GILBERT attachments contained in this document were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

2-3-2021

Jessica L Marlow

Date:

Jessica Marlow
Public Works Director
Town of Gilbert, Arizona

The Town of Gilbert is a young, affluent community in central Arizona.

In 1902, the Arizona Eastern Railway asked for donations of right of way in order to establish a rail line between Phoenix and Florence. A rail siding was established on property owned by William "Bobby" Gilbert. The siding, and the town that sprung up around it, eventually became known as Gilbert. Gilbert was a prime farming community, fueled by the construction of the Roosevelt Dam and the Eastern and Consolidated Canals in 1911. It remained an agriculture town for many years, and was known as the "Hay Capital of the World" until the late 1920's. Incorporated on July 6, 1920, Gilbert is a relatively new community that has seen tremendous growth during the past three decades.

Gilbert began to take its current shape during the 1970's when the Town Council approved a strip annexation that encompassed 53 square miles of county land. Although the population was only 1,971 in 1970 the Council realized that Gilbert would eventually grow and develop much like the neighboring communities of Tempe, Mesa, and Chandler. This proved to be a farsighted decision as Gilbert positioned itself for growth in the 1980's and beyond. Gilbert's planning area now encompasses 73 square miles.

Gilbert has experienced a rapid transition from a historically agriculture-based community to an urban center and suburb in the Phoenix Metropolitan Area. In the last thirty-four years Gilbert has grown at a pace unparalleled by most communities in the United States, increasing in population from 5,717 in 1980 to over 246,423 as of July 1, 2017. As Gilbert has grown, the community has recognized the need to develop a strong, diverse economy while preserving its highly desirable quality of life.

Gilbert has made the commitment to utilize 100% of its wastewater. Our Wastewater Treatment facilities are designed and operated to produce high quality effluent that is used for groundwater recharge, which builds up reserves for future drinking water use. The reuse water is also utilized for golf course watering, artificial lakes and landscape irrigation throughout the Town at a water rate approximately ½ the cost of potable water.

Pretreatment Program Summary

Reporting Period: 01/01/2020 to 12/31/2020

Implementing a wastewater survey form that must be completed as part of the Town's business license program has helped identify new users. There were 913 new business licenses processed during the 2020 reporting period. Of these 188 were possible new commercial and industrial users.

The Town of Gilbert continues to identify new facilities that meet Categorical or SIU criteria for wastewater discharge permits. There were 39 industrial user inspections and 39 Storm Water Inspections conducted in 2020. The Town also conducted 37 sampling events over 259 days and 4 flow studies over 96 days. At the end of 2020 there were 158 industrial user's in the Town's pretreatment database, of these 25 are permitted which include Five Class 'A' SIU's and Twenty Class 'B' IU's.

The Town of Gilbert has continued its commercial inspection program. The programs goal is to inspect all food service facilities, automotive service facilities, dry cleaners, and silver photo & x-ray developers annually. There were approximately 1,582 commercial inspections, and 1,582 storm water inspections conducted in 2020.

Individual Training: Pretreatment Program Coordinator (PPC)
Industrial Pretreatment Inspector (IPI)
Wastewater Quality Inspector (WWQI)

All personnel had confined space and fall protection training.

All personnel attended PPE / Bloodborne Pathogens Training

All personnel attended Lock Out/Tag Out procedures training.

All personnel attended Hazwoper refresher training.

All personnel attended Electrical Awareness Safety Training.

All personnel attended Illicit Discharge Storm Water Training.

All personnel trained on Kronos Dimensions

All personnel attended webinars regarding Linko Database

All personnel attended webinars unconscious bias training

All personnel attended required quarterly training by the People Team.

PPC attended National Pretreatment Conference.

All personnel attended Pretreatment Seminar.

WWQI 2) are attending Phoenix Compliance Academy.

All attended webinars on Flow Studies and Flow Link from Isco.

PPC and WWQI (2) attended webinars on Plans Review and use of Blue Beam.

WWQI is on Wellness Committee.

WWQI is on Green Gilbert Committee.

WWQI obtained ADEQ Collections Grade 1 Certification

Best Management Practices

Pollution Prevention through Point Source Control Measures

Reporting Period: 01/01/2020 to 12/31/2020

Introduction

Section C.1 of the National Pollutant Discharge Elimination System (NPDES) Permit # AZ0020524 requires the Sub-Regional Operating Group (SROG) member cities to submit annual progress reports detailing efforts pertaining to pollution prevention through point source control measures. Gilbert's efforts during the year 2020 are summarized below.

Pollution Prevention Efforts with Industry

The town developed and printed up brochures on grease traps and interceptors and another on silver recovery units. These are given during inspections of facilities, and during other public outreach events. We have also developed BMP's for food service facilities, automotive service facilities, printers, and silver photo and x-ray processors. These are given to these facilities during routine annual inspections. Since 2004 BMP's have been part of the Town Municipal Code.

Storm Water

The town has storm water BMP's for certain types of businesses; such as restaurants, automotive shops, carpet cleaners and a general business one. There are also Spanish versions of these brochures available. These brochures are being distributed by Wastewater Quality during the normal inspection schedule.

SROG Participation

The Town of Gilbert Staff continues to participate in periodic SROG meetings. SROG Group addresses Pretreatment Issues effecting the respective municipality participants. The Town of Gilbert's Pretreatment Coordinator attends SROG advisory meetings.

AZFOG Participation

The Town of Gilbert Staff continues to participate in periodic AZFOG meetings. The goal of the AZFOG Group is to reduce the amount of FOG that enters the sanitary sewer through calibration with neighboring municipalities. The Town of Gilbert's Pretreatment Personnel attends AZFOG meetings. The Pretreatment Coordinator assists in providing instruction at Pretreatment AZFOG Seminars to educate Pretreatment Personnel.

Pollution Prevention Green Gilbert Program

The Town of Gilbert Staff continues to participate in Green Gilbert Pollution Prevention meetings and conduct inspections for approval into the Green Gilbert Program.

Wastewater Effluent/Reuse

Presentations continue to be given at events such as the Spring Festival and the Trails Day Event at the Riparian Preserve on effluent recharge. Numerous tours were given to groups interested in the recharge treatment process and daily operation at the Riparian Preserve when available.

Household Hazardous Waste

Since 2007 the Town opened a permanent Household hazardous Waste Drop off Station. Through this Station the Town continues to collect items throughout the year such as batteries, fluorescent bulbs, used oil, and aerosol cans.

Collection Site

The Household Hazardous Waste Drop Off Station is located at the South Area Service Center the corner Greenfield Road and Queen Creek Road.

Christmas Trees

The Town in the past has collected Christmas trees. The trees were chipped and then used for landscaping purposes. Due to COVID circumstances they were not collected this year.

Grease Recycling

The Town collected used fryer oil all year long. The collection site was at the Household Hazardous Waste Drop Off Station. It was collected by Thermofluids for recycling.

Partnership with Gateway Community College

The Town assists in conducting educational opportunities for Gateway Community College Students in Pretreatment Compliance and Pollution Prevention. Due to COVID circumstances this did not take place this past year.

TOWN OF GILBERT

SUMMARY OF PRETREATMENT PROGRAM EXPENDITURES

January 1, 2020 – December 31, 2020 – Total Pretreatment Expenditures **\$ 545,620**

PRETREATMENT PROGRAM PERSONNEL

<u>Title</u>	<u>FTEs 2019</u>	<u>FTEs 2020</u>
Pretreatment Program Coordinator	1	1
Industrial Pretreatment Inspector	1	1
Wastewater Quality Inspector	4	4

PRETREATMENT PROGRAM EXPENDITURES

Personnel	\$ 455,385
Analytical Laboratory Services	\$ 11,100
Vehicle Operations & Maintenance	\$13,550
Training/Tuition	\$ 4,175
Program Operations & Maintenance	\$61,410

PRETREATMENT EQUIPMENT INVENTORY

<u>Equipment Name</u>	<u>Purchased 2020</u>	<u>Total 2020</u>
Samplers	1	5
Flow Meters & Modules	0	7
pH Meters	0	2
Vehicles	2	6
Computers (Laptops/IPads)	0(2)	6(7)

**TOWN OF GILBERT
LIST OF SIGNIFICANT INDUSTRIAL USERS AS OF 12/31/2020**

	COMPANY NAME AND ADDRESS	WWTP	NAICS Code	Regulation
1.	Banner Gateway Medical Center 1900 North Higley Road Gilbert, Arizona 85234-1904	91 st Ave via Neely	622110	Local Limits
2.	First Impression Iron Works, Inc. 1235 West Harwell Road Gilbert, Arizona 85233	91 st Ave via Neely	325510	40 CFR 433: Metal Finishing Point Source Category
3.	Herbally Yours, Inc. 1504 West San Pedro Street Gilbert, Arizona 85233-2412	91 st Ave via Neely	325412	40 CFR 439: Pharmaceutical Manufacturing Point Source Category
4.	Mercy Gilbert Medical Center 3555 South Val Vista Drive Gilbert, Arizona 85296-7323	91 st Ave via Neely or Greenfield	622110	Local Limits
5.	Unique Home Design, Inc. 973 North Colorado Street Gilbert, Arizona 85233-2274	91 st Ave via Neely	325510	40 CFR 433: Metal Finishing Point Source Category

TOWN OF GILBERT

PRETREATMENT PERFORMANCE SUMMARY ADDITIONS, DELETIONS AND CHANGES TO THE SIU LIST

ADDITIONS

The following Significant Industrial Users were added in 2020:

No changes in 2020.

DELETIONS

The following Significant Industrial Users have ceased operations in 2020:

1. Heliae Development, LLC
3776 South Riata Street
2. Innovative Circuits Arizona
130 North Pasadena Street

RECLASSIFICATIONS

The following Significant Industrial Users have been reclassified in 2020:

No changes in 2020.

NAME CHANGES

The following Significant Industrial Users changed their names in 2020:

No changes in 2020.

Town of Gilbert
PRETREATMENT PERFORMANCE SUMMARY
91st Avenue Wastewater Treatment Plant

I. General Information							
Control Authority Name: Town of Gilbert			NPDES No.: AZ0020524				
Address: 900 East Juniper Avenue		City: Gilbert		State: Arizona		ZIP: 85234-4714	
Contact Person: Edward Meza				Contact Telephone Number: 480-503-6463			
Reporting Period: January 1 – December 31, 2020			Categorical IUs: 4		Significant Non-Categorical IUs: 3		
II. Significant Industrial User Compliance							
		Categorical		Non-categorical		Total SIUs	
		No.	%	No.	%	No.	%
1.	No. of SIUs in Full Compliance	4	100	3	100	7	100
2.	No. of SIUs in Inconsistent Compliance	0	0	0	0	0	0
3.	No. of SIUs in Significant Noncompliance	0	0	0	0	0	0
4.	No. of Parameter Violations	0		0		0	
5.	No. of Reporting Violations	0		0		0	
6.	No. of Permit Condition Violations	0		0		0	
III. Compliance Monitoring Program							
		Categorical		Non-categorical		Total SIUs	
1.	No. of Control Documents Issued	1		1		2	
2.	No. of Nonsampling Inspections Conducted	3		3		6	
3.	No. of Facilities Inspected (Nonsampling)	3		3		6	
4.	No. of Sampling Visits Conducted	10		8		18	
5.	No. of Facilities Sampled	3		3		6	
IV. Enforcement Actions							
		Categorical		Non-categorical		Total SIUs	
1.	Notices of Violations Issued to SIUs	0		0		0	
2.	Temporary Increase in IU Self Monitoring	0		0		0	
3.	Administrative Orders Issued to SIUs	0		0		0	
4.	Compliance Schedules Issued	0		0		0	
5.	Settlement Agreements	0		0		0	
6.	Other Actions	0		0		0	
7.	Amount of Penalties Collected (Total Dollars / IUs Assessed)	\$ 0.00 / 0		\$ 0.00 / 0		\$ 0.00 / 0	

**TOWN OF GILBERT
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Banner Gateway Medical Center		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1900 North Higley Road Gilbert, Arizona 85234-1904		MAILING ADDRESS: Same		
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 11-26-2007	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 01-01-2017	PERMIT EXPIRES: 12-31-2021	
SAMPLING LOCATION VERIFIED ON: 07-28-20		RCRA NOTICE: 02-13-15		
SLUG CONTROL PLAN EVALUATION DATE: 07-28-20		COMPLIANCE SAMPLING POINT No: 2" Parshall Flume		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	0	0	0	3
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	02-04-21	02-04-21	02-04-21	02-04-21

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Banner Gateway Medical Center

Process Flow: 65,000 GPD Average Daily Discharge

General Information and type of wastewater treatment	
Banner Gateway Medical Center is a hospital which operations include Cooling Tower, Boiler Feed, Humidification, Plaster Trap, Acid Waste Neutralization, Grease Interceptor, and Other Hospital Operations and Associated Rinses.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**TOWN OF GILBERT
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: First Impression Iron Works, Inc.				REPORT PERIOD: 01/01/2020 through 12/31/2020				
SERVICE ADDRESS: 1235 West Harwell Road Gilbert, Arizona 85233				MAILING ADDRESS: 1415 North Mondel Drive Gilbert, Arizona 85233-1209				
CATEGORICAL USER? Yes		40 CFR 433.17		LIMITS APPENDIX: E		BMR SUBMITTED 02-06-2013		
TTO CERTIFICATION DATE SUBMITTED: N/A				PERMIT EFFECTIVE: 01-01-2018		PERMIT EXPIRES: 12-31-2021		
SAMPLING LOCATION VERIFIED ON: 08-12-19				RCRA NOTICE: 02-12-15				
SLUG CONTROL PLAN EVALUATION DATE: 09-20-18				COMPLIANCE SAMPLING POINT No: 22 ½ ° V-Notch Weir				
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0		0		1		0	
Number of City Sampling Days	0		0		0		3	
Number of IU Sampling Days	3		3		3		3	
Number of Parameter Violations	0		0		0		0	
Number of Inspection Violations	0		0		0		0	
Number of Reporting Violations	0		0		0		0	
Number of Permit Cond. Violations	0		0		0		0	
Compliance Status	C		C		C		C	
Evaluated as of:	02-04-21		02-04-21		02-04-21		02-04-21	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Enforcement Status	N		N		N		N	

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N - No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: First Impression Iron Works, Inc.
Process Flow: 600 GPD Average Daily Discharge

General Information and type of wastewater treatment	
First Impressions Security Doors, Inc. performs powder coating, coating conversion, acid cleaning and associated rinses. Treatment includes pH neutralization.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No
Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**TOWN OF GILBERT
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Heliae Development, LLC				REPORT PERIOD: 01/01/2020 through 12/31/2020				
SERVICE ADDRESS: 3776 South Riata Street Gilbert, Arizona 85297				MAILING ADDRESS: 578 East Germann Road Gilbert, Arizona 85297-2907				
CATEGORICAL USER? No		40 CFR Local Limits		LIMITS APPENDIX: A		BMR SUBMITTED: 01-08-15		
TTO CERTIFICATION DATE SUBMITTED: N/A				PERMIT EFFECTIVE: 01-01-2019		PERMIT EXPIRES: 12-31-2020		
SAMPLING LOCATION VERIFIED ON: 11-30-20				RCRA NOTICE: 02-12-15				
SLUG CONTROL PLAN EVALUATION DATE: 11-30-20				COMPLIANCE SAMPLING POINT No: Sampling Port – Holding Tank				
	1st Quarter (Jan 1 - Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 - Sep 30)		4th Quarter (Oct 1 - Dec 31)	
Number of Inspections	0		0		0		1	
Number of City Sampling Days	0		0		2		0	
Number of IU Sampling Days	3		2		2		0	
Number of Parameter Violations	0		0		0		0	
Number of Inspection Violations	0		0		0		0	
Number of Reporting Violations	0		0		0		0	
Number of Permit Cond. Violations	0		0		0		0	
Compliance Status	C		C		C		C	
Evaluated as of:	02-04-21		02-04-21		02-04-21		02-04-21	

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter	
			1st Quarter (Jan 1 – Mar 31)		2nd Quarter (Apr 1 - Jun 30)		3rd Quarter (Jul 1 – Sep 30)		4th Quarter (Oct 1 - Dec 31)
Enforcement Status			N		N		N		N

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Heliae Development, LLC

Process Flow: 65,000 GPD Average Daily Discharge

General Information and type of wastewater treatment	<p>Heliae is in the production of microalgae biomass with discharge from their waste holding tank water (Batch) originating from Greenhouse area, Seed Room, Dewatering of algae, and their associated cleaning and rinses.</p>
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	<p>11-30-20 – Last discharge was September 2020. Permit will not be renewed. Heliae Development, LLC is vacating the premises. They are out of business at this location.</p>

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**TOWN OF GILBERT
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Herbally Yours, Inc.		REPORT PERIOD: 01/01/2020 through 12/31/2020		
SERVICE ADDRESS: 1504 West San Pedro Street Gilbert, Arizona 85233-2412		MAILING ADDRESS: Same		
CATEGORICAL USER? Yes	40 CFR 439.47	LIMITS APPENDIX: L	BMR SUBMITTED 02-28-2003	
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 01-01-2021	PERMIT EXPIRES: 12-31-2024	
SAMPLING LOCATION VERIFIED ON: 08-05-20		RCRA NOTICE: 12-30-2002		
SLUG CONTROL PLAN EVALUATION DATE: 06-10-19		COMPLIANCE SAMPLING POINT No: 22 ½ ° V-Notch Weir		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)	4th Quarter (Oct 1 - Dec 31)
Number of Inspections	0	0	1	0
Number of City Sampling Days	0	0	3	0
Number of IU Sampling Days	3	3	3	3
Number of Parameter Violations	0	0	0	0
Number of Inspection Violations	0	0	0	0
Number of Reporting Violations	0	0	0	0
Number of Permit Cond. Violations	0	0	0	0
Compliance Status	C	C	C	C
Evaluated as of:	02-04-21	02-04-21	02-04-21	02-04-21

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Herbally Yours, Inc.

Process Flow: 2,000 GPD Average Daily Discharge

General Information and type of wastewater treatment	
Herbally Yours Inc. performs Mixing, Compounding, and Formulation operations of nutritional supplements. Treatment includes separation and pH neutralization.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Innovative Circuits Arizona

Process Flow: 250 GPD Average Daily Discharge

General Information and type of wastewater treatment	
Population and cleaning of circuit boards. Resin column filtration for metallic. Zero Discharge Conformal Coating.	
First Quarter	
Second Quarter	
Third Quarter	August – Innovative Circuits Arizona is no longer discharging at this facility. They will be vacating the premises. They will be out of business at this location. The permit was terminated upon their vacancy.
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

**TOWN OF GILBERT
SIGNIFICANT INDUSTRIAL USER COMPLIANCE STATUS REPORT**

NAME: Mercy Gilbert Medical Center		REPORT PERIOD: 01/01/2020 through 12/31/2020	
SERVICE ADDRESS: 3555 South Val Vista Drive Gilbert, Arizona 85296-7323		MAILING ADDRESS: Same	
CATEGORICAL USER? No	40 CFR Local Limits	LIMITS APPENDIX: A	BMR SUBMITTED: 07-27-2006
TTO CERTIFICATION DATE SUBMITTED: N/A		PERMIT EFFECTIVE: 07-01-2020	PERMIT EXPIRES: 06-30-2022
SAMPLING LOCATION VERIFIED ON: 12-01-20		RCRA NOTICE: 02-12-15	
SLUG CONTROL PLAN EVALUATION DATE: 06-06-19	COMPLIANCE SAMPLING POINT No: 3" Parshall Flume		
	1st Quarter (Jan 1 - Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 - Sep 30)
	4th Quarter (Oct 1 - Dec 31)		
Number of Inspections	0	0	0
Number of City Sampling Days	0	0	0
Number of IU Sampling Days	3	3	3
Number of Parameter Violations	0	0	0
Number of Inspection Violations	0	0	0
Number of Reporting Violations	0	0	0
Number of Permit Cond. Violations	0	0	0
Compliance Status	C	C	C
Evaluated as of:	02-03-21	02-03-21	02-03-21

COMPLIANCE CODES: C = Compliance I = Inconsistent Compliance S = Significant Noncompliance
If company is in I or S, then the following table applies:

Quarter	Type of Violation	Date of Violation	Sample Composite or Grab	Limit Federal or City	Monitoring City or IU	Parameter	Value / Limit	Number of Measurements per Quarter
			1st Quarter (Jan 1 – Mar 31)	2nd Quarter (Apr 1 - Jun 30)	3rd Quarter (Jul 1 – Sep 30)	4th Quarter (Oct 1 - Dec 31)		
Enforcement Status			N	N	N	N		

Enforcement Status Codes

- | | | |
|---------------------------------------------|--------------------------------------|-----------------------------------------------------------------------------------------|
| A - Notice of Violation (NOV) | F - Assessment of Monetary Penalties | K - Published in Newspaper for Significant Non-Compliance (SNC) In Prior Reporting Year |
| B - Administrative Order (AO) | G - Restriction of Flow | L - Temporary Increase in IU Self Monitoring (TISM) |
| C - Civil Action Filed | H - Permit Revocation | N- No Enforcement Action |
| D - Criminal Action Filed | I - Compliance Schedule Issued | |
| E - Pretreatment Settlement Agreement (PSA) | J - Disconnection from Sewer | |

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Mercy Gilbert Medical Center

Process Flow: 85,000 GPD Average Daily Discharge

General Information and type of wastewater treatment	
Mercy Gilbert Medical Center is a Hospital with discharge from their Cooling Tower, Boiler Feed, Humidification, Plaster Trap, Acid Waste Neutralization, Grease Interceptor, Hospital Operations and Associated Rinses.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes X No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00

ENFORCEMENT SUMMARY AND COMMENTS

Company Name: Unique Home Designs, Inc.

Process Flow: 4,000 GPD Average Daily Discharge

General Information and type of wastewater treatment	
Unique Home Designs, Inc. performs powder coating, coating conversion, acid cleaning and associated rinses. Treatment includes pH neutralization.	
First Quarter	
Second Quarter	
Third Quarter	
Fourth Quarter	

To be published for this year in newspaper for Significant Non-Compliance? Yes No

Penalties this reporting Year: Assessed \$ 0.00 Collected \$ 0.00